

iRite®

Programming Language

Programmer Manual



© Rice Lake Weighing Systems. All rights reserved.

Rice Lake Weighing Systems® is a registered trademark of
Rice Lake Weighing Systems.

All other brand or product names within this publication are trademarks or
registered trademarks of their respective companies.

All information contained within this publication is, to the best of our knowledge, complete and
accurate at the time of publication. Rice Lake Weighing Systems reserves the right to make
changes to the technology, features, specifications and design of the equipment without notice.

The most current version of this publication, software, firmware and all other product
updates can be found on our website:

www.ricelake.com

Revision History

This section tracks and describes the current and previous manual revisions for awareness of major updates and when the updates took place.

Revision	Date	Description
–	April 03, 2012	Initial manual release with the launch of the product
M	January 21, 2022	Revision history established after Rev M
N	August 15, 2022	Added additional API parameters
O	October 20, 2023	Clarified database operation descriptions
P	September 10, 2024	Added SendChrArray parameter to Serial I/O API reference
Q	September 19, 2025	Updated API references
R	January 22, 2026	Added Alibi API parameters
S	March 9, 2026	Updated WeightCollection API parameters

Table i. Revision Letter History



Technical training seminars are available through Rice Lake Weighing Systems. Course descriptions and dates can be viewed at www.ricelake.com/training or obtained by calling 715-234-9171 and asking for the training department.

Contents

1.0	Introduction	7
1.1	Overview	7
1.2	iRite Programs	7
1.3	Sound Programming Practices	9
2.0	Tutorial	10
2.1	Program Example with Constants and Variables	11
3.0	Language Syntax	15
3.1	Lexical Elements	15
3.1.1	Identifiers	15
3.1.2	Keywords	15
3.1.3	Constants	15
3.1.4	Delimiters	16
3.2	Program Structure	19
3.3	Declarations	21
3.3.1	Type Declarations	21
3.3.2	Variable Declarations	24
3.3.3	Subprogram Declarations	25
3.4	Statements	27
3.4.1	Assignment Statement	28
3.4.2	Call Statement	28
3.4.3	If Statement	30
3.4.4	Loop Statement	32
3.4.5	Return Statement	34
3.4.6	Exit Statement	34
4.0	Built-in Types	35
4.1	Using SysCode Data	38
5.0	API Reference	39
5.1	Scale Data Acquisition	39
5.1.1	Weight Acquisition	39
5.1.2	Weight Data Recording	41
5.1.3	Tare Manipulation	43
5.1.4	Rate of Change	45
5.1.5	Accumulator Operations	46
5.1.6	Scale Operation	48
5.1.7	Calibration Data	53
5.2	System Support	54
5.3	Serial I/O	61
5.3.1	880 Port Numbering	65
5.4	Program Scale	66
5.5	Setpoints and Batching	66
5.6	Digital I/O Control	76
5.7	Fieldbus Data	78
5.8	Analog Output Operation	79
5.9	Email	80



Rice Lake continually offers web-based video training on a growing selection of product-related topics at no cost. Visit www.ricelake.com/webinars

5.10	Pulse Input Operation	80
5.11	Display Operation	81
5.12	Display Programming	82
5.12.1	Setting Widget Colors	88
5.12.2	Image Widget Icons	89
5.12.3	Display Charting	90
5.13	Database Operation	91
5.13.1	iRite SQL Feature	94
5.14	Timer Control	97
5.15	Mathematical Operations	99
5.16	Bit-Wise Operation	100
5.17	String Operations	101
5.18	Data Conversion	103
5.19	High Precision	104
5.20	File I/O	104
5.21	882D Belt Scale Data Acquisition	109
5.22	Alibi Records	112
6.0	Appendix	113
6.1	Event Handlers	113
6.2	Compiler Error Messages	115
6.3	Database Operations	116
6.3.1	Uploading	116
6.3.2	Exporting	116
6.3.3	Importing	117
6.3.4	Clearing	117
6.3.5	Downloading	117
6.4	Fieldbus User Program Interface	118
6.5	Program to Retrieve Hardware Configuration	120
6.6	920i User Graphics	121



Technical training seminars are available through Rice Lake Weighing Systems. Course descriptions and dates can be viewed at www.ricelake.com/training or obtained by calling 715-234-9171 and asking for the training department.



Rice Lake continually offers web-based video training on a growing selection of product-related topics at no cost. Visit www.ricelake.com/webinars

1.0 Introduction

iRite is a programming language developed by Rice Lake Weighing Systems to be used with a programmable indicator.

Similar to other programming languages, iRite has a set of rules, called syntax, for composing instructions in a format that a compiler can understand.

This manual is intended for use by programmers who write iRite applications for digital weight indicators.



WARNING: All programs should be thoroughly tested before implementation in a live system. To prevent personal injury and equipment damage, software-based interrupts must always be supplemented by emergency stop switches and other safety devices necessary for the application.



Manuals are available from Rice Lake Weighing Systems at www.ricelake.com/manuals

Warranty information is available at www.ricelake.com/warranties

1.1 Overview

An iRite program is a text file, which contains statements composed following the iRite language syntax. The text file created using the iRite programming language must be compiled before use, this is done using a compiler program.

The compiler reads the text file and translates the program's intent into commands that are understandable to the indicators serial interface.

Other programming languages are often general and try to maximize flexibility in applications, therefore they have a lot of overhead and functionality that the programmer does not need.

With a variety of experienced operators that will be doing most of the iRite programming, there was a need for a language that was easy to learn and use for all programmers, but still familiar in syntax for the experienced programmer.

While creating the new language, the best features from other languages were used. The result is iRite: a compact language (only six discrete statement types, three data types) with a general syntax similar to Pascal and Ada, the string manipulation of Basic, and a rich set of function calls and built-in types specific to the weighing and batching industry.

1.2 iRite Programs

Each of the indicator tasks share processor time, but some tasks have higher priorities than others. If a low priority task is taking more than its share of processor time, it will be suspended so a higher priority task is given processor time when it needs it. When all the other higher priority tasks have completed, the low priority task will be resumed.

Gathering analog weight signals and converting it to weight data is the indicator's highest priority. Running a user-defined program has a very low priority. Streaming data out a serial port is the lowest priority task, because of its minimal computational requirements. This means that if the iRite program **hangs**, the task of streaming out the serial ports will never get any CPU time and streaming will never happen. An example of interrupting a task would be if a user program included an event handler for **SP1Trip** (Setpoint 1 Trip Event) and this event **fired**.

The logic for the SP1Trip event is executing at a given moment in time. In this example, the programmer wanted to display the message **Setpoint 1 Tripped** on the display. If the **SP1Trip** event logic does not complete by the time the indicator needs to calculate a new weight, the **SP1Trip** handler will be interrupted immediately, a new weight will be calculated, and the **SP1Trip** event will resume executing exactly where it was interrupted. In most circumstances, this happens so quickly the user will never know that the **SP1Trip** handler was ever interrupted.

Write and Compile iRite Programs

Templates and sample programs are available from Rice Lake Weighing Systems to provide the skeleton of a working program. With the iRite editor open, the program can be written. iRite source files are named with the **.src** extension.

In addition to writing **.src** files, a file with **.iri extension can also be written**. An **.iri** file is used to define frequently used, similar subprograms that can then be included in the **.src** file with the **#include** API. Because iRite enforces declaration before use, the **#include** statement must be placed before any of the subprograms that use components of the **.iri** file and after any variables, constants and subprograms the **.iri** may need to use. For example, one could create a file called **string.iri** that contains user created subprograms for string manipulation such as parsing, locating, trimming, etc that are not part of the current iRite API. When compiled in the iRite editor, the compiler takes the contents of the **.iri** file and places the entirety of it in the place of the **#include** statement.

When ready to compile the program, use the **Compile** feature from the **Tools** menu in the Revolution editor. If the program compiles without errors a new text file is created. This new text file has the same name but an extension of **.cod**. The new file named **your_program.cod** is a text file containing commands that can be sent to the indicator via a serial communication connection. Do not edit the **.cod** file.

iRite Editors

There are three iRite Editors that can be used:

- Revolution's 88X and 1280 modules have built-in editors for the 88X and 1280 indicators
- iRev has a built-in editor for the 920i
- New in 2017 is VSCode iRite Extension; this has features for programmers like syntax highlighting, snippets and pre-processing; to use VSCode, download the application from, <http://code.visualstudio.com/download> and within VSCode, add the iRite extensions




Figure 1-1. iRite Extensions

Install the Program in the Indicator

The indicator must be in configuration mode before the **.cod** file can be sent. Use Revolution to send the **.cod** file to the indicator.

The **.cod** file can be sent directly from Revolution by using the **Download Configuration...** selection on the **Communications** menu and specifying to send the **.cod** file.

If the indicator is not in configuration mode, a pop-up message will appear in Revolution indicating it is not in configuration. It is recommended that Revolution or the Revolution Editor is used to send the compiled program to the indicator. This method implements error checking on each string sent to the indicator and helps protect from data transmission errors corrupting the program.

Install and Set up VSCode iRite Editor

1. Install Revolution.
2. Download and Install VSCode from <http://code.visualstudio.com/download>.
3. Open VSCode.
4. Search extensions for Language iRite.
5. Install Language iRite.
6. Create new folder or open an existing one for your iRite project.
7. Create or open a **.src** file.
8. Click the iRite Build button to build.

An **irite.settings.json** file will be generated in this directory when the first build is created. Open this file to edit the desired indicator information.

Running the iRite Program

A program written for an indicator is simply a collection of one or more custom event handlers and their supporting subprograms. A custom event handler is run whenever the associated event occurs. The **ProgramStartup** event is called whenever the indicator is powered up, is taken out of configuration mode, or is sent the RS serial command. It should be straightforward when the other event handlers are called.

*Example: the **DotKeyPressed** event handler is called whenever "." is pressed.*

All events have built-in intrinsic functionality associated with them, although, the intrinsic functionality may be to do nothing. If a custom event handler is written for an event, the custom event handler will be called instead of the intrinsic function, and the default action will be suppressed.

For example, the built-in intrinsic function of the **UNITS** key is to switch between primary, secondary, and tertiary units. If the handler **UnitsKeyPressed** was defined in a user program, then the **UNITS** key no longer switches between primary, secondary, and tertiary units, but instead does whatever is written in the handler **UnitsKeyPressed**. The ability to turn off the custom event handler and return to the intrinsic functionality is provided by the **DisableHandler** function.

It is important to note that only one event handler can be running at a time. This means that if an event occurs while another event handler is running, the new event will not be serviced immediately but instead will be placed in a queue and serviced after the current event is done executing.

This means that if executing within an infinite loop in an event handler, then no other event handlers will ever get serviced. This doesn't mean that the indicator will be totally locked-up: The indicator will still be executing its other tasks, like calculating current weights, and running the setpoint engine. But it will not run any other custom event handlers while one event is executing in an infinite loop.

There are some fatal errors that an iRite program can make that will completely disable the indicator. Some of these errors are **...divide by zero**, **string space exhausted**, and **array bounds violation**. When they occur, the indicator stops processing and displays a fatal error message on the display. Power must be cycled to reset the indicator.

After the indicator has been restarted, it should be put into setup mode, and a new version (without the fatal error) of the iRite program should be loaded. If a fatal error occurs in the ProgramStartup Handler, then cycling power to the unit will only cause the ProgramStartup Handler to be run again and repeat the fatal error.

In this case, perform a **RESETCONFIGURATION**. The program, along with the configuration, will be erased and set to the defaults. This will allow the reload of the iRite program after the code that generated the fatal error has been corrected and the program re-compiled.

1.3 Sound Programming Practices

When writing source code remember that it has two important functions: it must work and how it works must be clearly documented. With well documented source code, a high quality product is produced that will require minimal maintenance.

iRite source code may need to be reviewed over time, long after the original author has forgotten how the program worked or isn't around to ask. This is why programming is done to a specific standard. The template programs, example programs, and purchased custom programs that are available from Rice Lake Weighing Systems follow a single standard. This standard can be downloaded at www.ricelake.com, or a new standard can be written.

The purpose of a standard is to guide programmers while creating software, when a standard is followed the source code will be easy to follow and understand. A standard documents:

- The recommended style and form for modules, programs, and subprogram headers
- Proper naming conventions for variables and functions
- Guidelines for function size and purpose
- Commenting guidelines and coding conventions

2.0 Tutorial

The first program a programmer typically writes in every language is the “Hello World!” program. Once that has been accomplished, the basic components will be in place and the door will be open to the imagination to start writing real world solutions to some challenging tasks.

Below is the “Hello World!” program in iRite:

```
01          program HelloWorld;
02
03          begin
04              DisplayStatus("Hello, world!");
05          end HelloWorld;
```

This program will display the text “Hello World!” on the indicator’s display in the status message area, every time the indicator is turned on, taken out of configuration mode or reset. Below is a description of each line:

Line 01: **program** HelloWorld;

The first line is the program header. It consists of the keyword **program** followed by the name of the program. The name of the program is arbitrary and made up by the programmer. The program name; however, must follow the identifier naming rules (cannot start with a number or contain a space).

Line 02:

The second line is an optional blank line. Blank lines can be placed anywhere in the program to separate important lines and to make the program easier to read and understand.

Line 03: **begin**

The **begin** keyword is the start of the optional main code body. The optional main code body is actually the ProgramStartup event handler. The ProgramStartup handler is the only event handler that doesn’t have to be specifically named.

Line 04: DisplayStatus("Hello, world!");

The statement DisplayStatus("Hello, world!") is the only statement in the main code body. It is a call to the built-in procedure DisplayStatus with the string constant “Hello, world!” passed as a parameter. The result is the text, "Hello, world!" will be shown in the status area of the display (lower left corner), whenever the startup event is fired.

Line 05: **end** HelloWorld;

The keyword **end** followed by the same identifier for the program name used in line one, HelloWorld, is required to end the program.

Only the first and last lines are required, the program would compile, but it would do nothing. At a minimum, a working program must have at least one event handler, though it doesn’t have to be the ProgramStartup handler. We could have written the HelloWorld program to display “Hello, world!” whenever any key on the keypad was pressed. It would look like this:

```
01          program HelloWorld;
02
03              handler KeyPressed;
04          begin
05              DisplayStatus("Hello, world!");
06          end;
07
08          end HelloWorld;
```

In this version, the **KeyPressed** event handler is used to call the **DisplayStatus** procedure. The **KeyPressed** event will fire any time any key on the keypad is pressed. Notice that the **begin** keyword that started the main code body, and the **DisplayStatus** call have been removed and replaced with the four lines making up the **KeyPressed** event handler definition.

Using the Revolution editor, write the original version of the “Hello, world!” program on the system. After it has compiled the program successfully, download it to the indicator. Once the program has been downloaded and the indicator is put back in run mode, then the text **Hello, world!** should appear on the display.

2.1 Program Example with Constants and Variables

The “Hello, world!” program didn’t use any explicitly declared constants or variables (the string “Hello, world!” is actually a constant, but not explicitly declared). Most useful programs use many constants and variables. The following program will calculate the area of a circle for various length radii.

The program, named **PrintCircleAreas**, is shown below.

```

01      program PrintCircleAreas;
02
03      -- Declare constants and aliases here.
04      g_ciPrinterPort : constant integer := 2;
05
06      -- Declare global variables here.
07      g_iCount : integer := 1;
08      g_rRadius : real;
09      g_rArea : real;
10      g_sPrintText: string;
11
12
13      function CircleArea(rRadius : real) : real;
14      crPi : constant real := 3.141592654;
15      begin
16      -- The area of a circle is defined by: area = pi*(r^2).
17      return (crPi * rRadius * rRadius);
18      end;
19
20
21      begin
22
23      for g_iCount := 1 to 10
24      loop
25
26      g_rRadius := g_iCount;
27      g_rArea := CircleArea(g_rRadius);
28
29      g_sPrintText := "The area of a circle with radius " + RealToString(g_rRadius, 4, 1)
30      + " is " + RealToString(g_rArea, 7, 2);
31
32      WriteLn(g_ciPrinterPort, g_sPrintText);
33
34      end loop;
35
36      end PrintCircleAreas;

```

The PrintCircleAreas program demonstrates variables and constants as well as introducing these important ideas: **for** loop, assignment statement, function declarations, function calling and return parameters, string concatenation, WriteLn procedure, a naming convention, comments, and a couple of data conversion functions.

This program will calculate the areas of circles with radius from 1 to 10 (counting by 1s) and send text like, **The area of a circle with radius 1 is 3.14**, once for each radius, out the communication port 2.

```

01      program PrintCircleAreas;

```

Line 01 is the program header with the keyword **program** and the program identifier **PrintCircleAreas**. This is the same in theory as the **HelloWorld** program header.

Line 03 is a comment. In iRite all comments are started with a `--` (double dash). All text after the double dash up to the end of the line is considered a comment. Comments are used to communicate to any reader what is going on in the program on the specific lines with the comment or immediately following the comment. The `--` can start on any column in a line and can be after, on the same line, as other valid program statements.

Line 4 is a global constant declaration for the communication port that a printer may be connected to. This simple line has many important parts:

```
04          g_ciPrinterPort : constant integer := 2;
```

First, an identifier name is given. Identifier names are made up by the programmer and should accurately describe what the identifier is used for. In the name `g_ciPrinterPort` the “PrinterPort” part tells us that this identifier will hold the value of a port where a printer should be connected. The “`g_ci`” is a prefix used to describe the type of the identifier. When “`g_ciPrinterPort`” is used later on in the program, the prefix may help someone reading the program, even the program’s author, to easily determine the identifier’s data type without having to look back at the declaration.

The “`g_`” in the prefix helps tell us that the identifier is “global”. Global identifiers are declared outside of any subprogram (handler, function, procedure) and have global scope. The term “scope” refers to the region of the program text in which the identifier is known and understood. The term “global” means that the identifier is “visible” or “known” everywhere in the program. Global identifiers can be used within an event handler body, or any procedure or function body. Global identifiers also have “program duration”. The duration of an identifier refers to when or at what point in the program the identifier is understood, and when their memory is allocated and freed. Identifiers with global duration, in the indicator program, are understood in all text regions of the program, and their memory is allocated at program start-up and is re-allocated when the indicator is powered up.

The “`c`” in the prefix helps us recognize that the identifier is a constant. Constants are a special type of identifier that are initialized to a specific value in the declaration and may not be changed anytime or anywhere in the program. Constants are declared by adding the keyword **constant** before the type.

Constants are very useful and make the program more understandable. In this example, we defined the printer port as port 2. If we would have just used the number 2 in the call to `WriteLn`, then a reader of the program would not have any idea that the programmer intended a printer to be connected to the programmable indicator’s port 2.

Also, in a larger program, port 2 may be used hundreds of times in `Write` and `WriteLn` calls. Then, if it were decided to change the printer port from port 2 to port 3, hundreds of changes would have to be made. With port 2 being a constant, only one change in the declaration of `g_ciPrinterPort` would be required to change the printer port from 2 to 3.

The type of the constant is an integer. The “`i`” in the prefix helps us identify `g_ciPrinterPort` as an integer. The keyword **integer** follows the keyword **constant** and specifies the type compatibility of the identifier as an integer and also determines how much memory will be required to store the value (a value of 2 in this example). In the iRite programming language, there are only 3 basic data types: integer, real and string.

The initialization of the constant is accomplished with the “`:= 2`” part of the statement. Initialization of constants is done in the declaration, with the assignment operator, `:=`, followed by the initial value.

Finally, the statement is terminated by a semicolon. The “`;`” is used in iRite and other languages as a statement terminator and separator. Every **statement** must be terminated with a semicolon. Do not read this to mean “every **line** must end in a semicolon”; this is not true. A statement may be written on one line, but it is usually easier to read if the statement is broken down into enough lines to make some keywords stand out and to keep the length of each line less than 80 characters.

Some statements contain one or more other statements.

Example: `g_ciPrinterPort : constant integer := 2;`

The above is an example of a simple statement that easily fit on one line of code. The **loop** statement in the program startup handler (main code body) is spread out over several lines and contains many additional statements. It does, however, end with line **end loop**, and ends in a semicolon.

```
06          -- Declare global variables here.
07          g_iCount : integer := 1;
08          g_rRadius : real;
09          g_rArea : real;
10          g_sPrintText: string;
```

Line 6 is another comment to let us know that the global variables are going to be declared.

Lines 7—10 are global variable declarations. One integer, `g_iCounter`, two reals, `g_rRadius` and `g_rArea`, and one string, `g_sPrintText`, are needed during the execution of this program. Like the constant `g_ciPrinterPort`, these identifiers are global in scope and duration; however, they are not constants. They may have an optional initial value assigned to them, but it is not required. Their value may be changed any time they are “in scope”, they may be changed in every region of the program anytime the program is loaded in the indicator.

Lines 13—18 are our first look at a function declaration. A function is a subprogram that can be invoked (or called) by other subprograms. In the `PrintCircleAreas` program, the function `CircleArea` is invoked in the program startup event handler. The radius of a circle is passed into the function when it is invoked. In `iRite` there are three types of subprograms: functions, procedures, and handlers.

```

13         function CircleArea(rRadius : real) : real;
14         crPi : constant real := 3.141592654;
15         begin
16         -- The area of a circle is defined by: area = pi*(r^2).
17         return (crPi * rRadius * rRadius);
18         end;

```

On line 13, the function declaration starts with the keyword **function** followed by the function name. The function name is an identifier chosen by the programmer. We chose the name “CircleArea” for this function because the name tells us that we are going to return the area of a circle. Our function `CircleArea` has an optional formal arguments (or parameters) list. The formal argument list is enclosed in parenthesis, like this: `(rRadius : real)`. Our example has one argument, but functions and procedures may have zero or more.

Argument declarations must be separated by a semicolon. Each argument is declared just like any other variable declaration: starting with an identifier followed by a colon followed by the data type. The exception is that no initialization is allowed. Initialization wouldn’t make sense, since a value is passed into the formal argument each time the function is called (invoked).

The `rRadius` parameters are passed by value. This means that the radius value in the call is copied in `rRadius`. If `rRadius` is changed, there is no effect on the value passed into the function. Unlike procedures, functions may return a value. Our function `CircleArea` returns the area of a circle. The area is a real number. The data type of the value returned is specified after the optional formal argument list. The type is separated with a colon, just like in other variable declarations, and terminated with a semicolon.

Up to this point in our program, we have only encountered global declarations. On line 14 we have a local declaration. A local declaration is made inside a subprogram and its scope and duration are limited. So the declaration: `crPi : constant real := 3.141592654`; on line 14 declares a constant real named `crPi` with a value of 3.141592654. The identifier `crPi` is only known—and only has meaning—inside the text body of the function `CircleArea`. The memory for `crPi` is initialized to the value 3.141592654 each time the function is called.

Line 15 contains the keyword **begin** and signals the start of the function code body. A function code body contains one or more statements.

Line 16 is a comment that explains what we are about to do in line 17. Comments are skipped over by the compiler, and are not considered part of the code. This doesn’t mean they are not necessary; they are, but are not required by the compiler.

Every function must return a value. The value returned must be compatible with the return type declared on line 14. The keyword **return** followed by a value, is used to return a value and end execution of the function. The **return** statement is always the last statement a function runs before returning. A function may have more than one return statement, one in each conditional execution path; however, it is good programming practice to have only one return statement per function and use a temporary variable to hold the value of different possible return values.

The function code body, or statement lists, is terminated with the **end** keyword on line 18.

In this program we do all the work in the program startup handler. We start this unnamed handler with the **begin** keyword on line 21.

```

23         for g_iCount := 1 to 10
24         loop
25
26             g_rRadius := g_iCount;
27             g_rArea := CircleArea(g_rRadius);
28
29             g_sPrintText := "The area of a circle with radius " + RealToString(g_rRadius, 4, 1)
30                 + " is " + RealToString(g_rArea, 7, 2);
31
32             WriteLn(g_ciPrinterPort, g_sPrintText);
33
34         end loop;

```

On line 23 we see a **for** loop to start the first statement in the startup handler. In iRite there are two kinds of looping constructs. The **for** loop and the **while** loop. **For** loops are generally used when you want to repeat a section of code for a predetermined number of times. Since we want to calculate the area of 10 different circles, we chose to use a **for** loop.

For loops use an optional iteration clause that starts with the keyword **for** followed by the name of variable, followed by an assignment statement, followed by the keyword **to**, then an expression, and finally an optional step clause. Our example doesn't use a step clause, but instead uses the implicit step of 1. This means that lines 26 through 32 will be executed ten times. The first time `g_iCount` will have a value of 1, and during the last iteration, `g_iCount` will have a value of 10.

All looping constructs (the **for** and the **while**) start with the keyword **loop** and end with the keywords **end loop**, followed by a semicolon. In our example, **loop** is on line 24 and **end loop** is on line 34. In between these two, are found, the statements that make up the body of the loop.

Line 26 is an assignment of an integer data type into a real data type. This line is unnecessary and the assignment could have been made automatically if the integer `g_iCount` was passed into the function `CircleArea` directly on line 27, since `CircleArea` is expecting a real value. Calls to functions like `CircleArea` are usually done in an assignment statement if the functions return value need to be used later in the program. The return value of `CircleArea` (the area of a circle with radius `g_rRadius`) is stored in `g_rArea`.

The assignment on lines 29 and 30 uses two lines strictly for readability. This single assignment statement does quite a bit. We are trying to create a string of plain English text that will say: "The area of a circle with radius xx.x is yyyy.yy", where the radius value will be substituted for xx.x and the calculated area will be substituted for yyyy.yy. The global variable `g_sPrintText` is a string data type. The constants (or literals): "The area of a circle with radius " and " is " are also strings.

However, `g_rRadius` and `g_iArea` are real values. We had to use a function from the API to convert the real values to strings. The API function `RealToString` is passed a real and a width integer and a precision integer. The width parameter specifies the minimum length to reserve in the string for the value. The precision parameter specifies how many places to report to the right of the decimal place. To concatenate all the small strings into one string we use the string concatenation operator, "+".

Finally, we want to send the new string we made to a printer. The `Write` and `WriteLn` procedures from the API send text data to a specified port. Earlier in the program we decided the printer port will be stored in `g_ciPrinterPort`. So the `WriteLn` call on line 32 send the text stored in `g_sPrintText`, followed by a carriage return character, out port 2.

If we had a printer connected to port 2 on the programmable indicator, every time the program startup handler is fired, we would see the following printed output:

```

The area of a circle with radius 1.0 is 3.14
The area of a circle with radius 2.0 is 12.57
The area of a circle with radius 3.0 is 28.27
The area of a circle with radius 4.0 is 50.27
The area of a circle with radius 5.0 is 78.54
The area of a circle with radius 6.0 is 113.10
The area of a circle with radius 7.0 is 153.94
The area of a circle with radius 8.0 is 201.06
The area of a circle with radius 9.0 is 254.47
The area of a circle with radius 10.0 is 314.16

```

3.0 Language Syntax

This section provides an overview of language syntax for the iRite software.

3.1 Lexical Elements

For details about lexical elements, see the following information:

3.1.1 Identifiers

An identifier is a sequence of letters, digits, and underscores. The first character of an identifier must be a letter or an underscore, and the length of an identifier cannot exceed 100 characters. Identifiers are not case-sensitive: “HELLO” and “hello” are both interpreted as “HELLO”.

Examples:

Valid identifiers: Variable12
 _underscore
 Std_Deviation

Not valid identifiers: 9abc First character must be a letter or an underscore.
 ABC DEF Space (blank) is not a valid character in an identifier.

Identifiers are used by the programmer to name programs, data types, constants, variables, and subprograms. They can be named anything as long as they follow the rules above and the identifiers are not already used as a keyword or as a built-in type or built-in function. Identifiers provide the name of an entity. Names are bound to program entities by declarations and provide a simple method of entity reference. For example, an integer variable iCounter (declared iCounter : integer) is referred to by the name iCounter.

3.1.2 Keywords

Keywords are special identifiers that are reserved by the language definition and can only be used as defined by the language. The keywords are listed below for reference purposes. More detail about the use of each keyword is provided later in this manual.

and	array	begin	builtin	constant	database
else	elseif	end	exit	for	function
handler	if	integer	is	loop	mod
not	of	or	procedure	program	real
record	return	step	stored	string	then
to	type	var	while		

3.1.3 Constants

Constants are tokens representing fixed numeric or character values and are a necessary and important part of writing code. Here we are referring to constants placed in the code when a value or string is known at the time of programming and will never change once the program is compiled. The compiler automatically figures out the data type for each constant.



NOTE: Be careful not to confuse the constants in this discussion with identifiers declared with the keyword constant, although they may both be referred to as constants.

The three types of constants are defined by the language as described in the following sections.

Constant Integer

A constant integer is a sequence of decimal digits. The value of constant integer is limited to the range $0 \dots 2^{31} - 1$ (+/- 2,147,483,647). **Any values outside the allowed range are silently truncated.**

Any time a whole number is used in the text of the program, the compiler creates a constant integer.

Constant Real

A constant real is a constant integer immediately followed by a decimal point and another constant integer. Constant Reals conform to the requirements of IEEE-754 for double-precision floating point values. When the compiler sees a number in the format **n.n** then a constant real is created.

Using the value .56 would generate a compiler error. Instead compose constant reals between -1 and +1 with a leading zero like this: 0.56 and -0.667.

Constant String

A constant string is a sequence of printable characters delimited by quotation marks (double quotes, "). The maximum length allowed for a constant string is 1000 characters, including the delimiters.

3.1.4 Delimiters

Delimiters include all tokens other than identifiers and keywords, including the arithmetic operators listed below:

```

>=    <=    <>    :=    ><    =    +    -    *    /
.     ,     ;     :     (     )    [     ]    "

```

Below is a functional grouping of all of the delimiters in iRite.

Punctuation

Parentheses

() (open and close parentheses) group expressions, isolate conditional expressions, and indicate function parameters:

```

iFahrenheit := ((9.0/5.0) * iCelsius) + 32; -- enforce proper precedence
if (iVal >= 12) and (iVal <= 34) or (iMaxVal > 200) -- conditional expr.
EnableSP(5); -- function parameters

```

Brackets

[] (open and close brackets) indicate single and multidimensional array subscripts:

```

type CheckerBoard is array [8, 8] of recSquare;
iThirdElement := aiValueArray[3];

```

Comma

The comma(,) separates the elements of a function argument list and elements of a multidimensional array:

```

type Matrix is array [4,8] of integer;
GetFilteredCount(iScale, iCounts);

```

Semicolon

The semicolon (;) is a statement terminator. Any legal iRite expression followed by a semicolon is interpreted as a statement.

Colon

The colon (:) is used to separate an identifier from its data type. The colon is also used in front of the equal sign (=) to make the assignment operator:

```

function GetAverageWeight(iScale : integer) : real;
iIndex : integer;
csCopyright : constant string := "2002 Rice Lake Weighing Systems";

```

Quotation Mark

Quotation marks (") are used to signal the start and end of string constants:

```

if sCommand = "download data" then
  Write(iPCPort, "Data download in progress. Please wait...");

```

Relational Operators

Greater than (>)
 Greater than or equal to (>=)
 Less than (<)
 Less than or equal to (<=)

Equality Operators

Equal to (=)
 Not equal to (<>)

The relational and equality operators are only used in an **if** expression. They may only be used between two objects of compatible type, and the resulting construct will be evaluated by the compiler to be either true or false;

```
if iPointsScored = 6 then
if iSpeed > 65 then
if rGPA <= 3.0 then
if sEntry <> "2" then
```



NOTE: Be careful when using the equal to (=) operator with real data. Because of the way real data is stored and the amount of precision retained, it may not contain what would be expected.

Example, given a real variable named rTolerance:

```
rTolerance := 10.0 / 3.0
...
if rTolerance * 3 = 10 then
  -- do something
end if;
```



NOTE: The evaluation of the if statement will resolve to false. The real value assigned to rTolerance by the expression 10.0 / 3.0 will be a real value (3.333333) that, when multiplied by 3, is not quite equal to 10.

Logical Operators

These are keywords and not delimiters. In iRite the logical operators are **and**, **or**, and **not**. They are named **logical and**, **logical or**, and **logical negation** respectively. They are only used in an **if** expression and can only be used with expressions or values that evaluate to true or false.

```
if (iSpeed > 55) and (not flgInterstate) or (strOfficer = "Cranky") then
  sDriverStatus := "Busted";
```

Arithmetic Operators

The arithmetic operators (+, -, *, /, and **mod**) are used in expression to add, subtract, multiply, and divide integers and real values. Multiplication and division take precedence over addition and subtraction. A sequence of operations with equal precedence is evaluated from left to right.

The keyword **mod** is not a delimiter, but is included here because it is also an arithmetic operator. The modulus (or remainder) operator returns the remainder when operand 1 is divided by operand 2.

Example:

```
rResult : 7 mod 3; -- rResult should equal 1
```



NOTE: Both division (/) and mod operations can cause the fatal divide-by-zero error if the second operand is zero.

When using the divide operator with integers, be careful of losing significant digits.

Example: If dividing a smaller integer by a larger integer then the result is an integer zero: $4/7 = 0$. If planning to assign the result to a real like in the following example:

```
rSlope : real;
rSlope := 4/7;
```

rSlope will still equal 0, not 0.571428671 as might be expected. This is because the compiler does integer math when both operands are integers, and stores the result in a temporary integer. To make the previous statement work in iRite, one of the operands must be a real data type or one of the operands must evaluate to a real.

So write the assignment statement like:

```
rSlope := 4.0/7;
```

If dividing two integer variables, multiply one of the operands by 1.0 to force the compile to resolve the expression to a real:

```
rSlope : real;
iRise : integer := 4;
iRun : integer := 7;
rSlope := (iRise * 1.0) / iRun;
```

Now rSlope will equal 0.571428671.



NOTE: The plus sign (+) is also used as the string concatenation operator. The minus sign (-) is also used as a unary minus operator that has the result equal to the negative of its operand.

Assignment Operator (:=)

The assignment operator is used to assign a value to a compatible program variable or to initialize a constant. The value on the left of the “:=” must be a modifiable value.

Invalid examples:

```
3 := 1 + 1; -- not valid
ciMaxAge := 67; -- where ciMaxAge was declared with keyword constant
iInteger := "This is a string, not an integer!"; -- incompatible types
```

Structure Member Operator (“dot”)

The “dot” (.) is used to access the name of a field of a record or database types.

3.2 Program Structure

A program is delimited by a program header and a matching end statement. The body of a program contains a declarations section, which may be empty, and an optional main code body. The declaration section and the main code body may not both be empty.

```

<program>:
  program IDENTIFIER ';'
    <decl-section>
    <optional-main-body>
  end IDENTIFIER ';'
;
<optional-main-body>:
  /* NULL */
  | begin <stmt-list>
;

```




Figure 3-1. Program Statement Syntax

The declaration section contains declarations defining global program types, variables, and subprograms. The main code body, if present, is assumed to be the declaration of the program startup event handler. A program startup event is generated when the instrument personality enters operational mode at initial power-up and when exiting setup mode.

Example:

```

program MyProgram;
  KeyCounter : Integer;
  handler AnyKeyPressed;
  begin
    KeyCounter := KeyCounter + 1;
  end;

begin
  KeyCounter := 0
end MyProgram;

```

The iRite language requires declaration before use so the order of declarations in a program is very important. The declaration before use requirement is imposed to prevent recursion, which is difficult for the compiler to detect.

In general, it make sense for certain types of declarations to always come before others types of declarations. For example, functions and procedures must always be declared before the handlers. Handlers cannot be called or invoked from within the program, only by the event dispatching system. But functions and procedures can be called from within event handlers; therefore, always declare the functions and procedures before handlers.

Another example would be to always declare constants before type definitions. This way you can size an array with named constants.

Example program with a logical ordering for various elements:

```

program Template; -- program name is always first!
-- Put include (.iri) files here.
#include template.iri

-- Constants and aliases go here.
g_csProgName : constant string := "Template Program";
g_csVersion : constant string := "0.01";
g_ciArraySize : integer := 100;

-- User defined type definitions go here.
type tShape is (Circle, Square, Triangle, Rectangle, Octagon, Pentagon, Dodecahedron);

type tColor is (Blue, Red, Green, Yellow, Purple);

type tDescription is
  record
    eColor : tColor;
    eShape : tShape;
  end record;

type tBigArray is array [g_ciArraySize] of tDescription;

-- Variable declarations go here.
g_iBuild : integer;
g_srcResult : SysCode;
g_aArray : tBigArray;
g_rSingleRecord : tDescription;

-- Start functions and procedures definitions here.

function MakeVersionString : string;
  sTemp : string;
begin
  if g_iBuild > 9 then
    sTemp := ("Ver " + g_csVersion + "." + IntegerToString(g_iBuild, 2));
  else
    sTemp := ("Ver " + g_csVersion + ".0" + IntegerToString(g_iBuild, 1));
  end if;

  return sTemp;
end;

procedure DisplayVersion;
begin
  DisplayStatus(g_csProgName + " " + MakeVersionString);
end;
-- Begin event handler definitions here.
handler User1KeyPressed;
begin
  DisplayVersion;
end;

-- This chunk of code is the system startup event handler.
begin
  -- Initialize all global variables here.
  -- Increment the build number every time you make a change to a new version.
  g_iBuild := 3;

  -- Display the version number to the display.
  DisplayVersion;
end Template;

```

3.3 Declarations

For declaration details, see the following information:

3.3.1 Type Declarations

Type declarations provide the mechanism for specifying the details of enumeration and aggregate types. The identifier representing the type name must be unique within the scope in which the type declaration appears. All user-defined types must be declared prior to being used.

```

<type-declaration>:
    type IDENTIFIER is <type-definition> ';'
;
<type-definition>:
    <record-type-definition>
  | <array-type-definition>
  | <database-type-definition>
  | <enum-type-definition>
;
  
```




Figure 3-2. Type Declaration Syntax



Figure 3-3. Identifier Syntax




Figure 3-4. Type Declaration Syntax

Enumeration Type Definitions

An enumeration type definition defines a finite ordered set of values. Each value, represented by an identifier, must be unique within the scope in which the type definition appears.

```
<enum-type-definition>:
    '(' <identifier-list> ')'
    ;
<identifier-list>:
    IDENTIFIER
    | <identifier-list> ',' IDENTIFIER
    ;
```

Examples:

type StopLightColors **is** (Green, Yellow, Red);

type BatchStates **is** (NotStarted, OpenFeedGate, CloseGate, WaitforSS, PrintTicket, AllDone);

Record Type Definitions

A record type definition describes the structure and layout of a record type. Each field declaration describes a named component of the record type. Each component name must be unique within the scope of the record; no two components can have the same name. Enumeration, record and array type definitions are not allowed as the type of a component: only previously defined user- or system-defined type names are allowed.

```
<record-type-definition>:
    record
    <field-declaration-list>
    end record
    ;
<field-declaration-list>:
    <field-declaration>
    | <field-declaration-list>
    <field-declaration>
    ;
<field-declaration>:
    IDENTIFIER ':' <type> ';'
    ;
```




Figure 3-5. Record Type Definition Syntax

Examples:

type MyRecord **is**
record
 A : **integer**;
 B : **real**;
end record;

The EmployeeRecord record type definition, below, incorporates two enumeration type definitions, tDepartment and tEmptype:

```
type tDepartment is (Shipping, Sales, Engineering, Management);
```

```
type tEmptype is (Hourly, Salaried);
```

```
type EmployeeRecord is
  record
    ID : integer;
    Last : string;
    First : string;
    Dept : tDepartment;
    EmployeeType : tEmptype;
  end record;
```

Database Type Definitions

A database type definition describes a database structure, including an alias used to reference the database.

```
<database-type-definition>:
  database (STRING_CONSTANT)
    <field-declaration-list>
  end database
;
<field-declaration-list>:
  <field-declaration>
  | <field-declaration-list>
  <field-declaration>
;
<field-declaration>:
  IDENTIFIER ':' <type> ';'
;
;
```




Figure 3-6. Database Type Definition Syntax

Example: A database consisting of two fields, an integer field and a real number, could be defined as follows:

```
type MyDB is
  database ("DBALIAS")
    A : integer
    B : real
  end database;
;
```

Array Type Definitions

An array type definition describes a container for an ordered collection of identically typed objects. The container is organized as an array of one or more dimensions. All dimensions begin at index 1.

```
<array-type-definition>:
    array '[' <expr-list> ']' of <type>
    ;
```



Figure 3-7. Array Type Definition Syntax

Examples:

```
type Weights is array [25] of Real;
```

An array consisting of user-defined records could be defined as follows:

```
type Employees is array [100] of EmployeeRecord;
```

A two-dimensional array in which each dimension has an index range of 10 (1...10), for a total of 100 elements could be defined as follows:

```
type MyArray is array [10,10] of Integer;
```



NOTE: In all of the preceding examples, no variables (objects) are created, no memory is allocated by the type definitions. The type definition only defines a type for use in a later variable declaration, at which time memory is allocated.

3.3.2 Variable Declarations

A variable declaration creates an object of a particular type. The type specified must be a previously defined user- or system-defined type name. The initial value, if specified, must be type-compatible with the declared object type. All user-defined variables must be declared before being used.

Variables declared with the keyword **stored** cause memory to be allocated in battery-backed RAM. Stored data values are retained even after the indicator is powered down.

Variables declared with the keyword **constant** must have an initial value.

```
<variable-declaration>:
    IDENTIFIER ':' <stored-option> <constant-option> <type>
    <optional-initial-value>
    ;
<stored-option>:
    /* NULL */
    | stored
    ;
<constant-option>:
    /* NULL */
    | constant
    ;
<optional-initial-value>:
    /* NULL */
    | := <expr>
    ;
```

Example:

```
MyVariable : StopLightColor; -- Declare MyVariable
MyCount : stored Integer; --Declare a stored variable of type Integer
```

3.3.3 Subprogram Declarations

A subprogram declaration defines the formal parameters, return type, local types and variables, and the executable code of a subprogram. Subprograms include handlers, procedures, and functions.

Handler Declarations

A handler declaration defines a subprogram that is to be installed as an event handler. An event handler does not permit parameters or a return type, and can only be invoked by the event dispatching system.

```
<handler-declaration>:
  handler IDENTIFIER ';'
    <decl-section>
  begin
    <stmt-list>
  end ';'
;
```




Figure 3-8. Handler Declaration Syntax

Example:

```
handler SP1Trip;

I : Integer;

begin
  for I := 1 to 10
  loop
    Writeln (1, "Setpoint Tripped!");
    if I=2 then
      return;
    endif;
  end loop;
end;
```

Procedure Declarations

A procedure declaration defines a subprogram that can be invoked by other subprograms. A procedure allows parameters but not a return type. A procedure must be declared before it can be referenced; recursion is not supported.

```

<procedure-declaration>:
    procedure IDENTIFIER
        <optional-formal-args> ';'
        <decl-section>
        begin
            <stmt-list>
        end ';
;
<optional-formal-args>:
    /* NULL */
    | <formal-args>
;
<formal-args>:
    '(' <arg-list> ')'
;
<arg-list>:
    <optional-var-spec>
    <variable-declaration>
    | <arg-list> ';' <optional-var-spec>
    <variable-declaration>
;
<optional-var-spec>:
    /* NULL */
    | var
;

```




Figure 3-9. Procedure Declaration Syntax

Examples:

```

procedure PrintString (S : String);
begin
    Writeln (1, "The String is => ",S);
end;

```

```

procedure ShowVersion;
begin
    DisplayStatus ("Version 1.42");
end;

```

```

procedure Inc (var iVarible : Integer);
begin
    iVarible := iVarible + 1;
end;

```

Function Declarations

A function declaration defines a subprogram that can be invoked by other subprograms. A function allows parameters and requires a return type. A function must be declared before it can be referenced; recursion is not supported. A function must return to the point of call using a return-with-value statement.

```
<function-declaration>:
  function IDENTIFIER
  <optional-formal-args> ':' <type> ':'
  <decl-section>
  begin
  <stmt-list>
  end ':'
  ;
```




Figure 3-10. Function Declaration Syntax

Examples:

```
function Sum (A : integer; B : integer) : Integer;
begin
  return A + B;
end;
```

```
function PoundsPerGallon : Real;
begin
  return 8.34;
end;
```

3.4 Statements

There are only six discrete statements in iRite. Some statements, like the **if**, **call**, and assignment (**:=**) are used extensively even in the simplest program, while the **exit** statement should be used rarely. The **if** and the **loop** statements have variations and can be quite complex.

```
<stmt>:
  <assign-stmt>
  | <call-stmt>
  | <if-stmt>
  | <return-stmt>
  | <loop-stmt>
  | exit-stmt
  ;
```

3.4.1 Assignment Statement




Figure 3-11. Assignment Statement Syntax

The assignment statement uses the assignment operator (`:=`) to assign the expression on the right-hand side to the object or component on the left-hand side. The types of the left-hand and right-hand sides must be compatible. The value on the left of the `:=` must be a modifiable value.

Examples:

Simple assignments:

```
iMaxPieces := 12000;
rRotations := 25.3456;
sPlaceChickenPrompt := "Please place the chicken on the scale...";
```

Assignments in declarations (initialization):

```
iRevision : integer := 1;
rPricePerPound : real := 4.99;
csProgramName : constant string := "Pig and Chicken Weigher";
```

Assignments in **for** loop initialization:

```
for iCounter := 1 to 25
for iTries := ciFirstTry to ciMaxTries
```

Assignment of function return value:

```
sysReturn := GetSPTIME(4, dtDateTime);
rCosine := Cos(1.234);
```

Assignment with complex expression on right-hand side:

```
iTotalLivestock := iNumChickens + iNumPigs + GetNumCows;
rTotalCost := ((iNumBolt * rBoltPrice) + (iNumNuts * rNutPrice)) * (1 + rTaxRate);
sOutputText := The total cost is : " + RealToString(rTotalCost, 4, 2) + " dollars.";
```

Assignment of different but compatible types:

```
iValue := 34.867; -- Loss of significant digits! iValue will equal 34, no rounding!
rDegrees := 212; -- No problem! rDegrees will equal 212.000000000000000000
```

3.4.2 Call Statement

The call statement is used to initiate a subprogram invocation. The number and type of any actual parameters are compared against the number and type of the formal parameters that were defined in the subprogram declaration. The number of parameters must match exactly. The types of the actual and formal parameters must also be compatible. Parameter passing is accomplished by copy-in, or by copy-in/copy-out for **var** parameters.

```
<call-stmt>:
  <name> '('
  ;
```

Copy-in refers to the way value parameters are copied into their corresponding formal parameters. The default way to pass a parameter in iRite is by value, which means that a copy of the actual parameter is made to use in the function or procedure. The copy may be changed inside the function or procedure but these changes will never affect the value of the actual parameter outside of the function or procedure, since only the copy may be changed.

The other way to pass a parameter is to use a copy-in/copy-out method. To specify this method, a formal parameter must be preceded by the keyword **var** (variable) in the subprogram declaration. This means the parameter may be changed. Just like with a **value** parameter, a copy is made. When the function or procedure is done executing, the value of the copy is then copied, or assigned, back into the actual parameter. This is the copy-out part. The result is that if the formal **var** parameter was changed within the subprogram, then the actual parameter will also be changed after the subprogram returns. Actual **var** parameters must be values: a constant cannot be passed as a **var** parameter.

A potential issue occurs when passing a global parameter as a **var** parameter. If a global parameter is passed to a function or procedure as a **var** parameter, then the system makes a copy of it to use in the function body. If the value of the formal parameter is changed and some other function or procedure call is made after the change to the formal parameter, the function or procedure called uses, by name, the same global parameter that was passed into the original function. Then the value of the global parameter in the second function will be the value of the global when it was pass into the original function. This is because the changes made to the formal parameter (only a copy of the actual parameter passed in) have not yet been copied-out, since the function or procedure has not returned yet.

Example:

```
program GlobalAsVar;

g_ciPrinterPort : constant integer := 2;

g_sString : string := "Initialized, not changed yet";

procedure PrintGlobalString;
begin
  WriteLn(g_ciPrinterPort, g_sString);
end;

procedure SetGlobalString (var vsStringCopy : string);
begin

  vsStringCopy := "String has been changed";

  Write(g_ciPrinterPort, "In function call: ");
  PrintGlobalString;

end;
begin
  Write(g_ciPrinterPort, "Before function call: ");
  PrintGlobalString;

  SetGlobalString(g_sString);

  Write(g_ciPrinterPort, "After function call: ");
  PrintGlobalString;

end GlobalAsVar;
```

When run, the program prints the following:

```
Before function call: Initialized, not changed yet
In function call: Initialized, not changed yet
After function call: String has been changed
```

3.4.3 If Statement




Figure 3-12. If Statement Syntax

The **if** statement is one of the programmer's most useful tools. The **if** statement is used to force the program to execute different paths based on a decision. In its simplest form, the **if** statement looks like this:

```

if <expression> then
  <statement list>
end if;

```

The decision is made after evaluating the expression. The expression is most often a conditional expression. If the expression evaluates to true, then the statements in **<statement list>** are executed. This form of the **if** statement is used primarily to only do something if a certain condition is true.

Example:

```

if iStrikes = 3 then
  sResponse := "You're out!";
end if;

```




Figure 3-13. Optional Else Statement Syntax

Another form of the **if** statement, known as the **if-else** statement has the general form:

```

if <expression> then
  <statement list 1>
else
  <statement list 2>
end if;

```

The **if-else** is used when the program must decide which of exactly two different paths of execution must be executed. The path that will execute the statement or statements in **<statement list 1>** will be chosen if **<expression>** evaluates to true.

Example:

```

if iAge => 18 then
  sStatus := "Adult";
else
  sStatus := "Minor";
end if;

```

If the statement is false, then the statement or statements in **<statement list 2>** will be executed. Once the expression is evaluated and one of the paths is chosen, the expression is not evaluated again. This means the statement will terminate after one of the paths has been executed.

*Example: If the expression was true and we were executing <statement list 1>, and within the code in <statement list 1> we change some part of <expression> so it would at that moment evaluate to false, <statement list 2> would still not be executed. This point is more relevant in the next form called the **if-elsif**.*




Figure 3-14. Optional Else-If Statement Syntax

The **if-elsif** version is used when a multi-way decision is necessary and has this general form:

```

if <expression> then
  <statement list 1>
elsif <expression> then
  <statement list 2>
elsif <expression> then
  <statement list 3>
elsif <expression> then
  <statement list 4>
else
  <statement list 5>
end if;

```

Example:

```

if rWeight <= 2.0 then
  iGrade := 1;
elsif (rWeight > 2.0) and (rWeight < 4.5) then
  iGrade := 2;
elsif (rWeight > 4.5) and (rWeight < 9.25) then
  iGrade := 3;
elsif (rWeight > 9.25) and (rWeight < 11.875) then
  iGrade := 4;
else
  iGrade := 0;
  sErrorString := "Invalid Weight!";
end if;

```

3.4.4 Loop Statement




Figure 3-15. Loop Statement Syntax

The **loop** statement is used to execute a statement list 0 or more times. An optional expression is evaluated and the statement list is executed. The expression is then re-evaluated and as long as the expression is true the statements will continue to get executed. The **loop** statement in iRite has three general forms. One way is to write a loop with no conditional expression. The loop will keep executing the loop body (the statement list) until the **exit** statement is encountered. The **exit** statement can be used in any **loop**, but is most often used in this version without a conditional expression to evaluate. It has this form:

```

loop
  <statement list>
end loop;

```

This version is most often used with an **if** statement at the end of the statement list. This way the statement list will always execute at least once. This is referred to as a **loop-until**.

Example:

```
rGrossWeight : real;
```

```

loop
  WriteLn(2, "I'm in a loop.");
  GetGross(1, Primary, rGrossWeight);
  if rGrossWeight > 200 then
    exit;
  end if;
end loop;

```

A similar version uses an optional **while** clause at the start of the loop. The **while-loop** version is used when the loop is to execute zero or more times. Since the expression is evaluated before the loop is entered, the statement list may not get executed even once. Here is the general form for the **while-loop** statement:

```

while <expression>
loop
  <statement list>
end loop;

```

*Example: from above, the statement has a **while** clause. If the gross weight is greater than 200 pounds then the loop body will never execute:*

```
rGrossWeight : real;
```

```
GetGross(1, Primary, rGrossWeight);
```

```

while rGrossWeight <= 200
loop
  WriteLn(2, "I'm in a loop.");
  GetGross(1, Primary, rGrossWeight);
end loop;

```

*Example: the weight must be known before we could evaluate the expression. In addition we have to get the weight in the loop. In this example, it would be better programming to use the **loop-until** version.*

Another version is known as the **for-loop**. The **for-loop** is best used when you want to execute a chunk of code for a known or predetermined number of times. In its general form the **for-loop** looks like this:

```
for <name> := <expression> to <expression> step <expression>
loop
  <statement list>
end loop;
```




Figure 3-16. Optional Loop Iteration Clause Syntax

The optional step clause can be omitted if **<name>** is to increment by 1 after each run of the statement list. To increment **<name>** by 2 or 3, or decrement it by 1 or 2, then use the step clause. The step expression (–1 in the second example below) must be a constant.

```
for iCount := 97 to 122
loop
  strAlpha := strAlpha + chr$(iCount);
end loop;

for iCount := 10 to 0 step -1
loop
  if iCount = 0 then
    strMissionControl := "Blast off!";
  else
    strMissionControl := IntegerToString(iCount, 2);
  end if;
end loop;
```




Figure 3-17. Optional Step Clause Syntax



NOTE: Use caution when designing loops to ensure that an infinite loop is not created. If the program encounters an infinite loop, only the loop will run; subsequent queued events will not be run.

3.4.5 Return Statement

The **return** statement can only be used inside of subprograms (functions, procedures, and event handlers). The **return** statement in procedures and handlers cannot return a value. An explicit return statement inside a procedure or handler is not required since the compiler will insert one if the **return** statement is missing. To return from a procedure or handler before the code body is done executing, use the **return** statement to exit at that point.

```
procedure DontDoMuch;
begin
if PromptUser("circle: ") <> SysOK then
    return;
end if;
end;
```

Functions must return a value and an explicit **return** statement is required. The data type of the expression returned must be compatible with the return type specified in the function declaration.

```
function Inc(var viNumber : integer) : integer;
begin
viNumber := viNumber + 1;
return viNumber;
end;
```

It is permissible to have more than one **return** statement in a subprogram, but not recommended. In most instances it is better programming practice to use conditional execution (using the **if** statement) with one **return** statement at the end of the function than it is to use a **return** statement multiple times. **Return** statements liberally dispersed through a subprogram body can result in dead code (code that never gets executed) and hard-to-find bugs.



Figure 3-18. Return Statement Syntax

3.4.6 Exit Statement

The **exit** statement is only allowed in loops. It is used to immediately exit any loop (loop-until, for-loop, while-loop) it is called from. Sometimes it is convenient to be able to exit from a loop instead of testing at the top. In the case of nested loops (a loop inside another loop), only the innermost enclosing loop will be exited. See the loop examples in [Section 3.4.4 on page 32](#) for the **exit** statement in action.




Figure 3-19. Exit Statement Syntax

4.0 Built-in Types

This section provides additional information about the iRite software's built-in types used in parameters passed to and from.

Code	Parameters
BatchingMode 920i 820i 880 882D 1280	Off, Auto, Manual
BatchStatus 920i 820i 880 882D 1280	BatchComplete, BatchStopped, BatchRunning, BatchPaused
BooleanType 1280	BoolTrue, BoolFalse
BusImage 920i 820i 1280	array[32] of integer
BusImageReal 920i 820i 1280	array[32] of real
ChrArray 920i	array[100] of integer
Color_type 920i	White, Black
DataArray 920i 1280	array[300] of real for 920i array[8000] of real for 1280
Decimal_type 920i 820i 880 1280	DP_8_888888, DP_88_888888, DP_888_888888, DP_8888_888, DP_88888_88, DP_888888_8, DP_88888888, DP_88888880, DP_88888800, DP_DEFAULT
DisplayImage 920i	array[2402] of integer
DTComponent 920i 820i 880 882D 1280	DateTimeYear, DateTimeMonth, DateTimeDay, DateTimeHour, DateTimeMinute, DateTimeSecond
ExtFloatArray 920i	array[5] of integer
FileAccessMode 920i 820i 1280	FileCreate, FileAppend, FileRead
FileDevice 1280	USB, SDCard, FTP

Table 4-1. Built-in Types

Code	Parameters
FileLineTermination 920i 820i 1280	FileCRLF, FileCR, FileLF
GraphType 920i	Line, Bar, XY
HW_array_type 920i 820i 880 882D 1280	array[x] of HW_type x = 14 (920i / 882D) x = 2 (820i) x = 1 (880) x = 6 (1280)
HW_type 880 1280	NoCard, DualSerial, DualAtoD, SingleAtoD, AnalogOut, DigitalIO, Profibus, AnalogInput, DualAnalogOut, Relay
HW_type 882D	NoCard, DualSerial, DualAtoD, SingleAtoD, AnalogOut, DigitalIO, Pulse, Memory, FieldbusCarrier, DeviceNet, Profibus, EtherNetIP, ABRIO, BCD, DSP2000, AnalogInput, ControlNet, DualAnalogOut, EtherCAT, DualEtherNetIP, ModbusTCP, PROFINET, DualPROFINET, FourChannelRelay
HW_type 920i 820i	NoCard, DualSerial, DualAtoD, SingleAtoD, AnalogOut, DigitalIO, Pulse, Memory, reservedCard, DeviceNet, Profibus, Ethernet, ABRIO, AnalogInput, ControlNet, DualAnalogOut, BCD, DSP2000
IQValType 920i 1280	IQSys, IQPlat, IQRawLC, IQCorrLC, IQZeroLC, IQStatLC, IQ2ScaleWt, IQ2StatusLC
Keys 880	GrossNetKey, UnitsKey, ZeroKey, TareKey, PrintKey, N1KEY, N4KEY, N7KEY, DecpntKey, NavUpKey, NavLeftKey, EnterKey, N2KEY, N5KEY, N8KEY, N0KEY, NavRightKey, NavDownKey, N3KEY, N6KEY, N9KEY, ClearKey, TimeDateKey, DisplayTareKey, DisplayAccumKey, MenuKey
Keys 882D	ModeKey, SetpointKey, ZeroKey, PrintKey, MenuKey, N0KEY, N1KEY, N2KEY, N3KEY, N4KEY, N5KEY, N6KEY, N7KEY, N8KEY, N9KEY, DecpntKey, F1KEY, F2KEY, F3KEY, F4KEY, NavUpKey, NavLeftKey, EnterKey, NavRightKey, NavDownKey, ClearKey, TimeDateKey
Keys 920i 820i 1280	Soft4Key, Soft5Key, GrossNetKey, UnitsKey, Soft3Key, Soft2Key, Soft1Key, ZeroKey, Undefined3Key, Undefined4Key, TareKey, PrintKey, N1KEY, N4KEY, N7KEY, DecpntKey, NavUpKey, NavLeftKey, EnterKey, Undefined5Key, N2KEY, N5KEY, N8KEY, N0KEY, Undefined1Key, Undefined2Key, NavRightKey, NavDownKey, N3KEY, N6KEY, N9KEY, ClearKey, TimeDateKey, WeighInKey, WeighOutKey, ID_EntryKey, DisplayTareKey, TruckRegsKey, DisplayAccumKey, ScaleSelectKey, DisplayROCKey, SetpointKey, BatchStartKey, BatchStopKey, BatchPauseKey, BatchResetKey, DiagnosticsKey, ContactsKey, DoneKey, TestKey, ContrastKey, LLStopKey, LLGoKey, LLOffKey, AuditKey, KeyedTareKey, ClearAccumKey, AuxPrintKey, USBKey (for 920i), DatabaseKey (for 1280)
Mode 920i 820i 880 1280	GrossMode, NetMode, TareMode
OnOffType 920i 1280	VOff, Von
PrintFormat 880	GrossFmt, NetFmt, SPFmt, AccumFmt
PrintFormat 882D	PrintFormat1, PrintFormat2, PrintFormat3, PrintFormat4, PrintFormatNone
PrintFormat 920i 820i 1280	GrossFmt, NetFmt, AuxFmt, TrWInFmt, TrRegFmt, TrWOutFmt, SPFmt, AccumFmt, AlertFmt, AuxFmt1, AuxFmt2, AuxFmt3, AuxFmt4, AuxFmt5, AuxFmt6, AuxFmt7, AuxFmt8, AuxFmt9, AuxFmt10, AuxFmt11, AuxFmt12, AuxFmt13, AuxFmt14, AuxFmt15, AuxFmt16, AuxFmt17, AuxFmt18, AuxFmt19, AuxFmt20

Table 4-1. Built-in Types (Continued)

Code	Parameters
SysCode 920i 820i 880 1280	SysOk, SysLFTViolation, SysOutOfRange, SysPermissionDenied, SysInvalidScale, SysBatchRunning, SysBatchNotRunning, SysNoTare, SysInvalidPort, SysQFull, SysInvalidUnits, SysInvalidSetpoint, SysInvalidRequest, SysInvalidMode, SysRequestFailed, SysInvalidKey, SysInvalidWidget, SysInvalidState, SysInvalidTimer, SysNoSuchDatabase, SysNoSuchRecord, SysDatabaseFull, SysNoSuchColumn, SysInvalidCounter, SysDeviceError, SysInvalidChecksum, SysDatabaseAccessTimeout, SysNoFileOpen, SysFileNotFound, SysInvalidFileFormat, SysDirectoryNotFound, SysFileReadOnly, SysFileExists, SysNoFileSystemFound, SysFileOpen, SysEndOfFile, SysNoRoomOnMedia, SysMediaChanged, SysDeviceNotFound, SysNoUSB, SysPortBusy, SysDeviceChange, SysDeviceAdded, SysBadFileName, SysInvalidFtpConfig, SysInvalidNetworkConfig, SysFtpStartFailed
SysCode 882D	SysOk, SysLFTViolation, SysOutOfRange, SysPermissionDenied, SysInvalidScale, SysBatchRunning, SysBatchNotRunning, SysNoTare, SysInvalidPort, SysQFull, SysInvalidUnits, SysInvalidSetpoint, SysInvalidRequest, SysInvalidMode, SysRequestFailed, SysInvalidKey, SysInvalidWidget, SysInvalidState, SysInvalidTimer, SysNoSuchDatabase, SysNoSuchRecord, SysDatabaseFull, SysNoSuchColumn, SysInvalidCounter, SysDeviceError, SysInvalidChecksum, SysDatabaseAccessTimeout, SysNoFileOpen, SysFileNotFound, SysInvalidFileFormat, SysDirectoryNotFound, SysFileReadOnly, SysFileExists, SysNoFileSystemFound, SysFileOpen, SysEndOfFile, SysNoRoomOnMedia, SysMediaChanged, SysDeviceNotFound, SysNoUSB, SysPortBusy, SysDeviceChange, SysDeviceAdded, SysBadFileName, SysInvalidTotalizer
TareType 920i 820i 880 1280	NoTare, PushbuttonTare, KeyedTare
TimerMode 920i 820i 880 882D 1280	TimerOneShot, TimerContinuous, TimerDigoutON, TimerDigoutOFF
Units 920i 820i 880 1280	Primary, Secondary, Tertiary
UnitType 920i 820i 880 1280	pound, kilogram, gram, ounce, short_ton, metric_ton, grain, troy_ounce, troy_pound, long_ton, custom, units_off, none
USBDeviceType 920i 820i 1280	USBNoDevice, USBHostPC, USBPrinter1, USBPrinter2, USBKeyboard, USBFileSystem
WeightCollectionArray 920i 1280	array[8000] of real
WgtMsg 920i	array[12] of integer

Table 4-1. Built-in Types (Continued)

4.1 Using SysCode Data

SysCode data can be used to take some action based on whether or not a function completed successfully.

Example: the following code checks the SysCode result following a GetTare function. If the function completed successfully, the retrieved tare weight is written to Port 1:

```
Procedure GetTareWeight
SysResult : SysCode;
TareWeight : Real;
begin
  SysResult:= GetTare(1, Primary, TareWeight);
  If SysResult = SysOk then
    WriteLn(1, "The current tare weight is " + realtostring(TareWeight,0,4));
  end if;
end;
```

5.0 API Reference

This section lists the application programming interfaces (APIs) used to program the indicator. Functions are grouped according to the kinds of operations they support.



NOTE: Check the `system.src` file to see all of the APIs that are present in the installed version of software.

5.1 Scale Data Acquisition



NOTE: Unless otherwise stated, when an API with a VAR parameter returns a SysCode value other than SysOK, the VAR parameter is not changed.

5.1.1 Weight Acquisition

Method	Description
GetCapacity 1280	Sets C to the configured capacity for scale S and units U Method Signature: function GetCapacity (S : Integer; U : Units, VAR C : Real) : SysCode; Parameters: [in] S Scale number [in] U Units (Primary, Secondary, Tertiary) [out] C Scale capacity SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidUnits The units value U is not valid SysOK The function completed successfully <i>Example:</i> Capacity : Real; ... GetCapacity (1, Primary, Capacity);
GetFilteredCount 920i 820i 880 882D 1280	Sets C to the current filtered A/D count for scale S Method Signature: function GetFilteredCount (S : Integer; VAR C : Integer) : SysCode; Parameters: [in] S Scale number [out] C Current filtered A/D count SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidRequest The scale specified by S is not an A/D-based scale SysDeviceError The scale is reporting an error condition SysOK The function completed successfully <i>Example:</i> FilterCount : Integer; ... GetFilteredCount (1, FilterCount);

Table 5-1. Weight Acquisition Methods

Method	Description																			
GetGross 920i 820i 880 1280	<p>Sets W to the current gross weight value of scale S, in the units specified by U; W will contain a weight value even if the scale is in programmed overload</p> <p>Method Signature: function GetGross (S : Integer; U : Units; VAR W : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[in]</td> <td>U</td> <td>Units (Primary, Secondary, Tertiary)</td> </tr> <tr> <td>[out]</td> <td>W</td> <td>Gross weight</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist</td> </tr> <tr> <td>SysInvalidUnits</td> <td>The units specified by U is not valid</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The requested value is not available</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> GrossWeight : Real; ... GetGross (1, Primary, GrossWeight); WriteLn (1, "Current gross weight is " + RealToString(GrossWeight,0,1));</p>	[in]	S	Scale number	[in]	U	Units (Primary, Secondary, Tertiary)	[out]	W	Gross weight	SysInvalidScale	The scale specified by S does not exist	SysInvalidUnits	The units specified by U is not valid	SysInvalidRequest	The requested value is not available	SysDeviceError	The scale is reporting an error condition	SysOK	The function completed successfully
[in]	S	Scale number																		
[in]	U	Units (Primary, Secondary, Tertiary)																		
[out]	W	Gross weight																		
SysInvalidScale	The scale specified by S does not exist																			
SysInvalidUnits	The units specified by U is not valid																			
SysInvalidRequest	The requested value is not available																			
SysDeviceError	The scale is reporting an error condition																			
SysOK	The function completed successfully																			
GetNet 920i 820i 880 1280	<p>Sets W to the current net weight value of scale S, in the units specified by U; W will contain a weight value even if the scale is in programmed overload</p> <p>Method Signature: function GetNet (S : Integer; U : Units; VAR W : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[in]</td> <td>U</td> <td>Units (Primary, Secondary, Tertiary)</td> </tr> <tr> <td>[out]</td> <td>W</td> <td>Net weight</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist</td> </tr> <tr> <td>SysInvalidUnits</td> <td>The units specified by U is not valid</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The requested value is not available</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> NetWeight : Real; ... GetNet (Scale1, Secondary, NetWeight); WriteLn (1, "Current net weight is " + RealToString(NetWeight,0,1));</p>	[in]	S	Scale number	[in]	U	Units (Primary, Secondary, Tertiary)	[out]	W	Net weight	SysInvalidScale	The scale specified by S does not exist	SysInvalidUnits	The units specified by U is not valid	SysInvalidRequest	The requested value is not available	SysDeviceError	The scale is reporting an error condition	SysOK	The function completed successfully
[in]	S	Scale number																		
[in]	U	Units (Primary, Secondary, Tertiary)																		
[out]	W	Net weight																		
SysInvalidScale	The scale specified by S does not exist																			
SysInvalidUnits	The units specified by U is not valid																			
SysInvalidRequest	The requested value is not available																			
SysDeviceError	The scale is reporting an error condition																			
SysOK	The function completed successfully																			
GetRawCount 920i 820i 880 882D 1280	<p>Sets C to the current raw A/D count for scale S</p> <p>Method Signature: function GetRawCount (S : Integer; VAR C : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[out]</td> <td>C</td> <td>Current raw A/D count</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The scale specified by S is not an A/D-based scale</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> RawCount : Integer; ... GetRawCount (1, RawCount);</p>	[in]	S	Scale number	[out]	C	Current raw A/D count	SysInvalidScale	The scale specified by S does not exist	SysInvalidRequest	The scale specified by S is not an A/D-based scale	SysDeviceError	The scale is reporting an error condition	SysOK	The function completed successfully					
[in]	S	Scale number																		
[out]	C	Current raw A/D count																		
SysInvalidScale	The scale specified by S does not exist																			
SysInvalidRequest	The scale specified by S is not an A/D-based scale																			
SysDeviceError	The scale is reporting an error condition																			
SysOK	The function completed successfully																			

Table 5-1. Weight Acquisition Methods (Continued)

Method	Description																					
GetMV 920i 880 1280 820i 882D	<p>Returns the mV value of scale S into the variable passed on as MV</p> <p>Method Signature: function GetMV (S : Integer; VAR MV : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[out]</td> <td>R</td> <td>Millivolts</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The requested value is not available</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> Millivolt : Real; ... GetMV (1, Millivolt); WriteLn (1, "Current Millivolt reading is" + realtostring(Millivolt,0,2));</p>	[in]	S	Scale number	[out]	R	Millivolts	SysInvalidScale	The scale specified by S does not exist	SysInvalidRequest	The requested value is not available	SysOK	The function completed successfully									
[in]	S	Scale number																				
[out]	R	Millivolts																				
SysInvalidScale	The scale specified by S does not exist																					
SysInvalidRequest	The requested value is not available																					
SysOK	The function completed successfully																					
GetTare 920i 820i 880 1280	<p>Sets W to the tare weight of scale S in weight units specified by U</p> <p>Method Signature: function GetTare (S : Integer; U : Units; VAR W : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[in]</td> <td>U</td> <td>Units (Primary, Secondary, Tertiary)</td> </tr> <tr> <td>[out]</td> <td>W</td> <td>Tare weight</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist</td> </tr> <tr> <td>SysInvalidUnits</td> <td>The units specified by U is not valid</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The requested value is not available</td> </tr> <tr> <td>SysNoTare</td> <td>The specified scale has no tare; W is set to 0.0</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> TareWeight : Real; ... GetTare (1, Tertiary, TareWeight); WriteLn (1, "Current tare weight is " + RealToString(TareWeight,0,1));</p>	[in]	S	Scale number	[in]	U	Units (Primary, Secondary, Tertiary)	[out]	W	Tare weight	SysInvalidScale	The scale specified by S does not exist	SysInvalidUnits	The units specified by U is not valid	SysInvalidRequest	The requested value is not available	SysNoTare	The specified scale has no tare; W is set to 0.0	SysDeviceError	The scale is reporting an error condition	SysOK	The function completed successfully
[in]	S	Scale number																				
[in]	U	Units (Primary, Secondary, Tertiary)																				
[out]	W	Tare weight																				
SysInvalidScale	The scale specified by S does not exist																					
SysInvalidUnits	The units specified by U is not valid																					
SysInvalidRequest	The requested value is not available																					
SysNoTare	The specified scale has no tare; W is set to 0.0																					
SysDeviceError	The scale is reporting an error condition																					
SysOK	The function completed successfully																					

Table 5-1. Weight Acquisition Methods (Continued)

5.1.2 Weight Data Recording

There are two methods to record weight readings into an array at a high rate of speed – DataRecording and WeightCollection.

DataRecording

DataRecording allows raw weights to be stored to a user program-specified array on each iteration of the scale processor. Recording begins when the Start Setpoint (start_sp is satisfied and ends when the Stop Setpoint (stop_sp) is satisfied.

Methods	Description			
CloseData Recording 920i 1280 820i	<p>Turns off data recording started with InitDataRecording; This procedure removes all connections to the data recording function; To restart data recording, use the InitDataRecording function</p> <p>Method Signature: Procedure CloseDataRecording (scale_no : Integer);</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>scale_no</td> <td>Scale Number</td> </tr> </table>	[in]	scale_no	Scale Number
[in]	scale_no	Scale Number		

Table 5-2. Data Recording Methods

Methods	Description
GetDataRecordSize 920i 1280 820i	Returns the number of data points recorded in the user-specified data array Method Signature: Function GetDataRecordSize(scale_no : Integer) : Integer; Parameters: [in] scale_no Scale Number Value Returned: [out] number The number of data points recorded
InitDataRecording 920i 1280 820i	Specifies the data array used for the recording, scale number, and the start and stop setpoint numbers NOTE: If the setpoint conditions return to the start conditions (start_up satisfied, stop_sp not satisfied), recording will continue at the array location where it left off. Thus, a continuous batch will need to call CloseDataRecording to stop recording, then call InitDataRecording to restart data recording at the beginning of the array. Method Signature: Function InitDataRecording (data : DataArray; scale_no : Integer; start_sp : Integer; stop_sp : Integer) : SysCode; Parameters: [in] data Data array name [in] scale_no Scale Number [in] start_sp Start setpoint number [in] stop_sp Stop setpoint number SysCode values returned: SysRequestFailed The function did not complete SysOk The function completed successfully
SetDataRecordPrecision 920i 1280	Sets the data recording to high precision Method Signature: Function SetDataRecordPrecision (scale_no : Integer; precision : OnOffType) : SysCode; Parameters: [in] scale_no Scale Number [in] precision OnOffType Von or VOff SysCode values returned: SysRequestFailed The function did not complete SysOk The function completed successfully

Table 5-2. Data Recording Methods (Continued)

WeightCollection

WeightCollection allows the recording of weights, at the A/D update rate, to a user-specified array of type WeightCollectionArray.

Methods	Description
StartWeightCollection 920i 1280	Starts the collection of weight data, from the specified scale, to the user specified array Method Signature: Function StartWeightCollection (scale_no : Integer; data : WeightCollectionArray) : SysCode; Parameters: [in] scale_no Scale Number [in] data Data array name SysCode values returned: SysRequestFailed The function did not complete SysOk The function completed successfully

Table 5-3. Weight Collection Methods

Methods	Description
StopWeight Collection 920i 1280	Stops the collection of weight data that was started with StartWeightCollection, and returns the number of data points recorded in the user-specified data array Method Signature: Function StopWeightCollection(scale_no : Integer) : Integer; Parameters: [in] scale_no Scale Number Value Returned: [out] number The number of data points recorded
GetMinMaxAvg 1280	Takes in data collection W and size S , and sets minimum X , maximum Y and average Z values. Method Signature: Function GetMinMaxAvg(W : WeightCollectionArray; S : Integer; VAR X : Real; VAR Y : Real; VAR Z : Real) : Syscode; Parameters: [in] W WeightCollection array [in] S Size of W Value Returned: [out] X Minimum Value [out] Y Maximum Value [out] Z Average Value SysCode values returned: SysRequestFailed The size specified by S is less than 1 or greater than 8000 SysOk The function completed successfully <i>Example:</i> g_iCount : integer; g_rMin : real; g_rMax : real; g_rAvg : real; GetMinMaxAvg(g_wcArray, g_iCount, g_rMin, g_rMax, g_rAvg);

Table 5-3. Weight Collection Methods (Continued)

5.1.3 Tare Manipulation

Methods	Description
AcquireTare 920i 820i 880 1280	Acquires a pushbutton tare from scale S Method Signature: function AcquireTare (S : Integer) : SysCode; Parameters: [in] S Scale number SysCode values returned: SysInvalidRequest The specified scale is Legal for Trade Serial Scale. No tare is acquired SysInvalidScale The scale specified by S does not exist or is a program scale SysLFTViolation The tare operation would violate configured legal-for-trade restrictions for the specified scale; no tare is acquired SysOutOfRange The tare operation would acquire a tare that may cause a display overload. No tare is acquired. SysPermissionDenied The tare operation would violate configured tare acquisition restrictions for the specified scale; no tare is acquired SysDeviceError The scale is reporting an error condition SysOK The function completed successfully <i>Example:</i> AcquireTare (1);

Table 5-4. Tare Manipulation Methods

Methods	Description
ClearTare 920i 820i 880 1280	<p>Removes the tare associated with scale S and sets the tare type associated with the scale to NoTare</p> <p>Method Signature: function ClearTare (S : Integer) : SysCode;</p> <p>Parameters: [in] S Scale number</p> <p>SysCode values returned:</p> <ul style="list-style-type: none"> SysInvalidRequest The specified scale is Legal for Trade Serial Scale; no tare is acquired SysInvalidScale The scale specified by S does not exist or is a program scale SysNoTare The scale specified by S has no tare SysDeviceError The scale is reporting an error condition SysOK The function completed successfully <p><i>Example:</i> ClearTare (1);</p>
GetTareType 920i 820i 880 1280	<p>Sets T to indicate type of tare currently on scale S</p> <p>Method Signature: function GetTareType (S : Integer; VAR T : TareType) : SysCode;</p> <p>Parameters: [in] S Scale number [out] T Tare type</p> <p>TareType values returned:</p> <ul style="list-style-type: none"> NoTare There is no tare value associated with the specified scale PushbuttonTare The current tare was acquired by pushbutton KeyedTare The current tare was acquired by key entry or by setting the tare <p>SysCode values returned:</p> <ul style="list-style-type: none"> SysDeviceError The scale is reporting an error condition; T is still set to the tare type SysInvalidScale The scale specified by S does not exist or is a program scale; T is unchanged SysOK The function completed successfully <p><i>Example:</i> TT : TareType; ... GetTareType (1, TT); if TT=KeyedTare then ...</p>
SetTare 920i 820i 880 1280	<p>Sets the tare weight for the specified channel</p> <p>Method Signature: function SetTare (S : Integer; U : Units; W : Real) : SysCode;</p> <p>Parameters: [in] S Scale number [in] U Units (Primary, Secondary, Tertiary) [in] W Tare weight</p> <p>SysCode values returned:</p> <ul style="list-style-type: none"> SysInvalidRequest The specified scale is Legal for Trade Serial Scale; no tare is acquired SysPermissionDenied The tare operation would violate configured tare acquisition restrictions for the specified scale; no tare is acquired SysInvalidScale The scale specified by S does not exist or is a program scale SysInvalidUnits The units specified by U is not valid SysLFTViolation The tare operation would violate configured legal-for-trade restrictions for the specified scale; no tare is acquired SysOutOfRange The tare operation would acquire a tare that may cause a display overload; no tare is acquired SysDeviceError The scale is reporting an error condition SysOK The function completed successfully <p><i>Example:</i> DesiredTare : Real; ... DesiredTare := 1234.5; SetTare (1, Primary, DesiredTare);</p>

Table 5-4. Tare Manipulation Methods (Continued)

Methods	Description																									
KeyedTareIgnoreReg() 920i	<p>Sets the tare weight for the specified channel; Disregards TAREFN configuration. Allows a KeyedTare whether TAREFN configuration is set to KEYED, BOTH or PBTARE</p> <p>Method Signature: function SetTare (S : Integer; U : Units; W : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[in]</td> <td>U</td> <td>Units (Primary, Secondary, Tertiary)</td> </tr> <tr> <td>[in]</td> <td>W</td> <td>Tare weight</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidRequest</td> <td>The specified scale is Legal for Trade Serial Scale; no tare is acquired</td> </tr> <tr> <td>SysPermissionDenied</td> <td>The tare operation would violate configured tare acquisition restrictions for the specified scale; no tare is acquired</td> </tr> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist or is a program scale</td> </tr> <tr> <td>SysInvalidUnits</td> <td>The units specified by U is not valid</td> </tr> <tr> <td>SysLFTViolation</td> <td>The tare operation would violate configured legal-for-trade restrictions for the specified scale; no tare is acquired</td> </tr> <tr> <td>SysOutOfRange</td> <td>The tare operation would acquire a tare that may cause a display overload; no tare is acquired</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> DesiredTare : Real; ... DesiredTare := 1234.5; SetTare (1, Primary, DesiredTare);</p>	[in]	S	Scale number	[in]	U	Units (Primary, Secondary, Tertiary)	[in]	W	Tare weight	SysInvalidRequest	The specified scale is Legal for Trade Serial Scale; no tare is acquired	SysPermissionDenied	The tare operation would violate configured tare acquisition restrictions for the specified scale; no tare is acquired	SysInvalidScale	The scale specified by S does not exist or is a program scale	SysInvalidUnits	The units specified by U is not valid	SysLFTViolation	The tare operation would violate configured legal-for-trade restrictions for the specified scale; no tare is acquired	SysOutOfRange	The tare operation would acquire a tare that may cause a display overload; no tare is acquired	SysDeviceError	The scale is reporting an error condition	SysOK	The function completed successfully
[in]	S	Scale number																								
[in]	U	Units (Primary, Secondary, Tertiary)																								
[in]	W	Tare weight																								
SysInvalidRequest	The specified scale is Legal for Trade Serial Scale; no tare is acquired																									
SysPermissionDenied	The tare operation would violate configured tare acquisition restrictions for the specified scale; no tare is acquired																									
SysInvalidScale	The scale specified by S does not exist or is a program scale																									
SysInvalidUnits	The units specified by U is not valid																									
SysLFTViolation	The tare operation would violate configured legal-for-trade restrictions for the specified scale; no tare is acquired																									
SysOutOfRange	The tare operation would acquire a tare that may cause a display overload; no tare is acquired																									
SysDeviceError	The scale is reporting an error condition																									
SysOK	The function completed successfully																									

Table 5-4. Tare Manipulation Methods (Continued)

5.1.4 Rate of Change

Methods	Description														
GetROC 920i 820i 1280	<p>Sets R to the current rate-of-change value of scale S</p> <p>Method Signature: function GetROC (S : Integer; VAR R : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[out]</td> <td>R</td> <td>Rate of change value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidRequest</td> <td>The scale specified by S is not an A/D scale, an industrial serial scale, or Rate of Change is not supported</td> </tr> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> ROC : Real; ... GetROC (1, ROC); WriteLn (1, "Current ROC is " + RealToString(ROC,0,1));</p>	[in]	S	Scale number	[out]	R	Rate of change value	SysInvalidRequest	The scale specified by S is not an A/D scale, an industrial serial scale, or Rate of Change is not supported	SysInvalidScale	The scale specified by S does not exist	SysDeviceError	The scale is reporting an error condition	SysOK	The function completed successfully
[in]	S	Scale number													
[out]	R	Rate of change value													
SysInvalidRequest	The scale specified by S is not an A/D scale, an industrial serial scale, or Rate of Change is not supported														
SysInvalidScale	The scale specified by S does not exist														
SysDeviceError	The scale is reporting an error condition														
SysOK	The function completed successfully														

Table 5-5. Rate of Change Command

5.1.5 Accumulator Operations

Methods	Description
ClearAccum 920i 820i 880 1280	<p>Sets the value of the accumulator for scale S to zero</p> <p>Method Signature: function ClearAccum (S : Integer) : SysCode;</p> <p>Parameters: [in] S Scale number</p> <p>SysCode values returned: SysInvalidScale The scale specified by S does not exist SysPermissionDenied The accumulator is not enabled for the specified scale SysDeviceError The scale is reporting an error condition SysOK The function completed successfully</p> <p><i>Example:</i> ClearAccum (1);</p>
GetAccum 920i 820i 880 1280	<p>Sets W to the value of the accumulator associated with scale S, in the units specified by U</p> <p>Method Signature: function GetAccum (S : Integer; U : Units; VAR W : Real) : SysCode;</p> <p>Parameters: [in] S Scale number [in] U Units (Primary, Secondary, Tertiary) [out] W Accumulated weight</p> <p>SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidUnits The units specified by U is not valid SysDeviceError The scale is reporting an error condition; D is still updated with the date of the most recent accumulation SysPermissionDenied The accumulator is not enabled for the specified scale SysOK The function completed successfully</p> <p><i>Example:</i> AccumValue : Real; ... GetAccum (1, Primary, AccumValue);</p>
GetAccumCount 920i 820i 880 1280	<p>Sets N to the number of accumulations performed for scale S since its accumulator was last cleared</p> <p>Method Signature: function GetAccumCount (S : Integer; VAR N : Integer) : SysCode;</p> <p>Parameters: [in] S Scale number [out] N Accumulator count</p> <p>SysCode values returned: SysInvalidScale The scale specified by S does not exist SysPermissionDenied The accumulator is not enabled for the specified scale SysDeviceError The scale is reporting an error condition SysOK The function completed successfully</p> <p><i>Example:</i> NumAccums : Integer; ... GetAccumCount (1, NumAccums);</p>

Table 5-6. Accumulator Operation Methods

Methods	Description																			
GetAccumDate 920i 820i 880 1280	<p>Sets D to the date of the most recent accumulation performed by scale S</p> <p>Method Signature: function GetAccumDate (S : Integer; VAR D : String) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[out]</td> <td>D</td> <td>Accumulator date</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist</td> </tr> <tr> <td>SysPermissionDenied</td> <td>The accumulator is not enabled for the specified scale</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition; D is still updated with the date of the most recent accumulation</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> AccumDate : String; ... GetAccumDate (1, AccumDate);</p>	[in]	S	Scale number	[out]	D	Accumulator date	SysInvalidScale	The scale specified by S does not exist	SysPermissionDenied	The accumulator is not enabled for the specified scale	SysDeviceError	The scale is reporting an error condition; D is still updated with the date of the most recent accumulation	SysOK	The function completed successfully					
[in]	S	Scale number																		
[out]	D	Accumulator date																		
SysInvalidScale	The scale specified by S does not exist																			
SysPermissionDenied	The accumulator is not enabled for the specified scale																			
SysDeviceError	The scale is reporting an error condition; D is still updated with the date of the most recent accumulation																			
SysOK	The function completed successfully																			
GetAccumTime 920i 820i 880 1280	<p>Sets T to the time of the most recent accumulation performed by scale S</p> <p>Method Signature: function GetAccumTime (S : Integer; VAR T : String) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[out]</td> <td>T</td> <td>Accumulator time</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist</td> </tr> <tr> <td>SysPermissionDenied</td> <td>The accumulator is not enabled for the specified scale</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition. T is still updated with the time of the most recent accumulation</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> AccumTime : String; ... GetAccumTime (1, AccumTime);</p>	[in]	S	Scale number	[out]	T	Accumulator time	SysInvalidScale	The scale specified by S does not exist	SysPermissionDenied	The accumulator is not enabled for the specified scale	SysDeviceError	The scale is reporting an error condition. T is still updated with the time of the most recent accumulation	SysOK	The function completed successfully					
[in]	S	Scale number																		
[out]	T	Accumulator time																		
SysInvalidScale	The scale specified by S does not exist																			
SysPermissionDenied	The accumulator is not enabled for the specified scale																			
SysDeviceError	The scale is reporting an error condition. T is still updated with the time of the most recent accumulation																			
SysOK	The function completed successfully																			
GetAvgAccum 920i 820i 880 1280	<p>Sets W to the average accumulator value associated with scale S, in the units specified by U, since the accumulator was last cleared</p> <p>Method Signature: function GetAvgAccum (S : Integer; U : Units; VAR W : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[in]</td> <td>U</td> <td>Units (Primary, Secondary, Tertiary)</td> </tr> <tr> <td>[out]</td> <td>W</td> <td>Average accumulator weight</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist</td> </tr> <tr> <td>SysInvalidUnits</td> <td>The units specified by U is not valid</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition. W is still updated with the average accumulator value</td> </tr> <tr> <td>SysPermissionDenied</td> <td>The accumulator is not enabled for the specified scale</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> AvgAccum : Real; ... GetAvgAccum (1, AvgAccum);</p>	[in]	S	Scale number	[in]	U	Units (Primary, Secondary, Tertiary)	[out]	W	Average accumulator weight	SysInvalidScale	The scale specified by S does not exist	SysInvalidUnits	The units specified by U is not valid	SysDeviceError	The scale is reporting an error condition. W is still updated with the average accumulator value	SysPermissionDenied	The accumulator is not enabled for the specified scale	SysOK	The function completed successfully
[in]	S	Scale number																		
[in]	U	Units (Primary, Secondary, Tertiary)																		
[out]	W	Average accumulator weight																		
SysInvalidScale	The scale specified by S does not exist																			
SysInvalidUnits	The units specified by U is not valid																			
SysDeviceError	The scale is reporting an error condition. W is still updated with the average accumulator value																			
SysPermissionDenied	The accumulator is not enabled for the specified scale																			
SysOK	The function completed successfully																			

Table 5-6. Accumulator Operation Methods (Continued)

Methods	Description																	
SetAccum 920i 820i 880 1280	<p>Sets the value of the accumulator associated with scale S to weight W, in units specified by U</p> <p>Method Signature: function SetAccum (S : Integer; U : Units; W : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[in]</td> <td>U</td> <td>Units (Primary, Secondary, Tertiary)</td> </tr> <tr> <td>[in]</td> <td>W</td> <td>Accumulator value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist</td> </tr> <tr> <td>SysInvalidUnits</td> <td>The units specified by U is not valid</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition</td> </tr> <tr> <td>SysPermissionDenied</td> <td>The accumulator is not enabled for the specified scale</td> </tr> </table> <p>NOTE: If the units specified by U are Secondary or Tertiary, the scale has to be either an A/D scale or a total scale. If not A/D scale or a total scale then SysPermissionDenied will be returned.</p> <p>NOTE: If the units specified by U are Primary, the scale can be any type.</p> <p>SysOK The function completed successfully</p> <p><i>Example:</i> AccumValue : Real; ... AccumValue := 110.5 SetAccum (1, Primary, AccumValue);</p>	[in]	S	Scale number	[in]	U	Units (Primary, Secondary, Tertiary)	[in]	W	Accumulator value	SysInvalidScale	The scale specified by S does not exist	SysInvalidUnits	The units specified by U is not valid	SysDeviceError	The scale is reporting an error condition	SysPermissionDenied	The accumulator is not enabled for the specified scale
[in]	S	Scale number																
[in]	U	Units (Primary, Secondary, Tertiary)																
[in]	W	Accumulator value																
SysInvalidScale	The scale specified by S does not exist																	
SysInvalidUnits	The units specified by U is not valid																	
SysDeviceError	The scale is reporting an error condition																	
SysPermissionDenied	The accumulator is not enabled for the specified scale																	

Table 5-6. Accumulator Operation Methods (Continued)

5.1.6 Scale Operation

Methods	Description																
CurrentScale 920i 820i 880 882D 1280	<p>Returns the number of the currently displayed scale</p> <p>Method Signature: function CurrentScale : Integer;</p> <p><i>Example:</i> ScaleNumber : Integer; ... ScaleNumber := CurrentScale;</p>																
GetMode 920i 820i 880 1280	<p>Sets M to the value representing the current display mode for scale S</p> <p>Method Signature: function GetMode (S : Integer; VAR M : Mode) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[out]</td> <td>M</td> <td>Current display mode</td> </tr> </table> <p>Mode values returned:</p> <table> <tr> <td>GrossMode</td> <td>Scale S is currently in gross mode</td> </tr> <tr> <td>NetMode</td> <td>Scale S is currently in net mode</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist or is a program scale</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition; M is still updated with the current display mode</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> CurrentMode : Mode; ... GetMode (1, CurrentMode);</p>	[in]	S	Scale number	[out]	M	Current display mode	GrossMode	Scale S is currently in gross mode	NetMode	Scale S is currently in net mode	SysInvalidScale	The scale specified by S does not exist or is a program scale	SysDeviceError	The scale is reporting an error condition; M is still updated with the current display mode	SysOK	The function completed successfully
[in]	S	Scale number															
[out]	M	Current display mode															
GrossMode	Scale S is currently in gross mode																
NetMode	Scale S is currently in net mode																
SysInvalidScale	The scale specified by S does not exist or is a program scale																
SysDeviceError	The scale is reporting an error condition; M is still updated with the current display mode																
SysOK	The function completed successfully																

Table 5-7. Scale Operation Methods

Methods	Description																					
GetUnits 920i 820i 880 1280	<p>Sets U to the value representing the current display units for scale S</p> <p>Method Signature: function GetUnits (S : Integer; VAR U : Units) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[out]</td> <td>U</td> <td>Current display units</td> </tr> </table> <p>Units values returned:</p> <table> <tr> <td>Primary</td> <td>Primary units are currently displayed on scale S</td> </tr> <tr> <td>Secondary</td> <td>Secondary units are currently displayed on scale S</td> </tr> <tr> <td>Tertiary</td> <td>Tertiary units are currently displayed on scale S</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist or is a program scale</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> CurrentUnits : Units; ... GetUnits (1, CurrentUnits);</p>	[in]	S	Scale number	[out]	U	Current display units	Primary	Primary units are currently displayed on scale S	Secondary	Secondary units are currently displayed on scale S	Tertiary	Tertiary units are currently displayed on scale S	SysInvalidScale	The scale specified by S does not exist or is a program scale	SysDeviceError	The scale is reporting an error condition	SysOK	The function completed successfully			
[in]	S	Scale number																				
[out]	U	Current display units																				
Primary	Primary units are currently displayed on scale S																					
Secondary	Secondary units are currently displayed on scale S																					
Tertiary	Tertiary units are currently displayed on scale S																					
SysInvalidScale	The scale specified by S does not exist or is a program scale																					
SysDeviceError	The scale is reporting an error condition																					
SysOK	The function completed successfully																					
GetUnitsString 920i 820i 880 1280	<p>Sets V to the text string representing the current display units for scale S</p> <p>Method Signature: function GetUnitsString (S : Integer; U : Units; VAR V : String) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[in]</td> <td>U</td> <td>Units (Primary, Secondary, Tertiary)</td> </tr> <tr> <td>[out]</td> <td>V</td> <td>Current display units string</td> </tr> </table> <p>Units values sent:</p> <table> <tr> <td>Primary</td> <td>Get the Primary units string for scale S</td> </tr> <tr> <td>Secondary</td> <td>Get the Secondary units string for scale S</td> </tr> <tr> <td>Tertiary</td> <td>Get the Tertiary units string for scale S</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist or is a program scale</td> </tr> <tr> <td>SysInvalidUnits</td> <td>The units value specified by U does not exist</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> CurrentUnitsString : String; ... GetUnitsString (1, Primary, CurrentUnitsString);</p>	[in]	S	Scale number	[in]	U	Units (Primary, Secondary, Tertiary)	[out]	V	Current display units string	Primary	Get the Primary units string for scale S	Secondary	Get the Secondary units string for scale S	Tertiary	Get the Tertiary units string for scale S	SysInvalidScale	The scale specified by S does not exist or is a program scale	SysInvalidUnits	The units value specified by U does not exist	SysOK	The function completed successfully
[in]	S	Scale number																				
[in]	U	Units (Primary, Secondary, Tertiary)																				
[out]	V	Current display units string																				
Primary	Get the Primary units string for scale S																					
Secondary	Get the Secondary units string for scale S																					
Tertiary	Get the Tertiary units string for scale S																					
SysInvalidScale	The scale specified by S does not exist or is a program scale																					
SysInvalidUnits	The units value specified by U does not exist																					
SysOK	The function completed successfully																					
InCOZ 920i 820i 880 1280	<p>Sets V to a non-zero value if scale S is within 0.25 grads of gross zero; If the condition is not met, V is set to zero</p> <p>Method Signature: function InCOZ (S : Integer; VAR V : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[in]</td> <td>V</td> <td>Center-of-zero value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist or is a program scale</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> ScaleAtCOZ : Integer; ... InCOZ (1, ScaleAtCOZ);</p>	[in]	S	Scale number	[in]	V	Center-of-zero value	SysInvalidScale	The scale specified by S does not exist or is a program scale	SysDeviceError	The scale is reporting an error condition	SysOK	The function completed successfully									
[in]	S	Scale number																				
[in]	V	Center-of-zero value																				
SysInvalidScale	The scale specified by S does not exist or is a program scale																					
SysDeviceError	The scale is reporting an error condition																					
SysOK	The function completed successfully																					

Table 5-7. Scale Operation Methods (Continued)

Methods	Description												
InMotion 920i 820i 880 1280	<p>Sets V to a non-zero value if scale S is in motion; otherwise, V is set to zero</p> <p>Method Signature: function InMotion (S : Integer; VAR V : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[out]</td> <td>V</td> <td>In-motion value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist or is a program scale</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> ScaleInMotion : Integer; ... InMotion (1, ScaleInMotion);</p>	[in]	S	Scale number	[out]	V	In-motion value	SysInvalidScale	The scale specified by S does not exist or is a program scale	SysDeviceError	The scale is reporting an error condition	SysOK	The function completed successfully
[in]	S	Scale number											
[out]	V	In-motion value											
SysInvalidScale	The scale specified by S does not exist or is a program scale												
SysDeviceError	The scale is reporting an error condition												
SysOK	The function completed successfully												
InRange 920i 820i 880 1280	<p>Sets V to zero value if scale S is in an overload or underload condition; otherwise, V is set to a non-zero value</p> <p>Method Signature: function InRange (S : Integer; VAR V : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[out]</td> <td>V</td> <td>In-range value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist or is a program scale</td> </tr> <tr> <td>SysDeviceError</td> <td>The scale is reporting an error condition</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> ScaleInRange : Integer; ... InRange (1, ScaleInRange);</p>	[in]	S	Scale number	[out]	V	In-range value	SysInvalidScale	The scale specified by S does not exist or is a program scale	SysDeviceError	The scale is reporting an error condition	SysOK	The function completed successfully
[in]	S	Scale number											
[out]	V	In-range value											
SysInvalidScale	The scale specified by S does not exist or is a program scale												
SysDeviceError	The scale is reporting an error condition												
SysOK	The function completed successfully												
SelectScale 920i 820i 1280 880 882D	<p>Sets scale S as the current scale</p> <p>Method Signature: function SelectScale (S : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist; the current scale is not changed</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SelectScale (1);</p>	[in]	S	Scale number	SysInvalidScale	The scale specified by S does not exist; the current scale is not changed	SysOK	The function completed successfully					
[in]	S	Scale number											
SysInvalidScale	The scale specified by S does not exist; the current scale is not changed												
SysOK	The function completed successfully												

Table 5-7. Scale Operation Methods (Continued)

Methods	Description
SetMode 920i 820i 880 1280	Sets the current display mode on scale S to M Method Signature: function SetMode (S : Integer; M : Mode) : SysCode; Parameters: [in] S Scale number [in] M Scale mode Mode values sent: GrossMode Scale S is set to gross mode NetMode Scale S is set to net mode SysCode values returned: SysInvalidScale The scale specified by S does not exist or is a program scale SysInvalidMode The mode value M is not valid SysDeviceError The scale is reporting an error condition; the mode is not changed SysOK The function completed successfully <i>Example:</i> SetMode (1, GrossMode or NetMode);
SetUnits 920i 820i 880 1280	Sets the current display units on scale S to U Method Signature: function SetUnits (S : Integer; U : Units) : SysCode; Parameters: [in] S Scale number [in] U Scale units Units values sent: Primary Primary units will be displayed on scale S Secondary Secondary units will be displayed on scale S Tertiary Tertiary units will be displayed on scale S SysCode values returned: SysInvalidRequest The scale specified by S is a legal for trade or industrial serial scale SysInvalidScale The scale specified by S does not exist or is a program scale SysInvalidUnits The units value U is not valid SysDeviceError The scale is reporting an error condition SysOK The function completed successfully <i>Example:</i> SetUnits (1, Secondary);
ZeroScale 920i 820i 880 1280	Performs a gross zero scale operation for S Method Signature: function ZeroScale (S : Integer) : SysCode; Parameters: [in] S Scale number SysCode values returned: SysInvalidRequest The scale specified by S is a legal for trade serial scale SysInvalidScale The scale specified by S does not exist or is a program scale SysLFTViolation The zero operation would violate configured legal-for-trade restrictions for the specified scale; No zero is performed SysOutOfRange The zero operation would exceed the configured zeroing limit; No zero is acquired SysDeviceError The scale is reporting an error condition SysOK The function completed successfully <i>Example:</i> ZeroScale (1);

Table 5-7. Scale Operation Methods (Continued)

Methods	Description
GetCountBy 920i 820i 880 1280	Sets C to the real count-by value on scale S , in units U Method Signature: function GetCountBy (S : Integer; U : Units; VAR C : Real) : SysCode; Parameters: [in] S Scale number [in] U Units (Primary, Secondary, Tertiary) [out] C Count-by value SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidUnits The units specified by U is not recognized SysInvalidRequest The scale specified by S does not support this operation (serial scale) SysDeviceError The scale is reporting an error condition; C is still updated with the count-by value SysOK The function completed successfully <i>Example:</i> CountBy : Real; ... GetCountBy (1, Primary, CountBy);
GetGrads 920i 820i 880 1280	Sets G to the configured grad value of scale S Method Signature: function GetGrads (S : Integer; VAR G : Integer) : SysCode; Parameters: [in] S Scale number [out] G Grads value SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidRequest The scale specified by S does not support this operation (serial scale) SysDeviceError The scale is reporting an error condition SysOK The function completed successfully <i>Example:</i> Grads : Integer; ... GetGrads (1, Grads);
SetDFStages 1280	Sets the digital filtering stage Method Signature: function SetDFStages (S : Integer; S1 : Integer; S2 : Integer; S3 : Integer) : SysCode; Parameters: [in] S Scale number [in] S1 Stage 1 [in] S2 Stage 2 [in] S3 Stage 3 SysCode values returned: SysInvalidRequest Invalid type SysOutOfRange Values have not been assigned SysOK The function completed successfully <i>Example:</i> SetDFStages (1, 4, 4, 4);
SetDFThresholds 1280	Sets the digital filtering threshold Method Signature: function SetDFThresholds (S : Integer; Sensitivity : Integer; Threshold : Integer) : SysCode; Parameters: [in] S Scale number [in] Sensitivity Sensitivity [in] Threshold Threshold SysCode values returned: SysInvalidRequest Invalid type SysOutOfRange Values have not been assigned SysOK The function completed successfully

Table 5-7. Scale Operation Methods (Continued)

5.1.7 Calibration Data

Methods	Description
GetLCCD 920i 820i 880 1280	Sets V to the calibrated deadload count for scale S Method Signature: function GetLCCD (S : Integer; VAR V : Integer) : SysCode; Parameters: [in] S Scale number [out] V Deadload count SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidRequest The scale specified by S is not an A/D-based scale SysOK The function completed successfully
GetLCCW 920i 820i 880 1280	Sets V to the calibrated span count for scale S Method Signature: function GetLCCW (S : Integer; VAR V : Integer) : SysCode; Parameters: [in] S Scale number [out] V Calibrated span count SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidRequest The scale specified by S is not an A/D-based scale SysOK The function completed successfully
GetLCCC 1280	Sets V to the calibrated load cell count at capacity for scale S Method Signature function GetLCCC (S : Integer; VAR V : Integer) : SysCode; Parameters: [in] S Scale number [out] V Load cell count at capacity SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidRequest The scale specified by S is not an A/D-based scale SysOK The function completed successfully
GetWVal 920i 820i 880 1280	Sets V to the configured WVAL (test weight value) for scale S Method Signature: function GetWVal (S : Integer; VAR V : Real) : SysCode; Parameters: [in] S Scale number [out] V Test weight value SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidRequest The scale specified by S is not an A/D-based scale SysOK The function completed successfully
GetZeroCount 920i 820i 880 1280	Sets V to the amount of counts from calibrated deadload for scale S Method Signature: function GetZeroCount (S : Integer; VAR V : Integer) : SysCode; Parameters: [in] S Scale number [out] V Deadload count SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidRequest The scale specified by S is not an A/D-based scale SysOK The function completed successfully

Table 5-8. Calibration Data Methods

Methods	Description
GetLiveZeroCounts 1280	Sets V to the counts value of the live zero weight for scale S Method Signature: function GetLiveZeroCounts (S : Integer; VAR V : Integer) : SysCode; Parameters: [in] S Scale number [out] V Live zero count SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidRequest The scale specified by S is not an A/D-based scale SysOK The function completed successfully
GetPBZeroCounts 1280	Sets V to the counts value of the pushbutton zero for scale S Method Signature: function GetPBZeroCounts (S : Integer; VAR V : Integer) : SysCode; Parameters: [in] S Scale number [out] V Live zero count SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidRequest The scale specified by S is not an A/D-based scale SysOK The function completed successfully

Table 5-8. Calibration Data Methods (Continued)

5.2 System Support

Methods	Description
Date\$ 920i 820i 880 882D 1280	Returns a string representing the system date contained in DT Method Signature: function Date\$ (DT : DateTime) : String;
DisableHandler 920i 820i 880 882D 1280	Disables the specified event handler. See Section 6.1 on page 113 for a list of handlers Method Signature: procedure DisableHandler (handler); SysCode values returned: SysInvalidRequest The specified handler does not exist SysOK The function completed successfully
Displays Suspended 920i 820i 880 882D 1280	Returns a true (non-zero) value if the display is suspended (using the SuspendDisplay procedure), or a false (zero) value if the display is not suspended Method Signature: function DisplaysSuspended : Integer;
EnableHandler 920i 820i 880 882D 1280	Enables the specified event handler; see Section 6.1 on page 113 for a list of handlers Method Signature: procedure EnableHandler (handler); SysCode values returned: SysInvalidRequest The specified handler does not exist SysOK The function completed successfully

Table 5-9. System Support Methods

Methods	Description
EventChar 920i 820i 880 882D 1280	<p>Returns a one-character string representing the character received on a communications port that caused the PortxCharReceived event; If EventChar is called outside the scope of a PortxCharReceived event, EventChar returns a string of length zero; See Section 6.1 on page 113 for information about the PortxCharReceived event handler</p> <p>Method Signature: function EventChar : String;</p> <p><i>Example:</i> handler Port4CharReceived; strOneChar : string; begin strOneChar := EventChar; end;</p>
EventConnection 1280	<p>Returns the name of the communications connection that caused the ConnectionCharReceived or Cmdx handler events; If EventConnection is called outside the scope of either of these events, a string of length zero is returned</p> <p>Method Signature: function EventConnection : string;</p>
EventKey 920i 820i 880 882D 1280	<p>Returns an enumeration of type keys with the value corresponding to the key press that generated the event; See Section 4.0 on page 35 for a definition of the Keys data type</p> <p>Method Signature: function EventKey : Keys;</p> <p><i>Example:</i> handler KeyPressed; begin if EventKey = ClearKey then ... end if; end;</p>
EventPort 920i 820i 880 882D 1280	<p>Returns the communications port number that received an F#x serial command; This function extracts data from the CmdxHandler event for the F#x command, if enabled (the CmdxHandler, if enabled, runs whenever a F#x command is received on any serial port); If the CmdxHandler is not enabled, this function returns 0 as the port number</p> <p>Method Signature: function EventPort : Integer;</p>
EventString 920i 820i 880 882D 1280	<p>Returns the string sent with an F#x serial command; this function extracts data from the CmdxHandler event for the F#x command, if enabled; The CmdxHandler, if enabled, runs whenever a F#x command is received on any serial port; If the CmdxHandler is not enabled, or if no string is defined for the F#x command, this function returns a string of length zero</p> <p>Method Signature: function EventString : String;</p>
EventHid 1280	–
EventWidget 1280	<p>When used in the WidgetClicked handler, determines the activated display widget. The value returned is the widget number (1-999).</p> <p>Method Signature: function EventWidget : Integer;</p>
GetConsecNum 920i 820i 880 882D 1280	<p>Returns the value of the consecutive number counter</p> <p>Method Signature: function GetConsecNum : Integer;</p>

Table 5-9. System Support Methods (Continued)

Methods	Description
GetDate 920i 820i 880 882D 1280	Extracts date information from DT and places the data in variables Year , Month , and Day Method Signature: procedure GetDate (DT : DateTime; VAR Year : Integer; VAR Month : Integer; VAR Day : Integer); Parameters: [in] DT DateTime variable name [out] Year Year [out] Month Month [out] Day Day
GetIQData 920i	Returns data from a given iQUBE; the types that IQValType may be are: IQSys, IQPlat, IQRawLC, IQCorrLC, IQZeroLC, IQStatLC, IQScaleWt, and IQ2StatusLC; IQSys returns the system weight value; IQPlat returns the millivolt value for the indexed platform; IQRawLC returns the indexed raw load cell millivolt value; IQCorrLC returns the indexed corrected load cell millivolt value; IQZeroLC returns the indexed load cell deadload millivolt value; IQStatLC returns the indexed load cell status; IQ2ScaleWt returns the indexed scale weight value; IQSys and IQPlat are revised to also return the scale data; IQ2StatusLC returns the indexed load cell status; The old IQStatLC is not supported and will return SysInvalidRequest NOTE: When using with Firmware 4.xx/iQube2: The IQSys and IQPlat data types will return SysOk as long as the command is correctly formatted (scale exists). To tell whether the iQUBE² is in an error condition, look at the value (not the syscode) of the IQ2StatusLC data type. Method Signature: function GetIqubeData(port_no : integer; dataType : IQValType; index : integer; VAR data : real) : SysCode; SysCode values returned: SysOutOfRange The array index is less than or equal to 0 SysInvalidRequest The requested port is not configured as an iQUBE; The value cannot be returned due to the device configuration, trying to address load cell 17; Certain requests while the diagnostic screen is open or an invalid data type is requested SysDeviceError The scale is reporting an internal error SysOK The function completed successfully
GetIQData 1280	Returns data from a given iQUBE; The types that IQValType may be are: IQSys, IQPlat, IQRawLC, IQCorrLC, IQZeroLC, IQStatLC, IQScaleWt, and IQ2StatusLC; IQSys returns the system weight value; IQPlat returns the millivolt value for the indexed platform; IQRawLC returns the indexed raw load cell millivolt value; IQCorrLC returns the indexed corrected load cell millivolt value; IQZeroLC returns the indexed load cell deadload millivolt value; IQStatLC returns the indexed load cell status; IQ2ScaleWt returns the indexed scale weight value; IQSys and IQPlat are revised to also return the scale data; IQ2StatusLC returns the indexed load cell status; The old IQStatLC is not supported and will return SysInvalidRequest NOTE: When using with Firmware 4.xx/iQube2: The IQSys and IQPlat data types will return SysOk as long as the command is correctly formatted (i.e., scale exists). To tell whether the iQUBE² is in an error condition, look at the value (not the syscode) of the IQ2StatusLC data type. Method Signature: function GetIQData(Connection Name : string; dataType : IQValType; index : integer; VAR data : real) : SysCode; SysCode values returned: SysOutOfRange The array index is less than or equal to 0 SysInvalidRequest The requested port is not configured as an iQUBE; The value cannot be returned due to the device configuration, trying to address load cell 17; Certain requests while the diagnostic screen is open or an invalid data type is requested SysDeviceError The scale is reporting an internal error SysOK The function completed successfully

Table 5-9. System Support Methods (Continued)

Methods	Description
GetKey 920i 820i 880 882D 1280	<p>Waits for a key press from the indicator front panel before continuing the program; The optional time-out is specified in 0.01-second intervals (1/100 seconds); If the wait time is set to zero, the procedure will wait indefinitely</p> <p>Method Signature: function GetKey (timeout : Integer);</p> <p>Parameters: [in] timeout Time-out value</p> <p><i>Example:</i> this_key : Keys; ... DisplayStatus ("Press [Enter] for Yes");</p> <pre> this_key = GetKey(0); if this_key = EnterKey then DisplayStatus ("Yes"); else DisplayStatus ("No"); end if; </pre>
GetMACAddress 1280	<p>Returns a string value of the read-only onboard MAC address</p> <p>Method Signature: function GetMACAddress : String;</p>
GetSoftware Version 920i 820i 880 882D 1280	<p>Returns the current software version</p> <p>Method Signature: function GetSoftwareVersion : String;</p>
GetTime 920i 820i 880 882D 1280	<p>Extracts time information from DT and places the data in variables Hour, Minute, and Second</p> <p>Method Signature: procedure GetTime (DT : DateTime; VAR Hour : Integer; VAR Minute : Integer; VAR Second : Integer);</p> <p>Parameters: [in] DT DateTime variable name [out] Hour Hour [out] Minute Minute [out] Second Second</p>
GetUID 920i 820i 880 882D 1280	<p>Returns the current unit identifier</p> <p>Method Signature: function GetUID : String;</p>
Hardware 920i 820i 880 882D 1280	<p>Returns an array of HW_type; The elements of the array correspond to option card slots in the indicator; This API is useful for determining the presence of option cards that are required or that could activate different options in the user program</p> <p>Method Signature: procedure Hardware(var hw : HW_array_type);</p> <p>SysCode values returned: None</p>

Table 5-9. System Support Methods (Continued)

Methods	Description
KeyPress 920i 820i 880 882D 1280	<p>Provides intrinsic functionality for a key; The following keys will have intrinsic function, in addition to the front panel keys already in the Keys built-in type: TimeDateKey, WeighInKey, WeighOutKey, ID_EntryKey, DisplayTareKey, TruckRegsKey, DisplayAccumKey, ScaleSelectKey, DisplayROCKey, SetpointKey, BatchStartKey, BatchStopKey, BatchPauseKey, BatchResetKey, DiagnosticsKey, ContactsKey, DoneKey, TestKey, ContrastKey, LLStopKey, LLGoKey, LLOffKey, AuditKey, KeyedTareKey, ClearAccumKey, AuxPrintKey, USBKey (in 920i only), DatabaseKey (in 1280 only); The ContactsKey will actually function like the Dignostics softkey, while the DiagnosticsKey will go straight to the Diagnostics screen; The DoneKey will only return from the contacts screen; The TestKey will allow the user program to test for strict weigh mode by not doing anything at all; This API will only function in actual weigh mode</p> <p>Method Signature: function KeyPress (K : Keys) : SysCode;</p> <p>SysCode values returned:</p> <p>SysInvalidMode The indicator is not actually in weigh mode; The TestKey will return SysInvalidMode for all sub-modes of weigh mode (the contact screen) as well as any other mode (time & date entry, or open prompt)</p> <p>SysInvalidKey Any Invalid key; softkeys and Undefined Keys are considered invalid</p> <p>SysInvalidRequest Processing the key returns invalid or error</p> <p>SysOK The function completed successfully</p>
LockKey 920i 820i 880 882D 1280	<p>Disables the specified front panel key; possible values are: ZeroKey, GrossNetKey, TareKey, UnitsKey, PrintKey, Soft1Key, Soft2Key, Soft3Key, Soft4Key, Soft5Key, NavUpKey, NavRightKey, NavDownKey, NavLeftKey, EnterKey, N1Key, N2Key, N3Key, N4Key, N5Key, N6Key, N7Key, N8Key, N9Key, N0Key, DecpntKey, ClearKey</p> <p>Method Signature: function LockKey (K : Keys) : SysCode;</p> <p>Parameters: [in] K Key name</p> <p>SysCode values returned:</p> <p>SysInvalidKey The key specified is not valid</p> <p>SysOK The function completed successfully</p>
LockKeypad 920i 820i 880 882D 1280	<p>Disables operation of the entire front panel keypad</p> <p>Method Signature: function LockKeypad : SysCode;</p> <p>SysCode values returned:</p> <p>SysPermissionDenied</p> <p>SysOK The function completed successfully</p>
ProgramDelay 920i 820i 880 882D 1280	<p>Pauses the user program for the specified time; Delay time is entered in 0.01-second intervals (1/100 seconds, 100 = 1 second)</p> <p>Method Signature: procedure ProgramDelay (D : Integer);</p> <p>Parameters: [in] D Delay time</p> <p><i>Example:</i> ProgramDelay(200); –Pauses the program for 2 seconds</p>
RestartNetworks 1280	<p>Resets the network if connection is lost</p> <p>Method Signature: function RestartNetworks : SysCode;</p> <p>SysCode values returned:</p> <p>SysOK The function completed successfully</p> <p>SysDeviceError Function failed to reset</p>
ResumeDisplay 920i 820i 1280	<p>Resumes a suspended display</p> <p>Method Signature: procedure ResumeDisplay;</p>

Table 5-9. System Support Methods (Continued)

Methods	Description
SetConsecNum 920i 820i 880 882D 1280	Sets V to the value of the consecutive number counter Method Signature: function SetConsecNum (V : Integer) : SysCode; Parameters: [in] V Consecutive number SysCode values returned: SysOutOfRange The value specified is not in the allowed range; The consecutive number is not changed SysOK The function completed successfully
SetDate 920i 820i 880 882D 1280	Sets the date in DT to the values specified by Year , Month , and Day Method Signature: function SetDate (VAR DT : DateTime; VAR Year : Integer; VAR Month : Integer; VAR Day : Integer) : SysCode; Parameters: [out] DT DateTime variable name [in] Year Year [in] Month Month [in] Day Day SysCode values returned: SysInvalidRequest Year, month, or day entry not valid SysOK The function completed successfully
SetSoftkeyText 920i 820i 1280	Sets the text of softkey K (representing F1–F10) to the text specified by S Method Signature: function SetSoftkeyText (K : Integer; S : String) : SysCode; Parameters: [in] K Softkey number [in] S Softkey text SysCode values returned: SysInvalidRequest The value specified for K is less than 1 or greater than 10, or does not represent a configured softkey SysOK The function completed successfully
SetSystemTime 920i 820i 880 882D 1280	Sets the realtime clock to the value specified in DT Method Signature: function SetSystemTime (DT : DateTime); Parameters: [in] DT System DateTime
SetTime 920i 820i 880 882D 1280	Sets the time in DT to the values specified by Hour , Minute , and Second Method Signature: function SetTime (VAR DT : DateTime; Hour : Integer; Minute : Integer; Second : Integer) : SysCode; Parameters: [out] DT DateTime variable name [in] Hour Hour [in] Minute Minute [in] Second Second SysCode values returned: SysInvalidRequest Hour or minute entry not valid SysOK The function completed successfully
SetUID 920i 820i 880 882D 1280	Sets the unit identifier NOTE: Changes made to the UID using the SetUID function are lost when the indicator power is cycled. When power is restored, the UID is reset to the value at the last SAVE/EXIT from configuration mode. Method Signature: function SetUID (newid : String); Parameters: [in] newid Unit identifier

Table 5-9. System Support Methods (Continued)

Methods	Description
StartFTPServer 1280	Allows access for external devices to the FTP server; Password must be manually configured and ftp server must be enabled in configuration Method Signature function StartFTPServer : SysCode; SysCode Values Returned SysOK Started Successfully SysInvalidFtpConfig FTP Server is not enabled in Features -> FTP -> FTP Enabled SysInvalidNetworkConfig Ethernet is not enabled in Communications -> Ethernet -> Enabled SysFtpStartFailed ftp server did not start (not password related)
STick 920i 820i 880 882D 1280	Returns the number of system ticks, in 1/1200th of a second intervals, since the indicator was powered on (1200 = 1 second) Method Signature: function STick : Integer; NOTE: STick is maintained internally as an unsigned 32-bit integer. When the MSB rolls over, it appears as a large negative number. Then it becomes decreasingly negative before rolling over to zero and becoming positive again. Ensure that calculations involving STick take these transitions into account. It takes 41-42 days of continuous operation for the STick value to rollover completely. Cycling power resets the count.
StopFTPServer 1280	Shuts down access for external devices to the FTP server Method Signature: function StopFTPServer : SysCode; SysCode Value Returned: SysOk Stopped Successfully
SuspendDisplay 920i 820i 1280	Suspends the display Method Signature: procedure SuspendDisplay;
SystemTime 920i 820i 880 882D 1280	Returns the current system date and time Method Signature: function SystemTime : DateTime;
Time\$ 920i 820i 880 882D 1280	Returns a string representing the system time contained in DT Method Signature: function Time\$ (DT : DateTime) : String;
UnlockKey 920i 820i 880 882D 1280	Enables the specified front panel key; Possible values are: ZeroKey, GrossNetKey, TareKey, UnitsKey, PrintKey, Soft1Key, Soft2Key, Soft3Key, Soft4Key, Soft5Key, NavUpKey, NavRightKey, NavDownKey, NavLeftKey, EnterKey, N1Key, N2Key, N3Key, N4Key, N5Key, N6Key, N7Key, N8Key, N9Key, N0Key, DecpntKey, ClearKey Method Signature: function UnlockKey (K : Keys) : SysCode; Parameters: [in] K Key name SysCode values returned: SysInvalidKey The key specified is not valid SysOK The function completed successfully
UnlockKeypad 920i 820i 880 882D 1280	Enables operation of the entire front panel keypad Method Signature: function UnlockKeypad : SysCode; SysCode values returned: SysPermissionDenied SysOK The function completed successfully

Table 5-9. System Support Methods (Continued)

Methods	Description
WaitForEntry 920i 820i 880 882D 1280	Similar to GetEntry, WaitForEntry causes the user program to wait for operator input; Wait time is specified in 0.01-second intervals (1/100 seconds); if the wait time is set to zero, the procedure will wait indefinitely or until the Enter key is pressed NOTE: The UserEntry handler must be disabled (see DisableHandler on page 54) before using this procedure. Method Signature: procedure WaitForEntry (I : Integer); Parameters: [in] I Wait time value

Table 5-9. System Support Methods (Continued)

5.3 Serial I/O

Methods	Description
Print 920i 820i 880 882D 1280	Requests a print operation using the print format specified by F; Output is sent to the port specified in the print format configuration Method Signature: function Print (F : PrintFormat) : SysCode; Parameters: [in] F Print format 920i, 820i and 1280 PrintFormat values sent: GrossFmt Gross format NetFmt Net format TrWInFmt Truck weigh-in format TrRegFmt Truck register format (truck IDs and tare weights) TrWOutFmt Truck weigh-out format SPFmt Setpoint format AccumFmt Accumulator format AuxFmtx Auxiliary format (x = 1 - 20) 880 PrintFormat values sent: GrossFmt Gross format NetFmt Net format SPFmt Setpoint format AccumFmt Accumulator format 882D PrintFormat values sent: PrintFormat1 Print format 1 PrintFormat2 Print format 2 PrintFormat3 Print format 3 PrintFormat4 Print format 4 SysCode values returned: SysInvalidRequest The print format specified by F does not exist SysQFull The request could not be processed because the print queue is full SysOK The function completed successfully <i>Example:</i> Fmtout : PrintFormat; ... Fmtout := NetFmt Print (Fmtout);

Table 5-10. Serial I/O Methods

Methods	Description															
Send 920i 820i 880 882D 1280	<p>Writes an ASCII representation of the in-memory bytes of the integer or real number specified in <number> to the port specified by P</p> <p>Method Signature: procedure Send (P : Integer; <number>);</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>P</td> <td>Serial port number</td> </tr> <tr> <td>[in]</td> <td><number></td> <td>The integer or real number to output</td> </tr> </table> <p><i>Example:</i> Send (Port1, 123.55); –sends "<42><F7><19><9A>" (without the quotes or <> symbols) to Port 1 where: <42> = 42 hex (66 decimal) <F7> = F7 hex (247 decimal) <19> = 19 hex (25 decimal) <9A> = 9A hex (154 decimal) Send (1, 4276803); –sends "<00>ABC" (without the quotes) to Port 1 - where <00> is an ASCII nul</p>	[in]	P	Serial port number	[in]	<number>	The integer or real number to output									
[in]	P	Serial port number														
[in]	<number>	The integer or real number to output														
SendChr 920i 820i 880 882D 1280	<p>Writes the single character specified to the port specified by P</p> <p>Method Signature: procedure SendChr (P : Integer; character : Integer);</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>P</td> <td>Serial port number</td> </tr> <tr> <td>[in]</td> <td>character</td> <td>The decimal value of the character to transmit</td> </tr> </table> <p><i>Example:</i> SendChr (1, 65); –sends upper-case "A" (decimal 65) to Port 1</p>	[in]	P	Serial port number	[in]	character	The decimal value of the character to transmit									
[in]	P	Serial port number														
[in]	character	The decimal value of the character to transmit														
SendChrArray 920i	<p>Writes a number of characters, specified by their decimal values in ChrArray, to the port specified by P. The range of values in the array is 0-255. This API provides functionality similar to making repeated calls to the SendChr API, but without a transmission delay between characters.</p> <p>Method Signature: function SendChrArray (P : Integer; data : ChrArray; Length : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>P</td> <td>Serial port number</td> </tr> <tr> <td>[in]</td> <td>ChrArray</td> <td>The array of characters to output</td> </tr> <tr> <td>[in]</td> <td>Length</td> <td>The number of bytes to transmit</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysOutOfRange</td> <td>Length < 1 or > 100</td> </tr> <tr> <td>SysInvalidPort</td> <td>The port number specified for P is not valid</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> data : ChrArray; data[1] := 3; data[2] := 4; data[3] := 5; data[4] := 6; data[5] := 32; data[6] := 0; data[7] := 77; data[8] := 220; SendChrArray (1, data, 8);</p>	[in]	P	Serial port number	[in]	ChrArray	The array of characters to output	[in]	Length	The number of bytes to transmit	SysOutOfRange	Length < 1 or > 100	SysInvalidPort	The port number specified for P is not valid	SysOK	The function completed successfully
[in]	P	Serial port number														
[in]	ChrArray	The array of characters to output														
[in]	Length	The number of bytes to transmit														
SysOutOfRange	Length < 1 or > 100															
SysInvalidPort	The port number specified for P is not valid															
SysOK	The function completed successfully															

Table 5-10. Serial I/O Methods (Continued)

Methods	Description
SendNull 920i 820i 880 882D 1280	Writes an ASCII null character (decimal 00) to the port specified by P Method Signature: procedure SendNull (P : Integer); Parameters: [in] P Serial port number <i>Example:</i> SendNull (1); <i>–sends an ASCII null character (decimal 00) to Port 1</i>
SetPrintText 920i 820i 880 882D 1280	Sets the value of the user-specified format (1–99) to the text specified; The text can be any string of up to 16-characters; If a string of more than 16-characters is specified, nothing is printed Method Signature: function SetPrintText (fmt_num : Integer ; text : String) : SysCode; Parameters: [in] fmt_num User-specified format number [in] text Print format text SysCode values returned: SysOutOfRange The text is more than 16 characters SysInvalidRequest The specified format number is out of the range of 1–99 SysOK The function completed successfully <i>Example:</i> SetPrintText(1, "User Pgm. Text");
StartStreaming 920i 820i 880 882D	Starts data streaming for the port number specified by P; Streaming must be enabled for the port in the indicator configuration Method Signature: function StartStreaming (P : Integer) : SysCode; Parameters: [in] P Serial port number SysCode values returned: SysInvalidPort The port number specified for P is not valid SysInvalidRequest The port specified for P is not configured for streaming SysOK The function completed successfully <i>Example:</i> StartStreaming (1);
StartStreaming 1280	Starts data streaming for the stream format specified by S; Streaming must be enabled for the port in the indicator configuration Method Signature: function StartStreaming (S : Integer) : SysCode; Parameters: [in] S Stream format number (1-4) SysCode values returned: SysInvalidRequest The stream format specified by S is not configured for streaming SysOK The function completed successfully <i>Example:</i> StartStreaming (1);
StopStreaming 920i 820i 880 882D	Stops data streaming for the port number specified by P Method Signature: function StopStreaming (P : Integer) : SysCode; Parameters: [in] P Serial port number SysCode values returned: SysInvalidPort The port number specified for P is not valid SysInvalidRequest The port specified for P is not configured for streaming SysOK The function completed successfully <i>Example:</i> StopStreaming (1);

Table 5-10. Serial I/O Methods (Continued)

Methods	Description
StopStreaming 1280	Stops data streaming for the stream format specified by S Method Signature: function StopStreaming (S : Integer) : SysCode; Parameters: [in] S Stream format number (1-4) SysCode values returned: SysInvalidRequest The stream format specified by S is not configured for streaming SysOK The function completed successfully <i>Example:</i> StopStreaming (1);
Write 920i 820i 880 882D 1280	Writes the text specified in the <arg-list> to the port specified by P ; A subsequent Write or WriteLn operation will begin where this Write operation ends; An End-of-Line termination is not included at the end of the data sent to the port NOTE: This procedure cannot be used to send null characters. Use the SendChr or SendNull procedure to send null characters. Method Signature: procedure Write (P : Integer; <arg-list>); Parameters: [in] P Serial port number [in] arg_list Print text <i>Example:</i> Write (1, "This is a test.");
WriteLn 920i 820i 880 882D 1280	Writes the text specified in the <arg-list> to the port specified by P , followed by the End-of-Line termination character(s) specified in the configuration parameters for the specified port; A subsequent Write or WriteLn operation begins on the next line NOTE: This procedure cannot be used to send null characters. Use the SendChr or SendNull procedure to send null characters. Method Signature: procedure Write (P : Integer; <arg-list>); Parameters: [in] P Serial port number [in] arg_list Print text <i>Example:</i> WriteLn (1, "This is another test.");
WriteOut 1280	Writes the text specified in the <arg-list> to the connection named by C ; A subsequent WriteOut or WriteOutLn operation will begin where this WriteOut operation ends; A carriage return is not included at the end of the data sent to the connection Method Signature: procedure WriteOut (C : String; <arg-list>); Parameters: [in] C Connection port number [in] arg_list Print text
WriteOutLn 1280	Writes the text specified in the <arg-list> to the connection named by C , followed by a carriage return and a line feed (CR/LF); A subsequent WriteOut or WriteOutLn operation begins on the next line Method Signature: procedure WriteOutLn (C : String; <arg-list>); Parameters: [in] C Connection port number [in] arg_list Print text

Table 5-10. Serial I/O Methods (Continued)

5.3.1 880 Port Numbering

Port Numbers	Port Description
1	Com Port
2	USB Device Port
3	Ethernet Server
4	Ethernet Client
5	Serial Option Card- Channel 1
6	Serial Option Card- Channel 2

Table 5-11. Port Numbering Description

Advanced Printing

Methods	Description
StartDocument (ADVPRN) 1280	Opens a connection to the printer setup in the Advanced Printer settings under the Features section; Must use this function before writing any data to the printer
EndDocument (ADVPRN) 1280	Closes the connection to the printer setup in the Advanced Printer setting under the Features section; Document will not print if this is not used after a StartDocument API is used Method Signature: Function(Connection : String) : Syscode; Parameters: [In] Connection This needs to be set to "ADVPRN" SysCode values returned: SysOK The function completed successfully <i>Example:</i> <pre> if StartDocument("ADVPRN") = SysOk then Writeoutln("ADVPRN", "String data to print"); else DisplayStatus("Printer Error"); end if; if EndDocument("ADVPRN") = SysOk then DisplayStatus("Document Printed"); else DisplayStatus("Printer Error"); end if; </pre>

Table 5-12. Advanced Printing Methods

5.4 Program Scale

Methods	Description				
SubmitData 920i 1280 820i	<p>Passes data from a user program to the scale processor; weight, mode, and tare values are provided by the user program; The displayed weight is the weight value minus tare; Gross/net mode is set by the gn parameter regardless of whether a tare value is passed; This allows display of a net value when the net is known but gross and tare values are not available</p> <p>NOTE: Because the user program supplies all weight data, weight data acquisition APIs are not valid for program scales. When used with program scales, these APIs (including GetGross, GetNet, GetTare) will typically return a SysCode value of SysInvalidScale. Always check the returned SysCode value of scale-related APIs to ensure valid data.</p> <p>Syntax: function SubmitData (scale : Integer; weight : Real; gn : Mode; units : UnitType; tare : Real) : SysCode;</p> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale is not set up as a program scale</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	SysInvalidScale	The scale is not set up as a program scale	SysOK	The function completed successfully
SysInvalidScale	The scale is not set up as a program scale				
SysOK	The function completed successfully				
SubmitDSPData	<p>Submit data to a program scale; This function works much like SubmitData() but has fewer parameters; New to this function is the dp : Decimal_Type that allows the program to set the decimal point for display; The call assumes Gross mode and primary units</p> <p>Syntax: function SubmitDSPData(scale : integer; weight : real; units : string; dp : Decimal_Type) : SysCode;</p> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale is not set up as a program scale</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	SysInvalidScale	The scale is not set up as a program scale	SysOK	The function completed successfully
SysInvalidScale	The scale is not set up as a program scale				
SysOK	The function completed successfully				

Table 5-13. Program Scale Methods

5.5 Setpoints and Batching



NOTE: Unless otherwise stated, when an API with a VAR parameter returns a SysCode value other than SysOK, the VAR parameter is not changed.

Command	Description											
DisableSP 920i 820i 880 882D 1280	<p>Disables operation of setpoint SP</p> <p>Method Signature: function DisableSP (SP : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysBatchRunning</td> <td>Setpoint SP cannot be disabled while a batch is running</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP cannot be enabled or disabled</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> DisableSP (4);</p>	[in]	SP	Setpoint number	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysBatchRunning	Setpoint SP cannot be disabled while a batch is running	SysInvalidRequest	The setpoint specified by SP cannot be enabled or disabled	SysOK	The function completed successfully
[in]	SP	Setpoint number										
SysInvalidSetpoint	The setpoint specified by SP does not exist											
SysBatchRunning	Setpoint SP cannot be disabled while a batch is running											
SysInvalidRequest	The setpoint specified by SP cannot be enabled or disabled											
SysOK	The function completed successfully											
EnableSP 920i 820i 880 882D 1280	<p>Enables operation of setpoint SP</p> <p>Method Signature: function EnableSP (SP : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysBatchRunning</td> <td>Setpoint SP cannot be enabled while a batch is running</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP cannot be enabled or disabled</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> EnableSP (4);</p>	[in]	SP	Setpoint number	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysBatchRunning	Setpoint SP cannot be enabled while a batch is running	SysInvalidRequest	The setpoint specified by SP cannot be enabled or disabled	SysOK	The function completed successfully
[in]	SP	Setpoint number										
SysInvalidSetpoint	The setpoint specified by SP does not exist											
SysBatchRunning	Setpoint SP cannot be enabled while a batch is running											
SysInvalidRequest	The setpoint specified by SP cannot be enabled or disabled											
SysOK	The function completed successfully											

Table 5-14. Setpoint and Batching Commands

Command	Description
GetBatchingMode 920i 820i 880 882D 1280	Returns the current batching mode (BATCHNG parameter) Method Signature: function GetBatchingMode : BatchingMode; BatchingMode values returned: Off Batching mode is off Auto Batching mode is set to automatic Manual Batching mode is set to manual NOTE: The 882D does not have an Auto Batching mode.
GetBatchStatus 920i 820i 880 882D 1280	Sets S to the current batch status Method Signature: function GetBatchStatus (VAR S : BatchStatus) : SysCode; Parameters: [out] S Batch status BatchStatus values returned: BatchComplete The batch is complete BatchStopped The batch is stopped BatchRunning A batch routine is in progress BatchPaused The batch is paused SysCode values returned: SysInvalidRequest The BATCHNG configuration parameter is set to OFF SysOK The function completed successfully
GetCurrentSP 920i 820i 880 882D 1280	Sets SP to the number of the current batch setpoint Method Signature: function GetCurrentSP (VAR SP : Integer) : Syscode; Parameters: [out] SP Setpoint number SysCode values returned: SysInvalidRequest The BATCHNG configuration parameter is set to OFF SysBatchNotRunning No batch routine is running SysOK The function completed successfully <i>Example:</i> CurrentSP : Integer; ... GetCurrentSP (CurrentSP); WriteLn (1, "Current setpoint is " + IntegerToString(CurrentSP,0));
GetSPBand 920i 820i 880 1280	Sets V to the current band value (BANDVAL parameter) of the setpoint SP Method Signature: function GetSPBand (SP : Integer; VAR V : Real) : SysCode; Parameters: [in] SP Setpoint number [out] V Band value SysCode values returned: SysInvalidSetpoint The setpoint number specified by SP is less than 1 or greater than the maximum number of setpoints SysInvalidRequest The setpoint specified by SP has no band value (BANDVAL) parameter SysOK The function completed successfully. <i>Example:</i> SP7Bandval : Real; ... GetSPBand (7, SP7Bandval); WriteLn (1, "Current Band Value of SP7 is " + RealToString(SP7Bandval,0,2));

Table 5-14. Setpoint and Batching Commands (Continued)

Command	Description
GetSPCaptured 920i 820i 880 882D 1280	Sets V to the weight value that satisfied the setpoint SP Method Signature: function GetSPCaptured (SP : Integer; VAR V : Real) : SysCode; Parameters: [in] SP Setpoint number [out] V Captured weight value SysCode values returned: SysInvalidSetpoint The setpoint number specified by SP is less than 1 or greater than the maximum number of setpoints SysInvalidRequest The setpoint is off and has no captured value SysOK The function completed successfully
GetSPCount 920i 820i 1280	For DINCNT setpoints, sets Count to the value specified for setpoint SP Method Signature: function GetSPCount (SP : Integer; VAR Count : Integer) : SysCode; Parameters: [in] SP Setpoint number [out] Count Count value SysCode values returned: SysInvalidSetpoint The setpoint number specified by SP is less than 1 or greater than the maximum number of setpoints SysInvalidRequest The specified setpoint is not a DINCNT setpoint SysOK The function completed successfully
GetSPDuration 920i 820i 1280	For time of day (TOD) setpoints, sets DT to the current trip duration (DURATION parameter) of setpoint SP Method Signature: function GetSPDuration (SP : Integer; VAR DT : DateTime) : SysCode; Parameters: [in] SP Setpoint number [out] DT Setpoint trip duration SysCode values returned: SysInvalidSetpoint The setpoint specified by SP does not exist SysInvalidRequest The setpoint specified by SP has no DURATION parameter SysOK The function completed successfully <i>Example:</i> SP3DUR : DateTime; ... GetSPTime (3, SP3DUR); WriteLn (Port1, "Current Trip Duration of SP3 is", SP3DUR);
GetSPHyster 920i 820i 880 1280	Sets V to the current hysteresis value (HYSTER parameter) of the setpoint SP Method Signature: function GetSPHyster (SP : Integer; VAR V : Real) : SysCode; Parameters: [in] SP Setpoint number [out] V Hysteresis value SysCode values returned: SysInvalidSetpoint The setpoint specified by SP does not exist SysInvalidRequest The setpoint specified by SP has no hysteresis HYSTER) parameter SysOK The function completed successfully <i>Example:</i> SP5Hyster : Real; ... GetSPHyster (5, SP5Hyster); WriteLn (1, "Current Hysteresis Value of SP5 is " + RealToString(SP5Hyster,0,2));

Table 5-14. Setpoint and Batching Commands (Continued)

Command	Description												
GetSPNSample 920i 820i 820i	<p>For averaging (AVG) setpoints, sets N to the current number of samples (NSAMPLE parameter) of the setpoint SP</p> <p>Method Signature: function GetSPNSample (SP : Integer; VAR N : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[out]</td> <td>N</td> <td>Sample value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no NSAMPLE parameter</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP5NS : Integer; ... GetSPNSample (5, SP5NS); WriteLn (1, "Current NSample Value of SP5 is " + IntegerToString(SP5NS,0));</p>	[in]	SP	Setpoint number	[out]	N	Sample value	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no NSAMPLE parameter	SysOK	The function completed successfully
[in]	SP	Setpoint number											
[out]	N	Sample value											
SysInvalidSetpoint	The setpoint specified by SP does not exist												
SysInvalidRequest	The setpoint specified by SP has no NSAMPLE parameter												
SysOK	The function completed successfully												
GetSPPreact 920i 820i 880 882D 1280	<p>Sets V to the current preact value (PREACT parameter) of the setpoint SP</p> <p>Method Signature: function GetSPPreact (SP : Integer; VAR V : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[out]</td> <td>V</td> <td>Preact value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no preact (PREACT) parameter</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP2Preval : Real; ... GetSPPreact (2, SP2Preval); WriteLn (1, "Current Preact Value of SP2 is " + RealToString(SP2Preval,0,2));</p>	[in]	SP	Setpoint number	[out]	V	Preact value	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no preact (PREACT) parameter	SysOK	The function completed successfully
[in]	SP	Setpoint number											
[out]	V	Preact value											
SysInvalidSetpoint	The setpoint specified by SP does not exist												
SysInvalidRequest	The setpoint specified by SP has no preact (PREACT) parameter												
SysOK	The function completed successfully												
GetSPPreCount 920i 820i 1280	<p>Sets Count to the preact count value (PCOUNT parameter) of DINCNT type setpoint SP</p> <p>Method Signature: function GetSPPreCount (SP : Integer; VAR Count : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[out]</td> <td>Count</td> <td>Preact count value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP is not DINCNT type parameter</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP3PCount : Integer; ... GetSPPreCount (3, SP3PCount); WriteLn (1, "Current Preact Learn Value of SP3 is " + IntegerToString(SP3PCount,0));</p>	[in]	SP	Setpoint number	[out]	Count	Preact count value	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP is not DINCNT type parameter	SysOK	The function completed successfully
[in]	SP	Setpoint number											
[out]	Count	Preact count value											
SysInvalidSetpoint	The setpoint specified by SP does not exist												
SysInvalidRequest	The setpoint specified by SP is not DINCNT type parameter												
SysOK	The function completed successfully												

Table 5-14. Setpoint and Batching Commands (Continued)

Command	Description												
GetSPTIME 920i 820i 1280	<p>For time of day (TOD) setpoints, sets DT to the current trip time (TIME parameter) of the setpoint SP</p> <p>Method Signature: function GetSPTIME (SP : Integer; VAR DT : DateTime) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[out]</td> <td>DT</td> <td>Current setpoint trip time</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no TIME parameter</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP2TIME : DateTime; ... GetSPTIME (2, SP2TIME); WriteLn (Port1, "Current Trip Time of SP2 is", SP2TIME);</p>	[in]	SP	Setpoint number	[out]	DT	Current setpoint trip time	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no TIME parameter	SysOK	The function completed successfully
[in]	SP	Setpoint number											
[out]	DT	Current setpoint trip time											
SysInvalidSetpoint	The setpoint specified by SP does not exist												
SysInvalidRequest	The setpoint specified by SP has no TIME parameter												
SysOK	The function completed successfully												
GetSPValue 920i 820i 880 882D 1280	<p>Sets V to the current value (VALUE parameter) of the setpoint SP</p> <p>Method Signature: function GetSPValue (SP : Integer; VAR V : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[out]</td> <td>V</td> <td>Setpoint value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no VALUE parameter</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP4Val : Real; ... GetSPValue (4, SP4Val); WriteLn (1, "Current Value of SP4 is " + RealToString(SP4Val,0,2));</p>	[in]	SP	Setpoint number	[out]	V	Setpoint value	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no VALUE parameter	SysOK	The function completed successfully
[in]	SP	Setpoint number											
[out]	V	Setpoint value											
SysInvalidSetpoint	The setpoint specified by SP does not exist												
SysInvalidRequest	The setpoint specified by SP has no VALUE parameter												
SysOK	The function completed successfully												
GetSPVover 920i 820i	<p>For checkweigh (CHKWEI) setpoints, sets V to the current overrange value (VOVER parameter) of the setpoint SP</p> <p>Method Signature: function GetSPVover (SP : Integer; VAR V : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[out]</td> <td>V</td> <td>Overrange value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no VOVER parameter</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP3VOR : Real; ... GetSPVover (3, SP3VOR); WriteLn (1, "Current Overrange Value of SP3 is " + RealToString(SP3VOR,0,2));</p>	[in]	SP	Setpoint number	[out]	V	Overrange value	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no VOVER parameter	SysOK	The function completed successfully
[in]	SP	Setpoint number											
[out]	V	Overrange value											
SysInvalidSetpoint	The setpoint specified by SP does not exist												
SysInvalidRequest	The setpoint specified by SP has no VOVER parameter												
SysOK	The function completed successfully												

Table 5-14. Setpoint and Batching Commands (Continued)

Command	Description
GetSPVunder 920i 820i 820i	<p>For checkweigh (CHKWEI) setpoints, sets V to the current underrange value (VUNDER parameter) of the setpoint SP</p> <p>Method Signature: function GetSPVunder (SP : Integer; VAR V : Real) : SysCode;</p> <p>Parameters: [in] SP Setpoint number [out] V Underrange value</p> <p>SysCode values returned: SysInvalidSetpoint The setpoint specified by SP does not exist SysInvalidRequest The setpoint specified by SP has no VUNDER parameter SysOK The function completed successfully</p> <p><i>Example:</i> SP4VUR : Real; ... GetSPVunder (4, SP4VUR); WriteLn (1, "Current Underrange Value of SP4 is " + RealToString(SP4VUR,0,2));</p>
PauseBatch 920i 820i 880 882D 1280	<p>Initiates a latched pause of a running batch process</p> <p>Method Signature: function PauseBatch : SysCode;</p> <p>SysCode values returned: SysPermissionDenied The BATCHNG configuration parameter is set to OFF SysBatchRunning No batch routine is running SysOK The function completed successfully</p>
ResetBatch 920i 820i 880 882D 1280	<p>Terminates a running, stopped, or paused batch process and resets the batch system</p> <p>Method Signature: function ResetBatch : SysCode;</p> <p>SysCode values returned: SysPermissionDenied The BATCHNG configuration parameter is set to OFF SysBatchRunning No batch routine is running SysOK The function completed successfully</p>
SaveSetpoint Updates 1280	<p>Saves setpoint changes made in iRite to permanent memory</p> <p>Method Signature: function SavesetpointUpdates;</p> <p>Parameters: None</p> <p>SysCode values returned: None</p>
SetBatchingMode 920i 820i 880 882D 1280	<p>Sets the batching mode (BATCHNG parameter) to the value specified by M</p> <p>Method Signature: function SetBatchingMode (M : BatchingMode) : SysCode;</p> <p>Parameters: [in] SP Setpoint number [in] M Batching mode</p> <p>BatchingMode values sent: Off Batching mode is off Auto Batching mode is set to automatic Manual Batching mode is set to manual NOTE: The 882D does not have an Auto Batching mode.</p> <p>SysCode values returned: SysInvalidMode The batching mode specified by M is not valid SysOK The function completed successfully</p>

Table 5-14. Setpoint and Batching Commands (Continued)

Command	Description																
SetSPBand 920i 820i 880 1280	<p>Sets the band value (BANDVAL parameter) of setpoint SP to the value specified by V</p> <p>Method Signature: function SetSPBand (SP : Integer; V : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[in]</td> <td>V</td> <td>Band value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no band value (BANDVAL) parameter</td> </tr> <tr> <td>SysBatchRunning</td> <td>The value cannot be changed because a batch process is currently running</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP7Bandval : Real; ... SP7Bandval := 10.0 SetSPBand (7, SP7Bandval);</p>	[in]	SP	Setpoint number	[in]	V	Band value	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no band value (BANDVAL) parameter	SysBatchRunning	The value cannot be changed because a batch process is currently running	SysOK	The function completed successfully		
[in]	SP	Setpoint number															
[in]	V	Band value															
SysInvalidSetpoint	The setpoint specified by SP does not exist																
SysInvalidRequest	The setpoint specified by SP has no band value (BANDVAL) parameter																
SysBatchRunning	The value cannot be changed because a batch process is currently running																
SysOK	The function completed successfully																
SetSPCount 920i 820i 1280	<p>For DINCNT setpoints, sets the VALUE parameter of setpoint SP to the value specified by Count</p> <p>Method Signature: function SetSPCount (SP : Integer; Count : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[in]</td> <td>Count</td> <td>Count value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint number specified by SP is less than 1 or greater than the maximum number of setpoints</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The specified setpoint is not a DINCNT setpoint</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	[in]	SP	Setpoint number	[in]	Count	Count value	SysInvalidSetpoint	The setpoint number specified by SP is less than 1 or greater than the maximum number of setpoints	SysInvalidRequest	The specified setpoint is not a DINCNT setpoint	SysOK	The function completed successfully				
[in]	SP	Setpoint number															
[in]	Count	Count value															
SysInvalidSetpoint	The setpoint number specified by SP is less than 1 or greater than the maximum number of setpoints																
SysInvalidRequest	The specified setpoint is not a DINCNT setpoint																
SysOK	The function completed successfully																
SetSPDuration 920i 820i 1280	<p>For time of day (TOD) setpoints, sets the trip duration (DURATION parameter) of setpoint SP to the value specified by DT</p> <p>Method Signature: function SetSPDuration (SP : Integer; DT : DateTime) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[in]</td> <td>DT</td> <td>Setpoint trip duration</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no DURATION parameter</td> </tr> <tr> <td>SysBatchRunning</td> <td>The value cannot be changed because a batch process is currently running</td> </tr> <tr> <td>SysOutOfRange</td> <td>The value specified for DT is not in the allowed range for setpoint SP</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP3DUR : DateTime; ... SP3DUR := 00:3:15 SetSPDuration (3, SP3DUR);</p>	[in]	SP	Setpoint number	[in]	DT	Setpoint trip duration	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no DURATION parameter	SysBatchRunning	The value cannot be changed because a batch process is currently running	SysOutOfRange	The value specified for DT is not in the allowed range for setpoint SP	SysOK	The function completed successfully
[in]	SP	Setpoint number															
[in]	DT	Setpoint trip duration															
SysInvalidSetpoint	The setpoint specified by SP does not exist																
SysInvalidRequest	The setpoint specified by SP has no DURATION parameter																
SysBatchRunning	The value cannot be changed because a batch process is currently running																
SysOutOfRange	The value specified for DT is not in the allowed range for setpoint SP																
SysOK	The function completed successfully																

Table 5-14. Setpoint and Batching Commands (Continued)

Command	Description																
SetSPHyster 920i 820i 880 1280	<p>Sets the hysteresis value (HYSTER parameter) of setpoint SP to the value specified by V</p> <p>Method Signature: function SetSPHyster (SP : Integer; V : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[in]</td> <td>V</td> <td>Hysteresis value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no hysteresis (HYSTER) parameter</td> </tr> <tr> <td>SysBatchRunning</td> <td>The value cannot be changed because a batch process is currently running</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP5Hyster : Real; ... SP5Hyster := 15.0; SetSPHyster (5, SP5Hyster);</p>	[in]	SP	Setpoint number	[in]	V	Hysteresis value	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no hysteresis (HYSTER) parameter	SysBatchRunning	The value cannot be changed because a batch process is currently running	SysOK	The function completed successfully		
[in]	SP	Setpoint number															
[in]	V	Hysteresis value															
SysInvalidSetpoint	The setpoint specified by SP does not exist																
SysInvalidRequest	The setpoint specified by SP has no hysteresis (HYSTER) parameter																
SysBatchRunning	The value cannot be changed because a batch process is currently running																
SysOK	The function completed successfully																
SetSPNSample 920i 820i	<p>For averaging (AVG) setpoints, sets the number of samples (NSAMPLE parameter) of setpoint SP to the value specified by N</p> <p>Method Signature: function SetSPNSample (SP : Integer; N : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[in]</td> <td>N</td> <td>Sample value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist.</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no NSAMPLE parameter.</td> </tr> <tr> <td>SysBatchRunning</td> <td>The value cannot be changed because a batch process is currently running.</td> </tr> <tr> <td>SysOutOfRange</td> <td>The value specified for N is not in the allowed range for setpoint SP.</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully.</td> </tr> </table> <p><i>Example:</i> SP5NS : Integer; ... SP5NS := 10 SetSPNSample (5, SP5NS);</p>	[in]	SP	Setpoint number	[in]	N	Sample value	SysInvalidSetpoint	The setpoint specified by SP does not exist.	SysInvalidRequest	The setpoint specified by SP has no NSAMPLE parameter.	SysBatchRunning	The value cannot be changed because a batch process is currently running.	SysOutOfRange	The value specified for N is not in the allowed range for setpoint SP .	SysOK	The function completed successfully.
[in]	SP	Setpoint number															
[in]	N	Sample value															
SysInvalidSetpoint	The setpoint specified by SP does not exist.																
SysInvalidRequest	The setpoint specified by SP has no NSAMPLE parameter.																
SysBatchRunning	The value cannot be changed because a batch process is currently running.																
SysOutOfRange	The value specified for N is not in the allowed range for setpoint SP .																
SysOK	The function completed successfully.																
SetSPPreact 920i 820i 880 882D 1280	<p>Sets the preact value (PRACT parameter) of setpoint SP to the value specified by V</p> <p>Method Signature: function SetSPPreact (SP : Integer; V : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[in]</td> <td>V</td> <td>Preact value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no preact (PRACT) parameter</td> </tr> <tr> <td>SysBatchRunning</td> <td>The value cannot be changed because a batch process is currently running</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP2PreVal : Real; ... SP2PreVal := 30.0; SetSPPreact (2, SP2PreVal);</p>	[in]	SP	Setpoint number	[in]	V	Preact value	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no preact (PRACT) parameter	SysBatchRunning	The value cannot be changed because a batch process is currently running	SysOK	The function completed successfully		
[in]	SP	Setpoint number															
[in]	V	Preact value															
SysInvalidSetpoint	The setpoint specified by SP does not exist																
SysInvalidRequest	The setpoint specified by SP has no preact (PRACT) parameter																
SysBatchRunning	The value cannot be changed because a batch process is currently running																
SysOK	The function completed successfully																

Table 5-14. Setpoint and Batching Commands (Continued)

Command	Description																
SetSPPreCount 920i 820i 880 1280	<p>Sets the preact count value (PCOUNT parameter) of setpoint SP to the value specified by Count</p> <p>Method Signature: function SetSPPreCount (SP : Integer; Count : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[in]</td> <td>Count</td> <td>Preact count value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP is not type DINCNT or Count is less than 0</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP3PCount : Integer; ... SP3Pcount := 4; SetSPPreCount (3, SP3PCount);</p>	[in]	SP	Setpoint number	[in]	Count	Preact count value	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP is not type DINCNT or Count is less than 0	SysOK	The function completed successfully				
[in]	SP	Setpoint number															
[in]	Count	Preact count value															
SysInvalidSetpoint	The setpoint specified by SP does not exist																
SysInvalidRequest	The setpoint specified by SP is not type DINCNT or Count is less than 0																
SysOK	The function completed successfully																
SetSPTIME 920i 820i	<p>For time of day (TOD) setpoints, sets the trip time (TIME parameter) of setpoint SP to the value specified by DT</p> <p>Method Signature: function SetSPTIME (SP : Integer; DT : DateTime) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[in]</td> <td>DT</td> <td>Setpoint trip time</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no TIME parameter</td> </tr> <tr> <td>SysBatchRunning</td> <td>The value cannot be changed because a batch process is currently running</td> </tr> <tr> <td>SysOutOfRange</td> <td>The value specified for DT is not in the allowed range for setpoint SP</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP2TIME : DateTime; ... SP2TIME := 08:15:00 SetSPTIME (2, SP2TIME);</p>	[in]	SP	Setpoint number	[in]	DT	Setpoint trip time	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no TIME parameter	SysBatchRunning	The value cannot be changed because a batch process is currently running	SysOutOfRange	The value specified for DT is not in the allowed range for setpoint SP	SysOK	The function completed successfully
[in]	SP	Setpoint number															
[in]	DT	Setpoint trip time															
SysInvalidSetpoint	The setpoint specified by SP does not exist																
SysInvalidRequest	The setpoint specified by SP has no TIME parameter																
SysBatchRunning	The value cannot be changed because a batch process is currently running																
SysOutOfRange	The value specified for DT is not in the allowed range for setpoint SP																
SysOK	The function completed successfully																
SetSPTIME 1280	<p>For time of day (TOD) setpoints, sets the trip time (TIME parameter) of setpoint SP to the value specified by DT</p> <p>Method Signature: function SetSPTIME (SP : Integer; DT : DateTime) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[in]</td> <td>DT</td> <td>Setpoint trip time</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no TIME parameter</td> </tr> <tr> <td>SysBatchRunning</td> <td>The value cannot be changed because a batch process is currently running</td> </tr> <tr> <td>SysOutOfRange</td> <td>The value specified for DT is not in the allowed range for setpoint SP</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP2TIME : DateTime; ... SetTime (SP2Time, 08, 15, 00); SetSPTIME (2, SP2Time);</p>	[in]	SP	Setpoint number	[in]	DT	Setpoint trip time	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no TIME parameter	SysBatchRunning	The value cannot be changed because a batch process is currently running	SysOutOfRange	The value specified for DT is not in the allowed range for setpoint SP	SysOK	The function completed successfully
[in]	SP	Setpoint number															
[in]	DT	Setpoint trip time															
SysInvalidSetpoint	The setpoint specified by SP does not exist																
SysInvalidRequest	The setpoint specified by SP has no TIME parameter																
SysBatchRunning	The value cannot be changed because a batch process is currently running																
SysOutOfRange	The value specified for DT is not in the allowed range for setpoint SP																
SysOK	The function completed successfully																

Table 5-14. Setpoint and Batching Commands (Continued)

Command	Description																
SetSPValue 920i 820i 880 882D 1280	<p>Sets the value (VALUE parameter) of setpoint SP to the value specified by V</p> <p>Method Signature: function SetSPValue (SP : Integer; V : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[in]</td> <td>V</td> <td>Setpoint value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no VALUE parameter</td> </tr> <tr> <td>SysBatchRunning</td> <td>The value cannot be changed because a batch process is currently running</td> </tr> <tr> <td>SysOutOfRange</td> <td>The value specified for V is not in the allowed range for setpoint SP</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP4Val : Real; ... SP4Val := 350.0; SetSPValue (4, SP4Val);</p>	[in]	SP	Setpoint number	[in]	V	Setpoint value	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no VALUE parameter	SysBatchRunning	The value cannot be changed because a batch process is currently running	SysOutOfRange	The value specified for V is not in the allowed range for setpoint SP	SysOK	The function completed successfully
[in]	SP	Setpoint number															
[in]	V	Setpoint value															
SysInvalidSetpoint	The setpoint specified by SP does not exist																
SysInvalidRequest	The setpoint specified by SP has no VALUE parameter																
SysBatchRunning	The value cannot be changed because a batch process is currently running																
SysOutOfRange	The value specified for V is not in the allowed range for setpoint SP																
SysOK	The function completed successfully																
SetSPVover 920i 820i	<p>For checkweigh (CHKWEI) setpoints, sets the overrange value (VOVER parameter) of setpoint SP to the value specified by V</p> <p>Method Signature: function SetSPVover (SP : Integer; V : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[in]</td> <td>V</td> <td>Overrange value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no VOVER parameter</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP3VOR : Real; ... SP3VOR := 35.5 SetSPVover (3, SP3VOR);</p>	[in]	SP	Setpoint number	[in]	V	Overrange value	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no VOVER parameter	SysOK	The function completed successfully				
[in]	SP	Setpoint number															
[in]	V	Overrange value															
SysInvalidSetpoint	The setpoint specified by SP does not exist																
SysInvalidRequest	The setpoint specified by SP has no VOVER parameter																
SysOK	The function completed successfully																
SetSPVunder 920i 820i	<p>For checkweigh (CHKWEI) setpoints, sets the underrange value (VUNDER parameter) of setpoint SP to the value specified by V</p> <p>Method Signature: function SetSPVunder (SP : Integer; V : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>SP</td> <td>Setpoint number</td> </tr> <tr> <td>[in]</td> <td>V</td> <td>Underrange</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidSetpoint</td> <td>The setpoint specified by SP does not exist</td> </tr> <tr> <td>SysInvalidRequest</td> <td>The setpoint specified by SP has no VUNDER parameter</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> SP4VUR : Real; ... SP4VUR := 26.4 SetSPVunder (4, SP4VUR);</p>	[in]	SP	Setpoint number	[in]	V	Underrange	SysInvalidSetpoint	The setpoint specified by SP does not exist	SysInvalidRequest	The setpoint specified by SP has no VUNDER parameter	SysOK	The function completed successfully				
[in]	SP	Setpoint number															
[in]	V	Underrange															
SysInvalidSetpoint	The setpoint specified by SP does not exist																
SysInvalidRequest	The setpoint specified by SP has no VUNDER parameter																
SysOK	The function completed successfully																
StartBatch 920i 820i 880 882D 1280	<p>Starts or resumes a batch run</p> <p>Method Signature: function StartBatch : SysCode;</p> <p>SysCode values returned:</p> <table> <tr> <td>SysPermissionDenied</td> <td>The BATCHNG configuration parameter is set to OFF</td> </tr> <tr> <td>SysBatchRunning</td> <td>A batch process is already in progress</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	SysPermissionDenied	The BATCHNG configuration parameter is set to OFF	SysBatchRunning	A batch process is already in progress	SysOK	The function completed successfully										
SysPermissionDenied	The BATCHNG configuration parameter is set to OFF																
SysBatchRunning	A batch process is already in progress																
SysOK	The function completed successfully																

Table 5-14. Setpoint and Batching Commands (Continued)

Command	Description
StopBatch 920i 820i 880 882D 1280	Stops a currently running batch Method Signature: function StopBatch : SysCode; SysCode values returned: SysPermissionDenied The BATCHNG configuration parameter is set to OFF SysBatchNotRunning No batch process is running SysOK The function completed successfully

Table 5-14. Setpoint and Batching Commands (Continued)

5.6 Digital I/O Control

In the following digital I/O control functions, slot 0 represents the digital I/O available on the CPU board of the indicator. The 920i supports six onboard bits, the 880 and 882D both support four, and the 820i and 1280 both support eight. Digital I/O on expansion boards each support 24-bits.

Command	Description
GetDigAll 1280	Sets V to the bitmasked value of all inputs/outputs in slot S ; See SetAllDigOut on page 78 for explanation of bitmasked integer Method Signature: function GetDigAll (S : Integer; VAR V : Integer) : SysCode; Parameters: [in] S Slot number [out] V Digital IO status SysCode Values Returned: SysInvalidRequest The slot does not contain a valid DIO Card SysOK SysOK The function completed successfully <i>Example:</i> dioStatus : integer; GetDigAll(0, dioStatus);
GetDigin 920i 820i 880 882D 1280	Sets V to the value of the digital input assigned to slot S , bit D ; GetDigin sets the value of V to 0 if the input is on, to 1 if the input is off. Note that the values returned are the reverse of those used when setting an output with the SetDigout function; GetDigin can monitor any digital I/O point that is not configured as OFF or OUTPUT Method Signature: function GetDigin (S : Integer; D : Integer; VAR V : Integer) : SysCode; Parameters: [in] S Slot number [in] D Bit number [out] V Digital input status SysCode values returned: SysInvalidRequest The slot and bit assignment specified is not a valid digital input SysOK SysOK The function completed successfully <i>Example:</i> DIGINS0B3 : Integer; ... GetDigin (0, 3, DIGINS0B3); WriteLn (1, "Digin S0B3 status is " + IntegerToString(DIGINS0B3,0));

Table 5-15. Digital I/O Control Commands

Command	Description															
GetDigout 920i 820i 880 882D 1280	<p>Sets V to the value of the digital output assigned to slot S, bit D; GetDigout sets the value of V to 0 if the output is off, to 1 if the output is on</p> <p>Method Signature: function GetDigout (S : Integer; D : Integer; VAR V : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Slot number</td> </tr> <tr> <td>[in]</td> <td>D</td> <td>Bit number</td> </tr> <tr> <td>[out]</td> <td>V</td> <td>Digital output status</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidRequest</td> <td>The slot and bit assignment specified is not a valid digital output</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> DIGOUTS0B2 : Integer; ... GetDigout (0, 2, DIGOUTS0B2); WriteLn (1, "Digout S0B2 status is " + IntegerToString(DIGOUTS0B2,0));</p>	[in]	S	Slot number	[in]	D	Bit number	[out]	V	Digital output status	SysInvalidRequest	The slot and bit assignment specified is not a valid digital output	SysOK	The function completed successfully		
[in]	S	Slot number														
[in]	D	Bit number														
[out]	V	Digital output status														
SysInvalidRequest	The slot and bit assignment specified is not a valid digital output															
SysOK	The function completed successfully															
SetAllDigOutOff 1280	<p>Sets all digital outputs on <i>slotNum</i> to off</p> <p>Method Signature function SetAllDigOutOff (S : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Slot number</td> </tr> </table> <p>SysCodes returned</p> <table> <tr> <td>SysInvalidRequest</td> <td>The slot and bit assignment specified is not a valid digital output</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	[in]	S	Slot number	SysInvalidRequest	The slot and bit assignment specified is not a valid digital output	SysOK	The function completed successfully								
[in]	S	Slot number														
SysInvalidRequest	The slot and bit assignment specified is not a valid digital output															
SysOK	The function completed successfully															
SetDigout 920i 820i 880 882D 1280	<p>Sets value of the digital output assigned to slot S, bit D, to the value specified by V; det V to 1 to turn the specified output on; set V to 0 to turn the output off</p> <p>Method Signature: function SetDigout (S : Integer; D : Integer; V : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Slot number</td> </tr> <tr> <td>[in]</td> <td>D</td> <td>Bit number</td> </tr> <tr> <td>[in]</td> <td>V</td> <td>Digital output status</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidRequest</td> <td>The slot and bit assignment specified is not a valid digital output</td> </tr> <tr> <td>SysOutOfRange</td> <td>The value V must be 0 (inactive) or 1 (active)</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> DIGOUTS0B2 : Integer; ... DIGOUTS0B2 := 0; SetDigout (0, 2, DIGOUTS0B2);</p>	[in]	S	Slot number	[in]	D	Bit number	[in]	V	Digital output status	SysInvalidRequest	The slot and bit assignment specified is not a valid digital output	SysOutOfRange	The value V must be 0 (inactive) or 1 (active)	SysOK	The function completed successfully
[in]	S	Slot number														
[in]	D	Bit number														
[in]	V	Digital output status														
SysInvalidRequest	The slot and bit assignment specified is not a valid digital output															
SysOutOfRange	The value V must be 0 (inactive) or 1 (active)															
SysOK	The function completed successfully															

Table 5-15. Digital I/O Control Commands (Continued)

Command	Description										
SetAllDigOut 1280	<p>Allows the application to set the state of a bank/card of outputs with a single function call vs. a series of individual calls.</p> <p>Method Signature: function SetAllDigOut (S : Integer, I : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Slot number that the DIO card is in</td> </tr> <tr> <td>[in]</td> <td>I</td> <td>Bitmasked integer for all outputs (see bitmask explanation below)</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidRequest</td> <td>The slot and bit assignment specified is not a valid digital output</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>For example:</i> SetAllDigOut command sets the input/output states of the DIO card using a bitmasked decimal number converted from a binary number. The binary number represents output states of each output, read from right to left. A value of 1 sets the output to ON and a value of 0 sets the output to OFF. To convert a binary number to a bitmasked decimal, correlate each bit from right to left with a consecutive integer as follows:</p> <ul style="list-style-type: none"> • Bit 1 = $2^0 = 1$ • Bit 2 = $2^1 = 2$ • Bit 3 = $2^2 = 4$ • Bit 4 = $2^3 = 8$ • Bit 5 = $2^4 = 16$ <p>Continue consecutively up to 8 values (2^7) for onboard DIO and up to 24 values (2^{23}) for DIO cards. The bitmasked decimal integer is the sum of all of the integers that are set to ON or 1</p> <p>SetAllDigOut(3, 68) DIO card is in slot 3; bits 3 and 7 are ON $68 = (2^2 + 2^6)$ or $68 = 4 + 64$ Binary number is: 01000100 (read right to left)</p> <p>SetAllDigOut(0, 86) Onboard DIO; bits 2, 3, 5 and 7 are ON $86 = (2^1 + 2^2 + 2^4 + 2^6)$ or $86 = 2 + 4 + 16 + 64$ Binary number is: 01010110 (read right to left)</p>	[in]	S	Slot number that the DIO card is in	[in]	I	Bitmasked integer for all outputs (see bitmask explanation below)	SysInvalidRequest	The slot and bit assignment specified is not a valid digital output	SysOK	The function completed successfully
[in]	S	Slot number that the DIO card is in									
[in]	I	Bitmasked integer for all outputs (see bitmask explanation below)									
SysInvalidRequest	The slot and bit assignment specified is not a valid digital output										
SysOK	The function completed successfully										

Table 5-15. Digital I/O Control Commands (Continued)

5.7 Fieldbus Data

Methods	Description													
GetFBStatus 920i 1280	<p>Returns the status word for the specified fieldbus, see appropriate fieldbus addendum for a description of the status word format</p> <p>Method Signature: function GetFBStatus (fieldbus_no : Integer; scale_no : Integer; VAR status : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>fieldbus_no</td> <td>Fieldbus number</td> </tr> <tr> <td>[in]</td> <td>scale_no</td> <td>Scale number</td> </tr> <tr> <td>[out]</td> <td>status</td> <td>Fieldbus status</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidRequest</td> <td></td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	[in]	fieldbus_no	Fieldbus number	[in]	scale_no	Scale number	[out]	status	Fieldbus status	SysInvalidRequest		SysOK	The function completed successfully
[in]	fieldbus_no	Fieldbus number												
[in]	scale_no	Scale number												
[out]	status	Fieldbus status												
SysInvalidRequest														
SysOK	The function completed successfully													
GetImage 920i 1280	<p>For integer data, GetImage returns the content of the BusImage for the specified fieldbus</p> <p>Method Signature: function GetImage (fieldbus_no : Integer; VAR data : BusImage) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>fieldbus_no</td> <td>Fieldbus number</td> </tr> <tr> <td>[out]</td> <td>BusImage</td> <td>Bus image</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidRequest</td> <td></td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	[in]	fieldbus_no	Fieldbus number	[out]	BusImage	Bus image	SysInvalidRequest		SysOK	The function completed successfully			
[in]	fieldbus_no	Fieldbus number												
[out]	BusImage	Bus image												
SysInvalidRequest														
SysOK	The function completed successfully													

Table 5-16. Fieldbus Methods

Methods	Description
GetImageReal 920i 1280	For real data, GetImage returns the content of the BusImageReal for the specified fieldbus Method Signature: function GetImageReal (fieldbus_no : Integer; VAR data : BusImageReal) : SysCode; Parameters: [in] fieldbus_no Fieldbus number [out] BusImageReal Bus image SysCode values returned: SysInvalidRequest SysOK The function completed successfully
SetImage 920i 1280	For integer data, SetImage sets the content of the BusImage for the specified fieldbus Method Signature: function SetImage (fieldbus_no : Integer; data : BusImage) : SysCode; Parameters: [in] fieldbus_no Fieldbus number [in] BusImage Bus image SysCode values returned: SysInvalidRequest SysOK The function completed successfully
SetImageReal 920i 1280	For real data, SetImageReal sets the content of the BusImageReal for the specified fieldbus Method Signature: function SetImage (fieldbus_no : Integer; data : BusImageReal) : SysCode; Parameters: [in] fieldbus_no Fieldbus number [in] BusImageReal Bus image SysCode values returned: SysInvalidRequest SysOK The function completed successfully

Table 5-16. Fieldbus Methods (Continued)

5.8 Analog Output Operation

Methods	Description
SetAlgout 920i 820i 880 882D 1280	Sets the analog output card in slot S to the percentage P ; Negative P values are set to zero; Values greater than 100.0 are set to 100.0 Method Signature: function SetAlgout (S : Integer; P : Real) : SysCode; Parameters: [in] S Slot number [in] P Analog output percentage value SysCode values returned: SysInvalidPort The specified slot (S) is not a valid analog output SysInvalidRequest The analog output is not configured from program control SysOK The function completed successfully

Table 5-17. Analog Output Operation Methods

5.9 Email

Methods	Description
SendEmail 1280	<p>Sends email through configured email server using the to, from, subject and body specified in the API call.</p> <p>Method Signature: function SendEmail (TO : String; FROM : string; SUBJECT : string; BODY : string) : SysCode;</p> <p>Parameters: <Self Explanatory></p> <p>SysCode values returned:</p> <p>SysInvalidToAddress Supplied to address is not in the correct format; This does not check if the to address actually exists only if the format is correct</p> <p>SysInvalidFromAddress Supplied from address is not in the correct format; This does not check if the to address actually exists only if the format is correct</p> <p>SysInvalidSubject Supplied subject is not within length limits; Subject length must be greater than 0 and less than or equal to 128 characters</p> <p>SysInvalid NetworkConfig There is an issue with the email configuration in the 1280 setup; Possibilities include incorrect port, incorrect address, invalid username/password and connectivity issues</p>
SendEmailFormat 1280	<p>Sends email through configured email server using the to, from, subject and body specified in the API call. The print format is generated and then used as the body of the email.</p> <p>Method Signature: function SendEmailFormat (TO : String; FROM : string; SUBJECT : string; PF : PrintFormat) : SysCode;</p> <p>Parameters: <Self Explanatory></p> <p>SysCode values returned:</p> <p>SysInvalidToAddress Supplied to address is not in the correct format; This does not check if the to address actually exists only if the format is correct</p> <p>SysInvalidFromAddress Supplied from address is not in the correct format; This does not check if the to address actually exists only if the format is correct</p> <p>SysInvalidSubject Supplied subject is not within length limits; Subject length must be greater than 0 and less than or equal to 128 characters</p> <p>SysInvalid NetworkConfig There is an issue with the email configuration in the 1280 setup; Possibilities include incorrect port, incorrect address, invalid username/password and connectivity issues</p>

Table 5-18. Analog Output Operation Methods

5.10 Pulse Input Operation

Methods	Description
ClearPulseCount 920i 820i 882D 1280	<p>Sets the pulse count of the pulse input card in slot S to zero (see note below for 1280 and 882D)</p> <p>Method Signature: function ClearPulseCount (S : Integer) : SysCode;</p> <p>Parameters: [in] S Slot number</p> <p>SysCode values returned:</p> <p>SysInvalidCounter The specified counter (S) is not a valid pulse input</p> <p>SysOK The function completed successfully</p>
PulseCount 920i 820i 882D 1280	<p>Sets C to the current pulse count of the pulse input card in slot S (see note below for 1280 and 882D)</p> <p>Method Signature: function PulseCount (S : Integer; VAR C : Integer) : SysCode;</p> <p>Parameters: [in] S Slot number [out] C Current pulse count</p> <p>SysCode values returned:</p> <p>SysInvalidCounter The specified counter (S) is not a valid pulse input</p> <p>SysOK The function completed successfully</p>

Table 5-19. Pulse Input Operation Methods

Methods	Description
PulseRate 920i 820i 882D	Sets R to the current pulse rate (in pulses per second) of the pulse input card in slot S (see note below for 1280 and 882D) Method Signature: function PulseRate (S : Integer; VAR R : Integer) : SysCode; Parameters: [in] S Slot number [out] C Current pulse rate SysCode values returned: SysInvalidCounter The specified counter (S) is not a valid pulse input SysOK The function completed successfully

Table 5-19. Pulse Input Operation Methods (Continued)



NOTES: When using pulse functions on the 1280 and 882D that do not support a Pulse Input card:

1280 – Pulse support is available on the 8 onboard Digital IO when set to function “PulseIn”. Replace the Slot number above with the Bit number.

882D – Two pulse input channels are supported by onboard hardware. Replace the Slot number above with the Pulse Input number 1 or 2.

5.11 Display Operation

Methods	Description
ClosePrompt 920i 820i 880 882D 1280	Closes a prompt opened by the PromptUser, PromptNumeric or PromptPassword function Method Signature: procedure ClosePrompt;
DisplayStatus 920i 820i 880 882D 1280	Displays the string msg in the front panel status message area; The length of string msg should not exceed 32 characters NOTE: On the 880 indicator, the message will scroll across the available six digit display. Method Signature: procedure DisplayStatus (msg : String); Parameters: [in] msg Display text
GetEntry 920i 820i 880 882D 1280	Retrieves the user entry from a programmed prompt. Method Signature: function GetEntry : String;
PromptUser 920i 820i 880 882D 1280	Opens the alpha entry box and places the string msg in the user prompt area Method Signature: function PromptUser (msg : String) : SysCode; Parameters: [in] msg Prompt text SysCode values returned: SysRequestFailed The prompt could not be opened SysOK The function completed successfully
PromptPassword 1280	Brings up a password protected alpha user prompt Method Signature: function PromptPassword (msg : String) : SysCode; Parameters: [in] msg Prompt text SysCode values returned: SysRequestFailed The prompt could not be opened SysOK The function completed successfully

Table 5-20. Display Operation Methods

Methods	Description
PromptNumeric 1280	Brings up a numeric user prompt Method Signature: function PromptNumeric (msg : String) : SysCode; Parameters: [in] msg Prompt text SysCode values returned: SysRequestFailed The prompt could not be opened SysOK The function completed successfully
SelectScreen 920i 1280	Selects the configured screen, N, to show on the indicator display Method Signature: function SelectScreen (N : Integer) : SysCode; Parameters: [in] N Screen number SysCode values returned: SysInvalidRequest The value specified for N is less than 1 or greater than 10 (920i) or 99 (1280) SysOK The function completed successfully
SetEntry 920i 820i 880 882D 1280	Sets the user entry for a programmed prompt; This procedure can be used to provide a default value for entry box text when prompting the operator for input; Up to 1000 characters can be specified NOTE: For the 1280, call SetEntry before opening the prompt with PromptUser. Method Signature: procedure SetEntry (S : String);
UpdateEntry	If using an external keyboard, this API is required to update data typed in on the keyboard; Works in conjunction with PortCharReceived or equivalent handler Method Signature: procedure UpdateEntry (userInput : string); Parameters: [in] userInput string value collected from external keyboard to update the data entry box in a prompt

Table 5-20. Display Operation Methods (Continued)

5.12 Display Programming

Methods	Description
BusyShow 1280	Shows the busy circle icon on screen, dimming the rest of the screen and disabling all touch functionality Method Signature: function BusyShow : SysCode; SysCode values returned: SysOK The function completed successfully
BusyHide 1280	Hides the busy circle icon on screen, restores the brightness and enables all touch functionality Method Signature: function BusyHide : SysCode; SysCode values returned: SysOK The function completed successfully
CaptureImageFromVivotekIP7361 1280	Automatically appends a .jpg to the filename; Image is stored to the microSD card in the 1280 in the "sdimages" folder; This API only works with the Vivotek IP7361 camera Method Signature: function CaptureImageFromVivotekIP7361 (source : String, filepath : String) : SysCode Parameters: [in] source IP address in quotes ("192.168.10.2") [in] filepath name of the file without an extension ("TruckPic") SysCode values returned: SysOK The function completed successfully

Table 5-21. Display Programming Methods

Methods	Description																			
ClearGraph 920i	<p>Clears a graph by setting all elements of a DisplayImage array to zero</p> <p>Method Signature: procedure ClearGraph (VAR graph_array : DisplayImage) : SysCode;</p> <p>Parameters: [out] graph_array Graph identifier</p>																			
DrawGraphic 920i	<p>Displays or erases a graphic defined in the bitmap.iri file incorporated into the user program source (.src) file, see Section 6.6 on page 121 for more information about display programming</p> <p>Method Signature: function DrawGraphic (gr_num : Integer; x_start : Integer; y_start : Integer; bitmap : DisplayImage; color : Color_type) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>gr_num</td> <td>Graphic number</td> </tr> <tr> <td>[in]</td> <td>x_start</td> <td>X-axis starting pixel location</td> </tr> <tr> <td>[in]</td> <td>y_start</td> <td>Y-axis starting pixel location</td> </tr> <tr> <td>[in]</td> <td>bitmap</td> <td>Graphic bitmap</td> </tr> <tr> <td>[in]</td> <td>color</td> <td>Color type</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysDeviceError</td> <td>The value specified for gr_num is greater than 100</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	[in]	gr_num	Graphic number	[in]	x_start	X-axis starting pixel location	[in]	y_start	Y-axis starting pixel location	[in]	bitmap	Graphic bitmap	[in]	color	Color type	SysDeviceError	The value specified for gr_num is greater than 100	SysOK	The function completed successfully
[in]	gr_num	Graphic number																		
[in]	x_start	X-axis starting pixel location																		
[in]	y_start	Y-axis starting pixel location																		
[in]	bitmap	Graphic bitmap																		
[in]	color	Color type																		
SysDeviceError	The value specified for gr_num is greater than 100																			
SysOK	The function completed successfully																			
GraphCreate 920i	<p>Assigns storage and defines the graph display type for use by other graphing functions</p> <p>Method Signature: function GraphCreate (graphic_no : Integer; bitmap : DisplayImage; color : Color_type; kind : GraphType) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>graphic_no</td> <td>Graphic number</td> </tr> <tr> <td>[in]</td> <td>bitmap</td> <td>Bitmap</td> </tr> <tr> <td>[in]</td> <td>color</td> <td>Graphic color</td> </tr> <tr> <td>[in]</td> <td>kind</td> <td>Graphic kind</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidRequest</td> <td>The DisplayImage specified by bitmap does not exist</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i></p> <pre>G_Graph1 : DisplayImage; result : Syscode; begin result := GraphCreate(1, G_Graph1, Black, Bar); if result = SysOK then result :=GraphInit(71,30,60,110,240); end if; end;</pre>	[in]	graphic_no	Graphic number	[in]	bitmap	Bitmap	[in]	color	Graphic color	[in]	kind	Graphic kind	SysInvalidRequest	The DisplayImage specified by bitmap does not exist	SysOK	The function completed successfully			
[in]	graphic_no	Graphic number																		
[in]	bitmap	Bitmap																		
[in]	color	Graphic color																		
[in]	kind	Graphic kind																		
SysInvalidRequest	The DisplayImage specified by bitmap does not exist																			
SysOK	The function completed successfully																			

Table 5-21. Display Programming Methods (Continued)

Methods	Description																							
GraphInit 920i	<p>Sets the location of the graph on the display; x_start and y_start values specify the distance, in pixels, from top left corner of the display at which the top left corner of the graph is shown; Height and width specify the graph size, in pixels (full display size is 240 pixels high by 320 pixels wide)</p> <p>Method Signature: function GraphInit (graphic_no : Integer; x_start : Integer; y_start : Integer; height : Integer; width : Integer) : SysCode;</p> <p>Parameters:</p> <table border="0"> <tr> <td>[in]</td> <td>graphic_no</td> <td>Graphic number</td> </tr> <tr> <td>[in]</td> <td>x_start</td> <td>X-axis starting pixel location</td> </tr> <tr> <td>[in]</td> <td>y_start</td> <td>Y-axis starting pixel location</td> </tr> <tr> <td>[in]</td> <td>height</td> <td>Graphic height</td> </tr> <tr> <td>[in]</td> <td>width</td> <td>Graphic width</td> </tr> </table> <p>SysCode values returned:</p> <table border="0"> <tr> <td>SysInvalidRequest</td> <td>The DisplayImage specified by bitmap does not exist</td> </tr> <tr> <td>SysOutOfRange</td> <td>Specified parameters exceed display height or width, or are too small to accommodate the graphic</td> </tr> <tr> <td>SysDeviceError</td> <td>Internal error</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> G_Graph1 : DisplayImage; result : Syscode; begin result := GraphCreate(1, G_Graph1, Black, Bar); if result = SysOK then result := GraphInit(71,30,60,110,240); end if; end;</p>	[in]	graphic_no	Graphic number	[in]	x_start	X-axis starting pixel location	[in]	y_start	Y-axis starting pixel location	[in]	height	Graphic height	[in]	width	Graphic width	SysInvalidRequest	The DisplayImage specified by bitmap does not exist	SysOutOfRange	Specified parameters exceed display height or width, or are too small to accommodate the graphic	SysDeviceError	Internal error	SysOK	The function completed successfully
[in]	graphic_no	Graphic number																						
[in]	x_start	X-axis starting pixel location																						
[in]	y_start	Y-axis starting pixel location																						
[in]	height	Graphic height																						
[in]	width	Graphic width																						
SysInvalidRequest	The DisplayImage specified by bitmap does not exist																							
SysOutOfRange	Specified parameters exceed display height or width, or are too small to accommodate the graphic																							
SysDeviceError	Internal error																							
SysOK	The function completed successfully																							
GraphPlot 920i	<p>Plots the graph previously set up using the GraphCreate, GraphInit, and GraphScale functions; The graph appears as a histogram: each GraphPlot call places a bar or line at the right edge of the graph, moving values from previous calls to the left; The width of the bar, in pixels, is specified by width parameter; The maximum width value is 8; Larger values are reduced to 8; If the y_value is beyond the bounds set by GraphScale, the bar is plotted to the maximum or minimum value</p> <p>Method Signature: function GraphPlot (graphic_no : Integer; y_value : Real; width : Integer; color : Color_type) : SysCode;</p> <p>Parameters:</p> <table border="0"> <tr> <td>[in]</td> <td>graphic_no</td> <td>Graphic number</td> </tr> <tr> <td>[in]</td> <td>y_value</td> <td>Pixel height of histogram</td> </tr> <tr> <td>[in]</td> <td>color</td> <td>Color type</td> </tr> <tr> <td>[in]</td> <td>width</td> <td>Pixel width of moving bar</td> </tr> </table> <p>SysCode values returned:</p> <table border="0"> <tr> <td>SysInvalidRequest</td> <td>Graph not initialized</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> result : Syscode; weight : real; begin GetGross(1,Primary,weight); result := GraphPlot(1, weight, 1, Black); end;</p>	[in]	graphic_no	Graphic number	[in]	y_value	Pixel height of histogram	[in]	color	Color type	[in]	width	Pixel width of moving bar	SysInvalidRequest	Graph not initialized	SysOK	The function completed successfully							
[in]	graphic_no	Graphic number																						
[in]	y_value	Pixel height of histogram																						
[in]	color	Color type																						
[in]	width	Pixel width of moving bar																						
SysInvalidRequest	Graph not initialized																							
SysOK	The function completed successfully																							

Table 5-21. Display Programming Methods (Continued)

Methods	Description																					
GraphScale 920i	<p>Sets the minimum and maximum x and y values for a graph; Currently, only the y values are used for the histogram displays; x values are reserved for future use, but must be present in the call</p> <p>Method Signature: function GraphScale (graphic_no : Integer; x_min : Real; x_max : Real; y_min : Real; y_max : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>graphic_no</td> <td>Graphic number</td> </tr> <tr> <td>[in]</td> <td>x_min</td> <td>Minimum x-axis value</td> </tr> <tr> <td>[in]</td> <td>x_max</td> <td>Maximum x-axis value</td> </tr> <tr> <td>[in]</td> <td>y_min</td> <td>Minimum y-axis value</td> </tr> <tr> <td>[in]</td> <td>y_max</td> <td>Maximum y-axis value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidRequest</td> <td>Graph not initialized</td> </tr> <tr> <td>SysOutOfRange</td> <td>A min value (x_min or y_min) is greater than its specified max value</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i> GraphScale(1, 10.0, 50000.0, 0.0, 10000.0);</p>	[in]	graphic_no	Graphic number	[in]	x_min	Minimum x-axis value	[in]	x_max	Maximum x-axis value	[in]	y_min	Minimum y-axis value	[in]	y_max	Maximum y-axis value	SysInvalidRequest	Graph not initialized	SysOutOfRange	A min value (x_min or y_min) is greater than its specified max value	SysOK	The function completed successfully
[in]	graphic_no	Graphic number																				
[in]	x_min	Minimum x-axis value																				
[in]	x_max	Maximum x-axis value																				
[in]	y_min	Minimum y-axis value																				
[in]	y_max	Maximum y-axis value																				
SysInvalidRequest	Graph not initialized																					
SysOutOfRange	A min value (x_min or y_min) is greater than its specified max value																					
SysOK	The function completed successfully																					
SetBargraphLevel 920i 1280	<p>Sets the displayed level of bar-graph widget W to the percentage (0–100%) specified by Level</p> <p>Method Signature: function SetBargraphLevel (W : Integer; Level : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>W</td> <td>Bargraph widget number</td> </tr> <tr> <td>[in]</td> <td>Level</td> <td>Bargraph widget level</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidWidget</td> <td>The bargraph widget specified by W does not exist</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	[in]	W	Bargraph widget number	[in]	Level	Bargraph widget level	SysInvalidWidget	The bargraph widget specified by W does not exist	SysOK	The function completed successfully											
[in]	W	Bargraph widget number																				
[in]	Level	Bargraph widget level																				
SysInvalidWidget	The bargraph widget specified by W does not exist																					
SysOK	The function completed successfully																					
SetLabelText 920i 882D 1280	<p>Sets the text of label widget W to S</p> <p>Method Signature: function SetLabelText (W : Integer; S : String) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>W</td> <td>Label widget number</td> </tr> <tr> <td>[in]</td> <td>S</td> <td>Label widget text</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidWidget</td> <td>The label widget specified by W does not exist</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p>NOTE: For the 882D only, this API is used to display a string (S) in one of the three text lines on the display. Specify 1, 2 or 3 for the widget (W). Only the first 20 characters of the string will be displayed.</p>	[in]	W	Label widget number	[in]	S	Label widget text	SysInvalidWidget	The label widget specified by W does not exist	SysOK	The function completed successfully											
[in]	W	Label widget number																				
[in]	S	Label widget text																				
SysInvalidWidget	The label widget specified by W does not exist																					
SysOK	The function completed successfully																					
SetNumericValue 920i	<p>Sets the value of numeric widget W to V</p> <p>Method Signature: function SetNumericValue (W : Integer; V : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>W</td> <td>Numeric widget number</td> </tr> <tr> <td>[in]</td> <td>V</td> <td>Numeric widget value</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidWidget</td> <td>The numeric widget specified by W does not exist</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	[in]	W	Numeric widget number	[in]	V	Numeric widget value	SysInvalidWidget	The numeric widget specified by W does not exist	SysOK	The function completed successfully											
[in]	W	Numeric widget number																				
[in]	V	Numeric widget value																				
SysInvalidWidget	The numeric widget specified by W does not exist																					
SysOK	The function completed successfully																					

Table 5-21. Display Programming Methods (Continued)

Methods	Description												
SetSymbolState 920i 1280	<p>Sets the state of symbol widget W to S; The widget state determines the variant of the widget symbol displayed; All widgets have at least two states (values 1 and 2); Some have three (3), see the 1280 Technical Manual (PN 167659) and the 920i Technical Manual (PN 67887) for descriptions of the symbol widget states</p> <p>Method Signature: function SetSymbolState (W : Integer; S : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>W</td> <td>Symbol widget number</td> </tr> <tr> <td>[in]</td> <td>S</td> <td>Symbol widget state</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidWidget</td> <td>The symbol widget specified by W does not exist</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	[in]	W	Symbol widget number	[in]	S	Symbol widget state	SysInvalidWidget	The symbol widget specified by W does not exist	SysOK	The function completed successfully		
[in]	W	Symbol widget number											
[in]	S	Symbol widget state											
SysInvalidWidget	The symbol widget specified by W does not exist												
SysOK	The function completed successfully												
SetWidget Visibility 920i 1280	<p>Sets the visibility state of widget W to V</p> <p>Method Signature: function SetWidgetVisibility (W : Integer; V : OnOffType) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>W</td> <td>Widget number</td> </tr> <tr> <td>[in]</td> <td>V</td> <td>Widget visibility</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidWidget</td> <td>The widget specified by W does not exist</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	[in]	W	Widget number	[in]	V	Widget visibility	SysInvalidWidget	The widget specified by W does not exist	SysOK	The function completed successfully		
[in]	W	Widget number											
[in]	V	Widget visibility											
SysInvalidWidget	The widget specified by W does not exist												
SysOK	The function completed successfully												
SetWidgetColor 1280	<p>Sets the color of widget W to C, a set widget color uses HTML RGB style (Section 5.12.1 on page 88)</p> <p>Method Signature: function SetWidgetColor (W : Integer; C : String) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>W</td> <td>Widget number</td> </tr> <tr> <td>[in]</td> <td>C</td> <td>Widget color</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidWidget</td> <td>Requested widget could not be found</td> </tr> <tr> <td>SysInvalidRequest</td> <td>No string provided for color parameter</td> </tr> <tr> <td>SysOk</td> <td>The function completed successfully</td> </tr> </table>	[in]	W	Widget number	[in]	C	Widget color	SysInvalidWidget	Requested widget could not be found	SysInvalidRequest	No string provided for color parameter	SysOk	The function completed successfully
[in]	W	Widget number											
[in]	C	Widget color											
SysInvalidWidget	Requested widget could not be found												
SysInvalidRequest	No string provided for color parameter												
SysOk	The function completed successfully												
SetSymbolColor 1280	<p>Sets the color of symbol widget W to C; Color integer range is 1–16 (Table 5-22 on page 88)</p> <p>Method Signature: function SetSymbolColor (W : Integer; C : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>W</td> <td>Widget number</td> </tr> <tr> <td>[in]</td> <td>C</td> <td>Symbol color, supports 16 colors (VGA)</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidWidget</td> <td>Requested widget could not be found</td> </tr> <tr> <td>SysInvalidRequest</td> <td>Invalid color</td> </tr> <tr> <td>SysOk</td> <td>The function completed successfully</td> </tr> </table>	[in]	W	Widget number	[in]	C	Symbol color, supports 16 colors (VGA)	SysInvalidWidget	Requested widget could not be found	SysInvalidRequest	Invalid color	SysOk	The function completed successfully
[in]	W	Widget number											
[in]	C	Symbol color, supports 16 colors (VGA)											
SysInvalidWidget	Requested widget could not be found												
SysInvalidRequest	Invalid color												
SysOk	The function completed successfully												
SetImageWidgetPath 1280	<p>Displays image widget as a BMP or PNG file; File is accessed from:</p> <ul style="list-style-type: none"> • A micro SD card, stored in a folder called sdimage • An HTTP or HTTPS link. <p>There are also a set of stock images on the 1280 firmware that can be accessed using the command "local://" followed by the desired file name; The file index can be found in the 1280 Technical Manual (PN 167659) in the Firmware Images section, see Section 5.12.2 on page 89 for image widgets</p> <p>Method Signature: function SetImageWidgetPath (W : Integer; C : String) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>W</td> <td>Widget image</td> </tr> <tr> <td>[in]</td> <td>C</td> <td>Image path</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidWidget</td> <td>Requested widget could not be found</td> </tr> <tr> <td>SysOk</td> <td>The function completed successfully</td> </tr> </table>	[in]	W	Widget image	[in]	C	Image path	SysInvalidWidget	Requested widget could not be found	SysOk	The function completed successfully		
[in]	W	Widget image											
[in]	C	Image path											
SysInvalidWidget	Requested widget could not be found												
SysOk	The function completed successfully												

Table 5-21. Display Programming Methods (Continued)

Methods	Description
SetMenuBarColor 1280	<p>Sets the color of the menu bar</p> <p>Method Signature: function SetMenuBarColor (C : String) : SysCode;</p> <p>Parameters: [in] C Color type, uses HTML RGB style</p> <p>SysCode values returned: SysInvalidRequest Invalid type SysOk The function completed successfully</p>
SetBGColor 1280	<p>Sets the background color</p> <p>Method Signature: function SetBGColor (C : string; T : string) : SysCode;</p> <p>Parameters: [in] T Text color [in] C Background color - name or HTML RGB Style</p> <p>SysCode values returned: SysInvalidRequest Invalid type SysOk The function completed successfully</p>
SetScaleSymbols 1280	<p>Sets the scale's symbols</p> <p>Method Signature: function SetScaleSymbols (C : String) : SysCode;</p> <p>Parameters: [in] C Color type (black and white only)</p> <p>SysCode values returned: SysInvalidRequest Invalid type SysOk The function completed successfully</p>

Table 5-21. Display Programming Methods (Continued)

5.12.1 Setting Widget Colors

SetWidgetColor(1, "#RRGGBB");

Hexadecimal color values are supported in all browsers and is specified with: #RRGGBB.

- RR = hex value for red 00-FF (0–255)
- GG = hex value for green 00-FF (0–255)
- BB = hex value for blue 00-FF (0–255)

00-FF – specifies the intensity of the color.

Example: #0000FF is displayed as blue, because the blue component is set to its highest value (FF) and the others are set to 00.

Value	Color
1	black
2	dark red
3	red
4	pink
5	teal
6	green
7	bright green
8	turquoise
9	dark blue
10	violet
11	blue
12	lightgrey
13	darkgrey
14	darkyellow
15	yellow
16	white

Table 5-22. Symbol Colors

The list of colors for the symbols are shown in [Table 5-22](#).

The following link explains web colors and supplies more information about the use of web colors.

https://en.wikipedia.org/wiki/Web_colors

This link accesses the vast number of hex colors that are supported by all browsers.

http://www.w3schools.com/colors/colors_names.asp

5.12.2 Image Widget Icons



NOTE: iRite does not have built-in functionality for iRite image numbers 1-7.png

Image	Filename								
	1.png		15.png		29.png		43.png		57.png
	2.png		16.png		30.png		44.png		58.png
	3.png		17.png		31.png		45.png		59.png
	4.png		18.png		32.png		46.png		60.png
	5.png		19.png		33.png		47.png		61.png
	6.png		20.png		34.png		48.png		62.png
	7.png		21.png		35.png		49.png		63.png
	8.png		22.png		36.png		50.png		64.png
	9.png		23.png		37.png		51.png		65.png
	10.png		24.png		38.png		52.png		66.png
	11.png		25.png		39.png		53.png		67.png
	12.png		26.png		40.png		54.png		68.png
	13.png		27.png		41.png		55.png		
	14.png		28.png		42.png		56.png		

Table 5-23. Image Widgets

5.12.3 Display Charting

Methods	Description
ChartClear 1280	<p>Clears the chart of data</p> <p>Method Signature: function ChartClear(widget_no : Integer) : SysCode;</p> <p>Parameters [in] widget_no Chart widget number</p> <p>SysCode values returned: SysOK The function completed successfully SysInvalidWidget Requested widget could not be found</p>
ChartInit 1280	<p>Call this API to initialize a non-static chart and set color values; Non-static charts allow:</p> <ul style="list-style-type: none"> • Added points once rendered (ChartInserToExisting) • Animation (ChartSetAnimation) • Up to 200 data points <p>Method Signature: Function ChartInit (widget_no : Integer; fillColor : String; lineColor : String; pointColor : String; maxPoints : Integer) : SysCode;</p> <p>Parameters: [in] widget_no Chart widget number [in] fillColor Html color for the fill area of the chart [in] lineColor Html color for the line between points, or the outer edge of the bar [in] pointColor Html color for data points on the line chart. Value is ignored on a bar chart [in] maxPoints Max number of points on the chart; The value is capped at 200 points; If the number of inserted points exceeds this value, the earliest points on the chart are removed</p> <p>SysCode values returned: SysOK The function completed successfully</p>
ChartInitStatic 1280	<p>Initializes a static chart; All data points shown in a static chart must be added (ChartPlot) prior to rendering (ChartRender); Static charts do not add data points after rendering nor support animation; Support up to 8000 data points</p> <p>Method Signature: function ChartInitStatic (widget_no : Integer; fillColor : String; lineColor : String; pointColor : String; maxPoints : Integer) : SysCode;</p> <p>Parameters: [in] widget_no Chart widget number [in] fillColor Html color for the fill area of the chart [in] lineColor Html color for the line between points, or the outer edge of the bar [in] pointColor Html color for data points on the line chart; Value is ignored on a bar chart [in] maxPoints Max number of points on the chart; The value is capped at 8000 points; If the number of inserted points exceeds this value, the earliest points on the chart are removed</p> <p>SysCode values returned: SysOK The function completed successfully</p>
ChartPlot 1280	<p>This API is called repeatedly until all data points are plotted prior to rendering the chart to the display</p> <p>Method Signature: function ChartPlot (widget_no : Integer; label : String; value : real) : SysCode;</p> <p>Parameters: [in] widget_no Chart widget number [in] label Label or name of the data point [in] value Value of the data point</p> <p>SysCode values returned: SysOK The function completed successfully</p>
ChartSetAnimation 1280	<p>If this is enabled, the chart will animate when rendered and updated (Non-static charts only)</p> <p>Method Signature: function ChartSetAnimation (widget_no : Integer; enabled : BooleanType) : SysCode;</p> <p>Parameters: [in] widget_no Chart widget number</p> <p>SysCode values returned: SysOK The function completed successfully</p>

Table 5-24. Display Charting Methods

Methods	Description
ChartRender 1280	Call this API to cause the chart to render to the display Method Signature: function ChartRender (widget_no : Integer) : SysCode; Parameters: [in] widget_no Chart widget number SysCode values returned: SysOK The function completed successfully
ChartInsertTo Existing 1280	Call this API to insert a new data point into a previously rendered non-static chart; If the new point exceeds the max number of points set in ChartInit, the oldest or leftmost point on the chart is removed while the new point is added Method Signature: function ChartInsertToExisting(widget_no : Integer; label : String; value : real) : SysCode; Parameters: [in] widget_no Chart widget number [in] label Label or name of the data point [in] value Value of the data point SysCode values returned: SysOK The function completed successfully
ChartSetPointSize 1280	Sets the point size of the dots in the chart Method Signature: Function ChartSetPointSize(widget_no : Integer; size : Integer) : Syscode; Parameters [in] widget_no Chart widget number [in] size Point size of the dots in the chart SysCode values returned: SysOK The function completed successfully SysInvalidRequest Invalid point size SysInvalidWidget Requested widget could not be found

Table 5-24. Display Charting Methods (Continued)

5.13 Database Operation

Methods	Description
<DB>.Add 920i 880 882D 1280	Adds a record to the referenced database; Previous sort operation may change Method Signature: function <DB>.Add : SysCode; SysCode values returned: SysNoSuchDatabase The referenced database cannot be found SysDatabaseFull There is no space in the specified database for this record SysOK The function completed successfully
<DB>.Clear 920i 880 882D 1280	Clears all records from the referenced database Method Signature: function <DB>.Clear : SysCode; SysCode values returned: SysNoSuchDatabase The referenced database cannot be found SysOK The function completed successfully
<DB>.Delete 920i 880 882D 1280	Deletes the current record from the referenced database; Previous sort operation may change Method Signature: function <DB>.Delete : SysCode; SysCode values returned: SysNoSuchDatabase The referenced database cannot be found SysNoSuchRecord The requested record is not contained in the database SysOK The function completed successfully

Table 5-25. Database Communication Methods

Methods	Description
<p>The following <DB.Find> functions allow a database to be searched; Column I is an alias for the field name, generated by the <i>Generate iRev import</i> file operation; The value to be matched is set in the working database record, in the field corresponding to column I, before a call to <DB>.FindFirst or <DB>.FindLast</p>	
<DB>.FindFirst 920i 880 882D 1280	<p>Finds the first record in the referenced database that matches the contents of the Working Database Record column I</p> <p>Method Signature: function <DB>.FindFirst (I : Integer) : SysCode;</p> <p>SysCode values returned: SysNoSuchDatabase The referenced database cannot be found SysNoSuchRecord The requested record is not contained in the database SysNoSuchColumn The column specified by I does not exist SysOK The function completed successfully</p>
<DB>.FindLast 920i 880 882D 1280	<p>Finds the last record in the referenced database that matches the contents of the Working Database Record column I</p> <p>Method Signature: function <DB>.FindLast (I : Integer) : SysCode;</p> <p>SysCode values returned: SysNoSuchDatabase The referenced database cannot be found SysNoSuchRecord The requested record is not contained in the database SysNoSuchColumn The column specified by I does not exist SysOK The function completed successfully</p>
<DB>.FindNext 920i 880 882D 1280	<p>Finds the next record in the referenced database that matches the criteria of a previous FindFirst or FindLast operation</p> <p>NOTE: GetNext only works with GetFirst. This only works for the 1280. NOTE: FindNext only works with FindFirst. This does not work for the 920i.</p> <p>Method Signature: function <DB>.FindNext : SysCode;</p> <p>SysCode values returned: SysNoSuchDatabase The referenced database cannot be found SysNoSuchRecord The requested record is not contained in the database SysOK The function completed successfully</p>
<DB>.FindPrev 920i 880 882D 1280	<p>Finds the previous record in the referenced database that matches the criteria of a previous FindFirst or FindLast operation</p> <p>Method Signature: function <DB>.FindLast : SysCode;</p> <p>SysCode values returned: SysNoSuchDatabase The referenced database cannot be found SysNoSuchRecord The requested record is not contained in the database SysOK The function completed successfully</p>
<DB>.GetFirst 920i 880 882D 1280	<p>Retrieves the first logical record from the referenced database</p> <p>Method Signature: function <DB>.GetFirst : SysCode;</p> <p>SysCode values returned: SysNoSuchDatabase The referenced database cannot be found SysNoSuchRecord The requested record is not contained in the database SysOK The function completed successfully</p>
<DB>.GetLast 920i 880 882D 1280	<p>Retrieves the last logical record from the referenced database</p> <p>Method Signature: function <DB>.GetLast : SysCode;</p> <p>SysCode values returned: SysNoSuchDatabase The referenced database cannot be found SysNoSuchRecord The requested record is not contained in the database SysOK The function completed successfully</p>

Table 5-25. Database Communication Methods (Continued)

Methods	Description
<DB>.GetNext 920i 880 882D 1280	Retrieves the next logical record from the referenced database NOTE: GetNext only works with GetFirst. This only works for the 1280. NOTE: FindNext only works with FindFirst. This does not work for the 920i. Method Signature: function <DB>.GetNext : SysCode; SysCode values returned: SysNoSuchDatabase The referenced database cannot be found SysNoSuchRecord The requested record is not contained in the database SysOK The function completed successfully
<DB>.GetPrev 920i 880 882D 1280	Retrieves the previous logical record from the referenced database Method Signature: function <DB>.GetPrev : SysCode; SysCode values returned: SysNoSuchDatabase The referenced database cannot be found SysNoSuchRecord The requested record is not contained in the database SysOK The function completed successfully
<DB>.Sort 920i 880 882D 1280	Sorts database <DB> into ascending order based on the contents of column I; The sort table supports a maximum of 30 000 elements; Databases with more than 30 000 records cannot be sorted; The 880 has a maximum sort of 15000 elements Method Signature: function <DB>.Sort (I : Integer) : SysCode; Parameters: [in] I Column number to sort by SysCode values returned: SysNoSuchDatabase The referenced database cannot be found SysNoSuchRecord The requested record is not contained in the database SysOK The function completed successfully
<DB>.Update 920i 880 882D 1280	Updates the current record in the referenced database with the contents of the Working Database Record; Using this function invalidates any previous sort operation Method Signature: function <DB>.Update : SysCode; SysCode values returned: SysNoSuchDatabase The referenced database cannot be found SysNoSuchRecord The requested record is not contained in the database SysOK The function completed successfully

Table 5-25. Database Communication Methods (Continued)

5.13.1 iRite SQL Feature

Version 1.05 of the 1280 indicator, includes an SQL query capability, added to the iRite language. This provides a robust query mechanism for iRite programs. It includes the ability to:

- specify multiple sort criteria
- specify multiple search criteria
- the ability to search for ranges rather than a single value
- join tables to pull in data from multiple tables into a single result set

In order to maintain compatibility with the existing DB.* APIs and DB.DATA EDP commands, all tables must be defined with DB.SCHEMA and DB.ALIAS configuration. The 1280 core software will be responsible for creating tables based on this configuration. The following SQL capabilities will not be supported:

- CREATE TABLE
- DROP TABLE
- ALTER TABLE

DB Tables

Current design has one sqlite database for each configured schema. Each database has one table. This feature modifies that to one iRite database. Each configured schema will be a table in the database. When updating an 1280 from Version 1.04 to Version 1.05, a program to transfer data from existing databases into the new iRite database needs to be run.

DB iRite APIs

APIs have been created to allow the use of SQL queries from an iRite user program. Basic use is as follows:

- Construct the SQL statement and call the DBExec; this API will return an identifier for the query result set
- Retrieve data from the result set using the DBColumnxxx API; there will be APIs for the iRite types: Integer, Real, String, and DateTime
- Step through the result set with the DBNext API
- After all results have been retrieved, call DBFinalize to free up the result set resources

Methods	Description																	
DBExec 1280	<p>Execute a SQL statement; queries which return data have an active result set for which an identifier is returned; this identifier is used on subsequent calls to retrieve data from the result set; the result set resources must be freed by calling DBFinalize when it is no longer needed; there is a limit of 10 concurrent active result sets</p> <p>Method Signature: function DBExec (S : String; var R : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>SQL query</td> </tr> <tr> <td>[out]</td> <td>R</td> <td>Result set identifier, 0 if there is no result set from the query</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidRequest</td> <td>Too many active result sets</td> </tr> <tr> <td>SysPermissionDenied</td> <td>An attempt was made to perform a restricted actions (create, alter or drop table)</td> </tr> <tr> <td>SysRequestFailed</td> <td>SQL query could not be executed</td> </tr> <tr> <td>SysOk</td> <td>The function completed successfully</td> </tr> </table>	[in]	S	SQL query	[out]	R	Result set identifier, 0 if there is no result set from the query	SysInvalidRequest	Too many active result sets	SysPermissionDenied	An attempt was made to perform a restricted actions (create, alter or drop table)	SysRequestFailed	SQL query could not be executed	SysOk	The function completed successfully			
[in]	S	SQL query																
[out]	R	Result set identifier, 0 if there is no result set from the query																
SysInvalidRequest	Too many active result sets																	
SysPermissionDenied	An attempt was made to perform a restricted actions (create, alter or drop table)																	
SysRequestFailed	SQL query could not be executed																	
SysOk	The function completed successfully																	
DBNext 1280	<p>Advance to the next row in the result set</p> <p>Method Signature: function DBNext (R : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>R</td> <td>Result set identifier</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidRequest</td> <td>Invalid result set identifier</td> </tr> <tr> <td>SysNoSuchRecord</td> <td>There are no more records in the result set</td> </tr> <tr> <td>SysRequestFailed</td> <td>Advance could not be completed</td> </tr> <tr> <td>SysOk</td> <td>The function completed successfully</td> </tr> </table>	[in]	R	Result set identifier	SysInvalidRequest	Invalid result set identifier	SysNoSuchRecord	There are no more records in the result set	SysRequestFailed	Advance could not be completed	SysOk	The function completed successfully						
[in]	R	Result set identifier																
SysInvalidRequest	Invalid result set identifier																	
SysNoSuchRecord	There are no more records in the result set																	
SysRequestFailed	Advance could not be completed																	
SysOk	The function completed successfully																	
DBColumnInt 1280	<p>Retrieve value of a column from the current row of the result set as an integer value</p> <p>Method Signature: function DBColumnInt (R : Integer; C : Integer; var V : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>R</td> <td>Result set identifier</td> </tr> <tr> <td>[in]</td> <td>C</td> <td>Column number</td> </tr> <tr> <td>[out]</td> <td>V</td> <td>Value of the requested column in the result set</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidRequest</td> <td>Invalid result set identifier</td> </tr> <tr> <td>SysNoSuchColumn</td> <td>Invalid column number</td> </tr> <tr> <td>SysRequestFailed</td> <td>Incorrect column type</td> </tr> <tr> <td>SysOk</td> <td>The function completed successfully</td> </tr> </table>	[in]	R	Result set identifier	[in]	C	Column number	[out]	V	Value of the requested column in the result set	SysInvalidRequest	Invalid result set identifier	SysNoSuchColumn	Invalid column number	SysRequestFailed	Incorrect column type	SysOk	The function completed successfully
[in]	R	Result set identifier																
[in]	C	Column number																
[out]	V	Value of the requested column in the result set																
SysInvalidRequest	Invalid result set identifier																	
SysNoSuchColumn	Invalid column number																	
SysRequestFailed	Incorrect column type																	
SysOk	The function completed successfully																	
DBColumnReal 1280	<p>Retrieve value of a column from the current row of the result set as a real value</p> <p>Method Signature: function DBColumnInt (R : Integer; C : Integer; var V : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>R</td> <td>Result set identifier</td> </tr> <tr> <td>[in]</td> <td>C</td> <td>Column number</td> </tr> <tr> <td>[out]</td> <td>V</td> <td>Value of the requested column in the result set</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidRequest</td> <td>Invalid result set identifier</td> </tr> <tr> <td>SysNoSuchColumn</td> <td>Invalid column number</td> </tr> <tr> <td>SysRequestFailed</td> <td>Incorrect column type</td> </tr> <tr> <td>SysOk</td> <td>The function completed successfully</td> </tr> </table>	[in]	R	Result set identifier	[in]	C	Column number	[out]	V	Value of the requested column in the result set	SysInvalidRequest	Invalid result set identifier	SysNoSuchColumn	Invalid column number	SysRequestFailed	Incorrect column type	SysOk	The function completed successfully
[in]	R	Result set identifier																
[in]	C	Column number																
[out]	V	Value of the requested column in the result set																
SysInvalidRequest	Invalid result set identifier																	
SysNoSuchColumn	Invalid column number																	
SysRequestFailed	Incorrect column type																	
SysOk	The function completed successfully																	

Table 5-26. iRite SQL Feature Methods

Methods	Description
DBCColumnString 1280	Retrieve value of a column from the current row of the result set as a string value Method Signature: function DBColumnInt (R : Integer; C : Integer; var V : String) : SysCode; Parameters: [in] R Result set identifier [in] C Column number [out] V Value of the requested column in the result set SysCode values returned: SysInvalidRequest Invalid result set identifier SysNoSuchColumn Invalid column number SysRequestFailed Incorrect column type SysOk The function completed successfully
DBCColumnDT 1280	Retrieve value of a column from the current row of the result set as a DateTime value Method Signature: function DBColumnDT (R : Integer; C : Integer; var V : DateTime) : SysCode; Parameters: [in] R Result set identifier [in] C Column number [out] V Value of the requested column in the result set SysCode values returned: SysInvalidRequest Invalid result set identifier SysNoSuchColumn Invalid column number SysRequestFailed Incorrect column type SysOk The function completed successfully
DBFinalize 1280	Free up result set resources. DBFinalize must be called when the result set is no longer needed; There is a limit to how many active result sets are allowed Method Signature: function DBFinalize (R : Integer) : SysCode; Parameters: [in] R Result set identifier SysCode values returned: SysInvalidRequest Invalid result set identifier SysOk The function completed successfully
DBErrMsg 1280	Get a description of the error from the last database call; If the most recent database call was successful the message returned is undefined Method Signature: function DBErrMsg () : String;
DTTToString 1280	Return String representation of the encoded date time d; This is intended to be used to add a DateTime value to an SQL query string Method Signature: function DTTToString (D : DateTime) : SysCode; Parameters: [in] D Date Time value to be formatted

Table 5-26. iRite SQL Feature Methods (Continued)

5.14 Timer Control

Thirty-two timers, configurable as either continuous or one-shot timers, can be used to generate events at some time in the future. The shortest interval for which a timer can be set is 10 ms.

Methods	Description
ResetTimer 920i 820i 880 882D 1280	Resets the value of timer T (1–32) by stopping the timer, setting the timer mode to <code>TimerOneShot</code> , and setting the timer time-out to 0 Method Signature: function <code>ResetTimer (T : Integer) : Syscode;</code> Parameters: [in] T Timer number SysCode values returned: SysInvalidTimer The timer specified by T is not a valid timer SysOK The function completed successfully
ResumeTimer 920i 820i 880 882D 1280	Restarts a stopped timer T (1–32) from its stopped value Method Signature: function <code>ResumeTimer (T : Integer) : Syscode;</code> Parameters: [in] T Timer number SysCode values returned: SysInvalidTimer The timer specified by T is not a valid timer SysOK The function completed successfully
SetTimer 920i 820i 880 882D 1280	Sets the time-out value of timer T (1–32); Timer values are specified in 0.01-second intervals (1= 10 ms, 100 = 1 second); For one-shot timers, the <code>SetTimer</code> function must be called again to restart the timer once it has expired Method Signature: function <code>SetTimer (T : Integer ; V : Integer) : Syscode;</code> Parameters: [in] T Timer number [in] V Timer value SysCode values returned: SysInvalidRequest The specified time-out value is less than 0 SysInvalidTimer The timer specified by T is not a valid timer SysOK The function completed successfully
SetTimerDigout 920i 820i 880 882D 1280	Used to provide precise control of state changes for timers using <code>TimerDigoutOff</code> or <code>TimerDigoutOn</code> modes; The state of the specified digital output (slot S , bit D) is changed when timer T (1–32) expires Method Signature: function <code>SetTimerDigOut (T : Integer ; S : Integer ; D: Integer) : Syscode;</code> Parameters: [in] T Timer number [in] S Digital I/O slot number [in] D Digital I/O bit number SysCode values returned: SysInvalidRequest The slot or bit number specified is not a valid digital output SysInvalidTimer The timer specified by T a not valid timer SysOK The function completed successfully <i>Example:</i> <code>SetTimer(1,100);</code> –Set value of <code>Timer1</code> to 100 (1 second) <code>SetTimerMode(1,TimerDigoutOn);</code> –Set timer mode to turn on the digital output <code>SetTimerDigout(1,0,1);</code> –Set the digital output to control (slot 0, bit 1) <code>StartTimer(1);</code> –Start timer

Table 5-27. Timer Control Methods

Methods	Description																				
SetTimerMode 920i 820i 880 882D 1280	<p>Sets the mode value, M, of timer T (1–32); This function, normally included in a program startup handler, only needs to be called once for each timer unless the timer mode is changed</p> <p>Method Signature: function SetTimerMode (T : Integer ; M : TimerMode) : Syscode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>T</td> <td>Timer number</td> </tr> <tr> <td>[in]</td> <td>M</td> <td>Timer mode</td> </tr> </table> <p>TimerMode values sent:</p> <table> <tr> <td>TimerOneShot</td> <td>Timer mode is set to one-shot</td> </tr> <tr> <td>TimerContinuous</td> <td>Timer mode is set to continuous</td> </tr> <tr> <td>TimerDigOutOff</td> <td>One-shot timer sets a digital output off when the timer expires</td> </tr> <tr> <td>TimerDigOutOn</td> <td>One-shot timer sets a digital output on when the timer expires</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidTimer</td> <td>The timer specified by T is not a valid timer</td> </tr> <tr> <td>SysInvalidMode</td> <td>The timer mode specified by M is not a valid timer mode</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	[in]	T	Timer number	[in]	M	Timer mode	TimerOneShot	Timer mode is set to one-shot	TimerContinuous	Timer mode is set to continuous	TimerDigOutOff	One-shot timer sets a digital output off when the timer expires	TimerDigOutOn	One-shot timer sets a digital output on when the timer expires	SysInvalidTimer	The timer specified by T is not a valid timer	SysInvalidMode	The timer mode specified by M is not a valid timer mode	SysOK	The function completed successfully
[in]	T	Timer number																			
[in]	M	Timer mode																			
TimerOneShot	Timer mode is set to one-shot																				
TimerContinuous	Timer mode is set to continuous																				
TimerDigOutOff	One-shot timer sets a digital output off when the timer expires																				
TimerDigOutOn	One-shot timer sets a digital output on when the timer expires																				
SysInvalidTimer	The timer specified by T is not a valid timer																				
SysInvalidMode	The timer mode specified by M is not a valid timer mode																				
SysOK	The function completed successfully																				
StartTimer 920i 820i 880 882D 1280	<p>Starts timer T (1–32); For one-shot timers, this function must be called each time the timer is used; Continuous timers are started only once; They do not require another call to StartTimer unless stopped by a call to the StopTimer function; If a timer has been set with a time-out value of 0, StartTimer will not start the timer but will return SysOk</p> <p>Method Signature: function StartTimer (T : Integer) : Syscode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>T</td> <td>Timer number</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidTimer</td> <td>The timer specified by T is not a valid timer</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	[in]	T	Timer number	SysInvalidTimer	The timer specified by T is not a valid timer	SysOK	The function completed successfully													
[in]	T	Timer number																			
SysInvalidTimer	The timer specified by T is not a valid timer																				
SysOK	The function completed successfully																				
StopTimer 920i 820i 880 882D 1280	<p>Stops timer T (1–32)</p> <p>Method Signature: function StopTimer (T : Integer) : Syscode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>T</td> <td>Timer number</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidTimer</td> <td>The timer specified by T is not a valid timer</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table>	[in]	T	Timer number	SysInvalidTimer	The timer specified by T is not a valid timer	SysOK	The function completed successfully													
[in]	T	Timer number																			
SysInvalidTimer	The timer specified by T is not a valid timer																				
SysOK	The function completed successfully																				

Table 5-27. Timer Control Methods (Continued)

5.15 Mathematical Operations

Methods	Description
Abs 920i 820i 880 882D 1280	Returns the absolute value of x Method Signature: function Abs (x : Real) : Real;
ATan 920i 820i 880 882D 1280	Returns a value between $-p/2$ and $p/2$, representing the arctangent of x in radians Method Signature: function Atan (x : Real) : Real;
Ceil 920i 820i 880 882D 1280	Returns the smallest integer greater than or equal to x Method Signature: function Ceil (x : Real) : Integer;
Cos 920i 820i 880 882D 1280	Returns the cosine of x . x must be specified in radians Method Signature: function Cos (x : Real) : Real;
Exp 920i 820i 880 882D 1280	Returns the value of e^x Method Signature: function Exp (x : Real) : Real;
Log 920i 820i 880 882D 1280	Returns the value of $\log_e(x)$ Method Signature: function Log (x : Real) : Real;
Log10 920i 820i 880 882D 1280	Returns the value of $\log_{10}(x)$ Method Signature: function Log10 (x : Real) : Real;
Sign 920i 820i 880 882D 1280	Returns the sign of the numeric operand; If x < 0, the function returns a value of -1; Otherwise, the value returned is 1 Method Signature: function Sign (x : Real) : Integer;
Sin 920i 820i 880 882D 1280	Returns the sine of x . x must be specified in radians Method Signature: function Sin (x : Real) : Real;

Table 5-28. Mathematical Operation Methods

Methods	Description
Sqrt 920i 820i 880 882D 1280	Returns the square root of x Method Signature: function Sqrt (x : Real) : Real;
Tan 920i 820i 880 882D 1280	Returns the tangent of x . x must be specified in radians Method Signature: function Tan (x : Real) : Real;

Table 5-28. Mathematical Operation Methods (Continued)

5.16 Bit-Wise Operation

Methods	Description
BitAnd 920i 820i 880 882D 1280	Returns the bit-wise AND result of X and Y Method Signature: function BitAnd (X : Integer; Y : Integer) : Integer;
BitNot 920i 820i 880 882D 1280	Returns the bit-wise NOT result of X Method Signature: function BitNOT (X : Integer) : Integer;
BitOr 920i 820i 880 882D 1280	Returns the bit-wise OR result of X and Y Method Signature: function BitOr (X : Integer; Y : Integer) : Integer;
BitXor 920i 820i 880 882D 1280	Returns the bit-wise exclusive OR (XOR) result of X and Y Method Signature: function BitXor (X : Integer; Y : Integer) : Integer;

Table 5-29. Bit-Wise Operation Methods

5.17 String Operations

Methods	Description
Asc 920i 820i 880 882D 1280	Returns the ASCII value of the first character of string S ; If S is an empty string, the value returned is 0 Method Signature: function Asc (S : String) : Integer;
Chr\$ 920i 820i 880 882D 1280	Returns a one-character string containing the ASCII character represented by I Method Signature: function Chr\$ (I : Integer) : String; Parameters: [in] I The integer value to be converted Value returned: A string containing the ASCII character of the integer value
Hex\$ 920i 820i 880 882D 1280	Returns an eight-character hexadecimal string equivalent to I (Range is -2147483647–2147483647) Method Signature: function Hex\$ (I : Integer) : String; Parameters: [in] I The integer value to be converted Value returned: The string representation of the hexadecimal conversion of the integer value
LCase\$ 920i 820i 880 882D 1280	Returns the string S with all upper-case letters converted to lower case Method Signature: function LCase\$ (S : String) : String; Parameters: [in] S The string to be converted to all lower case Value returned: The converted string
Left\$ 920i 820i 880 882D 1280	Returns a string containing the leftmost I characters of string S ; If I is greater than the length of S , the function returns a copy of S Method Signature: function Left\$ (S : String; I : Integer) : String; Parameters: [in] S The source string [in] I The number of characters to return in the result Value returned: A string containing the requested number of leftmost characters of the provided string
Len 920i 820i 880 882D 1280	Returns the length (number of characters) of string S Method Signature: function Len (S : String) : Integer; Parameters: [in] S The string Value returned: An Integer representing the number of characters in the provided string

Table 5-30. String Operation Methods

Methods	Description									
Mid\$ 920i 820i 880 882D 1280	<p>Returns a number of characters (specified by length) from string s, beginning with the character specified by start; if start is greater than the string length, the result is an empty string; if start + length is greater than the length of S, the returned value contains the characters from start through the end of S</p> <p>Method Signature: function Mid\$ (S : String; start : Integer; length : Integer) : String;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>The source string</td> </tr> <tr> <td>[in]</td> <td>start</td> <td>Character position to start from</td> </tr> <tr> <td>[in]</td> <td>length</td> <td>The number of characters to return in the result</td> </tr> </table> <p>Value returned: A string containing the requested portion of the provided string</p>	[in]	S	The source string	[in]	start	Character position to start from	[in]	length	The number of characters to return in the result
[in]	S	The source string								
[in]	start	Character position to start from								
[in]	length	The number of characters to return in the result								
Oct\$ 920i 820i 880 882D 1280	<p>Returns an 11-character octal string equivalent to I (range is -2147483647–2147483647)</p> <p>Method Signature: function Oct\$ (I : Integer) : String;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>I</td> <td>The integer value to be converted</td> </tr> </table> <p>Value returned: The string representation of the octal conversion of the integer value</p>	[in]	I	The integer value to be converted						
[in]	I	The integer value to be converted								
Right\$ 920i 820i 880 882D 1280	<p>Returns a string containing the rightmost I characters of string S; if I is greater than the length of S, the function returns a copy of S</p> <p>Method Signature: function Right\$ (S : String; I : Integer) : String;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>The source string.</td> </tr> <tr> <td>[in]</td> <td>I</td> <td>The number of characters to return in the result.</td> </tr> </table> <p>Value returned: A string containing the requested number of rightmost characters of the provided string</p>	[in]	S	The source string.	[in]	I	The number of characters to return in the result.			
[in]	S	The source string.								
[in]	I	The number of characters to return in the result.								
Space\$ 920i 820i 880 882D 1280	<p>Returns a string containing N spaces</p> <p>Method Signature: function Space\$ (N : Integer) : String;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>N</td> <td>The number of spaces to be contained in the string</td> </tr> </table> <p>Value returned: A string containing the requested number of spaces</p>	[in]	N	The number of spaces to be contained in the string						
[in]	N	The number of spaces to be contained in the string								
UCase\$ 920i 820i 880 882D 1280	<p>Returns the string S with all lower-case letters converted to upper case</p> <p>Method Signature: function UCase\$ (S : String) : String;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>The string to be converted to all upper case</td> </tr> </table> <p>Value returned: The converted string</p>	[in]	S	The string to be converted to all upper case						
[in]	S	The string to be converted to all upper case								

Table 5-30. String Operation Methods (Continued)

5.18 Data Conversion

Command	Description									
IntegerToString 920i 820i 880 882D 1280	<p>Returns a string representation of the integer I with a minimum length of W; If W is less than zero, zero is used as the minimum length; If W is greater than 100, 100 is used as the minimum length</p> <p>Method Signature: function IntegerToString (I : Integer; W : Integer) : String;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>I</td> <td>The integer value to be converted</td> </tr> <tr> <td>[in]</td> <td>W</td> <td>The minimum length of the string</td> </tr> </table>	[in]	I	The integer value to be converted	[in]	W	The minimum length of the string			
[in]	I	The integer value to be converted								
[in]	W	The minimum length of the string								
RealToString 920i 820i 880 882D 1280	<p>Returns a string representation of the real number R with a minimum length of W, with P digits to the right of the decimal point; If W is less than zero, zero is used as the minimum length; If W is greater than 100, 100 is used as the minimum length; If P is less than zero, zero is used as the precision; If P is greater than 20, 20 is used</p> <p>Method Signature: function RealToString (R : Real; W : Integer; P: Integer) : String;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>R</td> <td>Real variable to convert to a string</td> </tr> <tr> <td>[in]</td> <td>W</td> <td>The minimum length of the string</td> </tr> <tr> <td>[in]</td> <td>P</td> <td>Precision or number of places to the right of the decimal place to display</td> </tr> </table>	[in]	R	Real variable to convert to a string	[in]	W	The minimum length of the string	[in]	P	Precision or number of places to the right of the decimal place to display
[in]	R	Real variable to convert to a string								
[in]	W	The minimum length of the string								
[in]	P	Precision or number of places to the right of the decimal place to display								
StringToInteger 920i 820i 880 882D 1280	<p>Returns the integer equivalent of the numeric string S; If S is not a valid string, function returns the value 0</p> <p>Method Signature: function StringToInteger (S : String) : Integer;</p> <p>Parameter:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>String to convert to an integer</td> </tr> </table>	[in]	S	String to convert to an integer						
[in]	S	String to convert to an integer								
StringToReal 920i 820i 880 882D 1280	<p>Returns the real number equivalent of the numeric string S; If S is not a valid string, the function returns the value 0.0</p> <p>Method Signature: function StringToReal (S : String) : Real;</p> <p>Parameter:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>String to convert to a real value</td> </tr> </table>	[in]	S	String to convert to a real value						
[in]	S	String to convert to a real value								
SysCodeToString 920i 880 882D 1280	<p>Returns a string representation of the SysCode type, see Section 4.0 on page 35 for all the possible types that can be returned</p> <p>Method Signature: function SysCodeToString(Code : SysCode): String;</p> <p>Parameter:</p> <table> <tr> <td>[in]</td> <td>Code</td> <td>A value of type SysCode to convert to a value of type String</td> </tr> </table> <p>Value Returned: The String, see Section 4.0 on page 35 for possible values</p> <p><i>Example:</i> result : Syscode; ... result := SetFileTermination(FileCRLF); WriteLn(1, SysCodeToString(result));</p>	[in]	Code	A value of type SysCode to convert to a value of type String						
[in]	Code	A value of type SysCode to convert to a value of type String								

Table 5-31. Data Conversion Commands

5.19 High Precision

Command	Description
DecodeExtFloat 920i 820i 1280	A five-byte IEEE-1594 extended floating point number, expressed as an array or bytes, is converted to a standard 4-byte floating point real; NaN and infinity are processed; If a number is too small to convert to 4-byte precision, zero is returned; If a number is too large to convert to 4-byte precision, infinity is returned Method Signature: function DecodeExtFloat(weight : ExtFloatArray) : real;
EncodeExtFloat 920i 820i 1280	Converts a 4-byte floating point real to a 5-byte IEEE-1394 extended floating point number in the form of an array of five bytes Method Signature: function EncodeExtFloat(weight : real) : ExtFloatArray;

Table 5-32. High Precision Commands

5.20 File I/O

A user program may have only one file open at a time. Once opened, any further file accesses will be to that file.

Methods	Description
USBFileOpen 920i 1280	Read a file from a flash drive; opening a file as Read positions the internal pointer at the start of the file; opening a file as Create or Append positions the internal pointer at the end of the file; Any attempt to read a file opened as Create or Append will return SysEndOfFile Method Signature: function (filename : string; mode : FileAccessMode) : SysCode; Parameters: [in] filename The indicator will look in a folder named whatever the indicator's UID is set for (defaulted to 1) for the filename sent as the parameter. Use the entire path (without the drive) [in] mode How the file is to be opened: FileCreate, FileAppend, or FileRead. See FileAccessMode in Section 4.0 on page 35 SysCode values returned: SysOk SysNoFileSystemFound SysPortBusy SysFileNotFound SysDirectoryNotFound SysFileExists SysInvalidFileFormat SysBadFilename (over 8 characters) SysEndOfFile <i>Examples:</i> USBFileOpen(Testing.txt, FileCreate); –Creates a new empty file called Testing.txt USBFileOpen(Testing.txt, FileAppend); –Adds to a currently stored file called Testing.txt USBFileOpen(test, FileRead); –Reads from a currently stored file
FileOpen 1280	Similar to <i>USBFileOpen</i> , except 1280 specific; Opens a file on the USB drive, SD card or FTP Server; Has an additional parameter to specify the device; Refer to the <i>USBFileOpen</i> description for additional information Method Signature: function FileOpen (filename : string; device : FileDevice; mode : FileAccessMode) : SysCode; SysCode values returned: SysOk SysFileOpen SysRequestFailed <i>Examples:</i> FileOpen("Testing.txt", SDCard, FileCreate); –Creates a new empty file called Testing.txt on the SD card FileOpen("Testing.txt", SDCard, FileAppend); –Adds to a currently stored file called Testing.txt on the SD card FileOpen("Testing.txt", SDCard, FileRead); –Reads from a currently stored file on the SD card

Table 5-33. File I/O Commands

Methods	Description
USBFileClose 920i 1280	<p>Used to close a currently opened file (USB) (see <i>USBFileOpen</i>); A file must be closed before device removal or the file contents may be corrupted</p> <p>Method Signature: function USBFileClose : SysCode;</p> <p>Parameters: None</p> <p>SysCode values returned: SysOk SysNoFileSystemFound SysMediaChanged SysNoFileOpen</p> <p><i>Example:</i> USBFileClose;</p>
FileClose 1280	<p>Similar to <i>USBFileClose</i>, except 1280 specific; Used to close a currently opened file, see <i>FileOpen</i>; a file must be closed before device removal or the file contents may be corrupted; Refer to the <i>USBFileClose</i> description for additional information</p> <p>Method Signature: function FileClose : Syscode;</p> <p>SysCode values returned: SysOk SysNoFileOpen</p> <p><i>Example:</i> FileClose;</p>
USBFileDelete 920i 1280	<p>Deletes a file saved on the USB drive; To overwrite an existing file, the user program should first delete the file, then reopen it with Create access</p> <p>Method Signature: function USBFileDelete (filename : string) : SysCode;</p> <p>Parameters: Filename -the indicator will look in a folder named whatever the indicator's UID is set for (defaulted to 1) for the filename sent as the parameter</p> <p>SysCode values returned: SysOk SysNoFileSystemFound SysPortBusy SysFileNotFound SysDirectoryNotFound SysBadfilename</p> <p><i>Example:</i> USBFileDelete("Testing.txt");</p>
FileDelete 1280	<p>Similar to <i>USBFileDelete</i>, except 1280 specific; Deletes a file saved on the USB drive, SD card or FTP server; To overwrite an existing file, the user program should first delete the file, then reopen it with Create access; Has an additional parameter to specify the device; Refer to the <i>USBFileDelete</i> description for additional information</p> <p>Method Signature: function FileDelete (filename : string; device : FileDevice) : Syscode;</p> <p>SysCode values returned: SysOk SysFileOpen SysFileNotFound</p> <p><i>Example:</i> FileDelete("Testing.txt", FTP); FileDelete("Testing.txt", USB);</p>

Table 5-33. File I/O Commands (Continued)

Methods	Description
USBFileExists 920i 1280	<p>Checks to see if a file exists on the USB drive</p> <p>Method Signature: function USBFileExists (filename : string) : SysCode;</p> <p>Parameters: Filename - the indicator will look in a folder named whatever the indicator's UID is set for (defaulted to 1) for the filename sent as the parameter</p> <p>SysCode values returned: SysOk SysNoFileSystemFound SysPortBusy SysInvalidMode SysBadfilename</p> <p><i>Example:</i> USBFileExists("Testing.txt");</p>
FileExists 1280	<p>Similar to <i>USBFileExists</i>, except 1280 specific; Checks to see if a file exists on the USB drive, SD card or FTP server; Has an additional parameter to specify the device; Refer to the <i>USBFileExists</i> description for additional information</p> <p>Method Signature: function FileExists (filename : string; device : FileDevice) : SysCode;</p> <p>SysCode values returned: SysOk SysFileOpen SysFileNotFound</p> <p><i>Example:</i> FileExists("Testing.txt", SDCard); FileExists("Testing.txt", FTP);</p>
ReadLn 920i 1280	<p>Read a string from whatever file is currently open; The string will be placed in a string-type-variable that must be defined</p> <p>Method Signature: function ReadLn (VAR data : string) : SysCode;</p> <p>Parameters: Data: this is the string type variable that the data will be placed in to display or print or otherwise be used by the program; It reads one line at a time and the entire line is in this string</p> <p>SysCode values returned: SysOk SysNoFileOpen SysMediaChanged SysNoFileSystemFound SysEndOfFile</p> <p><i>Example:</i> Result := ReadLn(sTempString); –Reads a line of data from whatever file is open while Result <> SysEndOfFile –Loops, looking at the return code until the end loop Result := ReadLn(sTempString); WriteLn(3, sTempString); –Prints each line read out Port 3 end loop;</p>
WriteLn 920i	<p>These APIs both write out a port (and are not new to USB but can be used by the USB); If writing to the USB drive it will append the string to the end of the currently open file; The only difference between the two is the WriteLn sends a carriage return/line feed at the end, and Write does not</p> <p>Method Signature: procedure Write (Port : Integer; data : string);</p> <p>Parameters: Port - Whichever port on the indicator the data will be sent out of. Port 2 is used for USB</p> <p><i>Example:</i> see ReadLn.</p>

Table 5-33. File I/O Commands (Continued)

Methods	Description
FileWrite 1280	Append a string to the currently open file Method Signature: function FileWrite (S : String) : SysCode; Parameters: S - The string to append to the file SysCode values returned: SysOk SysNoFileOpen SysNoFileSystemFound <i>Example:</i> FileWrite("line of data");
FileWriteLn 1280	Append a string to the currently open file; Sends FileTermination (SetFileTermin) at the end Method Signature: function FileWriteLn (S : String) : SysCode; Parameters: S - The string to append to the file SysCode values returned: SysOk SysNoFileOpen SysNoFileSystemFound <i>Example:</i> FileWriteLn("line of data");
GetUSBStatus 920i	Returns the most recent status report for the USB port; This is useful for validating a Write or WriteLn Method Signature: function GetUSBStatus : SysCode; SysCode values returned: SysOk SysInvalidRequest <i>Example:</i> Result := GetUSBStatus;
GetUSBAssignment 920i	Returns the USBDeviceType currently in use Method Signature: function GetUSBAssignment : USBDeviceType; <i>Example:</i> dDevice := GetUSBAssignment; <i>–verify the assignment</i> if dDevice = USBFileSystem then WriteLn(3,"USBFlashDrive"); elseif dDevice = USBHostPC then WriteLn(OutPort,"USBHostPC"); elseif dDevice = USBPrinter2 then WriteLn(OutPort,"USBPrinter2"); elseif dDevice = USBPrinter1 then WriteLn(OutPort,"USBPrinter1"); elseif dDevice = USBKeyboard then WriteLn(OutPort,"USBKeyboard"); else WriteLn(OutPort,"Device Unknown"); end if;

Table 5-33. File I/O Commands (Continued)

Methods	Description
SetUSBAssignment 920i	Selects a secondary device for current use, capturing the current device as primary Method Signature: function SetUSBAssignment (device : USBDeviceType) : SysCode Parameters: device (see Section 4.0 on page 35) SysCode values returned: SysOk SysDeviceNotFound SysPortBusy <i>Example:</i> SetUSBAssignment(USBHostPC);
ReleaseUSB Assignment 920i	Returns the current USB device to the captured primary device Method Signature: function ReleaseUSBAssignment : SysCode SysCode values returned: SysOk SysDeviceNotFound SysPortBusy <i>Example:</i> ReleaseUSBAssignment;
IsUSBDevicePresent 920i	Checks to see if the device passed is there or not Method Signature: function IsUSBDevicePresent (device : USBDeviceType) : SysCode; Parameters: device (see Section 4.0 on page 35) SysCode values returned: SysOk SysDeviceNotFound <i>Example:</i> Result := IsUSBDevicePresent(USBFileSystem); if Result <> SysOk then WriteLn(OutPort,"Flash Drive Not Found"); else WriteLn(OutPort,"SysOK"); end if;
SetFileTermin 920i 1280	This determines what is appended at the end of each line Termin - see Section 4.0 on page 35 for FileLineTermination type options Method Signature: function SetFileTermin (termin : FileLineTermination) : SysCode; SysCode values returned: SysOk <i>Example:</i> SetFileTermin(FileCRLF);

Table 5-33. File I/O Commands (Continued)

Methods	Description
DBLoad 920i	<p>Opens a file in Read mode using the name of the database and the Unit ID and calls the core to process it as a database file; The file is closed when done</p> <p>Method Signature: function DBLoad (db name : String) : SysCode;</p> <p>SysCode values returned: SysOk SysNoSuchDatabase SysNoFileSystemFound SysFileAlreadyOpen SysFileNotFound SysDirectoryNotFound SysInvalidFileFormat SysPortBusy</p> <p><i>Example:</i> if DBLoad("Product") = Sysok then DisplayStatus("Product Database Loaded into 920i") end if;</p>
DBSave 920i	<p>Opens a file in Create mode using the name of the database and the Unit ID and calls the core to process it as a database file; File is closed when done</p> <p><i>Example: if the Unit ID in the 920i was 5, it would store a file to E:/5/Product.txt (if the computer recognized the thumb drive as drive E).</i></p> <p>Method Signature: function DBSave (db name : String) SysCode;</p> <p>SysCode values returned: SysOk SysNoSuchDatabase SysNoFileSystemFound SysFileAlreadyOpen SysFileNotFound SysDirectoryNotFound SysFileExists SysPortBusy</p> <p><i>Example:</i> if DBSave("Product") = Sysok then DisplayStatus("Product Database Saved to thumb drive") end if;</p>

Table 5-33. File I/O Commands (Continued)

5.21 882D Belt Scale Data Acquisition

This section lists additional APIs used specifically to program the 882D integrator.



NOTE: General APIs for the 882D are referenced elsewhere throughout this chapter ([Section 5.0 on page 39](#)).

Methods	Description						
GetMaxCapacity 882D	<p>Sets C to the configured max capacity for scale S</p> <p>Method Signature: function GetMaxCapacity (S : Integer; VAR C : Real) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[out]</td> <td>C</td> <td>Scale capacity</td> </tr> </table> <p>SysCode values returned: SysInvalidScale The scale specified by S does not exist SysOK The function completed successfully</p>	[in]	S	Scale number	[out]	C	Scale capacity
[in]	S	Scale number					
[out]	C	Scale capacity					

Table 5-34. Scale Operation Methods

Methods	Description
GetTotal 882D	Sets V to the current value for totalizer T , scale S Method Signature: function GetTotal (S : Integer; T : Integer; V : Real) : SysCode; Parameters: [in] S Scale number [in] T Totalizer number (0=master totalizer, 1=totalizer 1, 2=totalizer 2) [out] V Current belt totalizer value SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidTotalizer The totalizer specified by T does not exist SysOK The function completed successfully
ClearTotal 882D	Sets the value for totalizer T , scale S to zero Method Signature: function ResetBeltResetTotal (S : Integer; T : Integer) : SysCode; Parameters: [in] S Scale number [in] T Totalizer number (1=totalizer 1, 2=totalizer 2) SysCode values returned: SysInvalidScale The scale specified by S does not exist SysInvalidTotalizer The totalizer specified by T does not exist or the master totalizer (0) was specified SysOK The function completed successfully
GetLoad 882D	Sets V to the current belt load for scale S Method Signature: function GetLoad (S : Integer; V : Real) : SysCode; Parameters: [in] S Scale number [out] V Current belt load value SysCode values returned: SysInvalidScale The scale specified by S does not exist SysOK The function completed successfully
GetSpeed 882D	Sets V to the current belt speed for scale S Method Signature: function GetSpeed (S : Integer; V : Real) : SysCode; Parameters: [in] S Scale number [out] V Current belt speed SysCode values returned: SysInvalidScale The scale specified by S does not exist SysOK The function completed successfully
GetRate 882D	Sets V to the current belt rate value for scale S Method Signature: function GetRate (S : Integer; V : Real) : SysCode; Parameters: [in] S Scale number [out] V Current belt rate value SysCode values returned: SysInvalidScale The scale specified by S does not exist SysOK The function completed successfully

Table 5-34. Scale Operation Methods (Continued)

Methods	Description
GetTotalizerUnitsString 882D	Sets V to the text string representing the configured totalizer resolution units for scale S Method Signature: function GetTotalizerUnitsString (S : Integer; VAR V : String) : SysCode; Parameters: [in] S Scale number [out] V The configured totalizer resolution units string SysCode values returned: SysInvalidScale The scale specified by S does not exist SysOK The function completed successfully <i>Example:</i> CurrentTotalizerUnitsString : string; ... GetTotalizerUnitsString (1, CurrentTotalizerUnitsString);
GetLoadUnitsString 882D	Sets V to the text string representing the configured load units for scale S Method Signature: function GetLoadUnitsString (S : Integer; VAR V : String) : SysCode; Parameters: [in] S Scale number [out] V The configured load units string SysCode values returned: SysInvalidScale The scale specified by S does not exist SysOK The function completed successfully <i>Example:</i> CurrentLoadUnitsString : string; ... GetLoadUnitsString (1, CurrentLoadUnitsString); NOTE: Based on UNITS of METRIC (kg/m) or IMPERIAL (lb/ft)
GetSpeedUnitsString 882D	Sets V to the text string representing the configured belt speed units for scale S Method Signature: function GetSpeedUnitsString (S : Integer; VAR V : String) : SysCode; Parameters: [in] S Scale number [out] V The configured belt speed units string SysCode values returned: SysInvalidScale The scale specified by S does not exist SysOK The function completed successfully <i>Example:</i> CurrentSpeedUnitsString : string; ... GetSpeedUnitsString (1, CurrentSpeedUnitsString);

Table 5-34. Scale Operation Methods (Continued)

Methods	Description										
GetRateUnitsString 882D	<p>Sets V to the text string representing the configured rate resolution units for scale S</p> <p>Method Signature: function GetRateUnitsString (S : Integer; VAR V : String) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>S</td> <td>Scale number</td> </tr> <tr> <td>[out]</td> <td>V</td> <td>The configured rate resolution units string</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysInvalidScale</td> <td>The scale specified by S does not exist</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i></p> <pre>CurrentRateUnitsString : string; ... GetRateUnitsString (1, CurrentRateUnitsString);</pre>	[in]	S	Scale number	[out]	V	The configured rate resolution units string	SysInvalidScale	The scale specified by S does not exist	SysOK	The function completed successfully
[in]	S	Scale number									
[out]	V	The configured rate resolution units string									
SysInvalidScale	The scale specified by S does not exist										
SysOK	The function completed successfully										

Table 5-34. Scale Operation Methods (Continued)

5.22 Alibi Records

Command	Description												
AlibiSend 1280	<p>Write the requested alibi record to the requested port.</p> <p>Method Signature: function AlibiSend# (R : Integer, P : Integer) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>R</td> <td>Alibi record number</td> </tr> <tr> <td>[in]</td> <td>P</td> <td>Port number</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysNoSuchRecord</td> <td>Requested Alibi record does not exist</td> </tr> <tr> <td>SysInvalidPort</td> <td>The port number specified is not valid</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i></p> <pre>AlibiSend(345, 1);</pre>	[in]	R	Alibi record number	[in]	P	Port number	SysNoSuchRecord	Requested Alibi record does not exist	SysInvalidPort	The port number specified is not valid	SysOK	The function completed successfully
[in]	R	Alibi record number											
[in]	P	Port number											
SysNoSuchRecord	Requested Alibi record does not exist												
SysInvalidPort	The port number specified is not valid												
SysOK	The function completed successfully												
AlibiLookup 1280	<p>Retrieve requested alibi record.</p> <p>NOTE: Each alibi record that ends with a “\” is saved.</p> <p>Method Signature: function AlibiLookup# (R : Integer, VAR S : String) : SysCode;</p> <p>Parameters:</p> <table> <tr> <td>[in]</td> <td>R</td> <td>Alibi record number</td> </tr> </table> <p>SysCode values returned:</p> <table> <tr> <td>SysNoSuchRecord</td> <td>Requested Alibi record does not exist</td> </tr> <tr> <td>SysInvalidPort</td> <td>Insufficient string space available</td> </tr> <tr> <td>SysOK</td> <td>The function completed successfully</td> </tr> </table> <p><i>Example:</i></p> <pre>AlibiRecordString : string; ... AlibiLookup(345, AlibiLookupString);</pre>	[in]	R	Alibi record number	SysNoSuchRecord	Requested Alibi record does not exist	SysInvalidPort	Insufficient string space available	SysOK	The function completed successfully			
[in]	R	Alibi record number											
SysNoSuchRecord	Requested Alibi record does not exist												
SysInvalidPort	Insufficient string space available												
SysOK	The function completed successfully												

Table 5-35. Alibi Record Commands

6.0 Appendix

This section provides additional information about the iRite software.

6.1 Event Handlers

For even handler details, see the following information:

Handler	Description
AlertHandler	Runs when an error is generated from an attached iQUBE; Use the EventString function to retrieve the error message displayed by the 920i
BusCommandHandler	Runs when new input data is received on the fieldbus; GetImage() or GetImageReal() must be called before the BusCommandHandler() will be activated again; A new activation of the handler will occur when new input data is present on the bus
ClearKeyPressed	Runs when the CLR key on the numeric keypad is pressed
ClearKeyReleased	Runs when the CLR key on the numeric keypad is released
CmdxHandler	Runs when an F#x serial command is received on a serial port, where x is the F# command number, 1–32; The communications port number receiving the command and the text associated with the F#x command can be returned from the CmdxHandler using the EventPort and EventString functions (Table 5-9 on page 54)
ConnectionChar Received	Runs when a character is received on connection TCPC1-TCPC3 or PORT1-PORT32. EventConnection function determines which connection the character was received on. Eventchar function returns a one character string representing the character that caused the event. This handler will be queued up for the following events: <ul style="list-style-type: none"> • Data received on one of the TCP ports - TCPC1, TCPC2, TCPC3 • Data received on any of the serial ports - PORT1..PORT32 if there is no PortxCharReceived handler installed • The connection must be configured for Programmability NOTE: This is not the configured Alias. This is the same name to be used in the WriteOut/WriteOutLn APIs.
DiginSxByActivate	Runs when the digital input assigned to slot x, bit y is activated; Valid bit assignments for slot 0 are 1–4 (for 88x) or 1-6 (for 820i and 1280); Valid bit assignments for slots 1 through 14 are 1–24
DiginSxByDeactivate	Runs when the digital input assigned to slot x, bit y is deactivated; Valid bit assignments for slot 0 are 1–4 (for 88x) or 1-6 (for 820i and 1280); Valid bit assignments for slots 1 through 14 are 1–24
DotKeyPressed	Runs when the decimal point key on the numeric keypad is pressed
DotKeyReleased	Runs when the decimal point key on the numeric keypad is released
EnterKeyPressed	Runs when the ENTER key on the front panel is pressed
EnterKeyReleased	Runs when the ENTER key on the front panel is released
EventHid	For Rice Lake Weighing System use only
GrossNetKeyPressed	Runs when the GROSS/NET key is pressed (Not available in the 882D)
GrossNetKeyReleased	Runs when the GROSS/NET key is released (Not available in the 882D)
KeyPressed	Runs when any front panel key is pressed; Use the EventKey function within this handler to determine which key caused the event
KeyReleased	Runs when any front panel key is released; Use the EventKey function within this handler to determine which key caused the event
MajorKeyPressed	Runs when any of the five preceding major keys is pressed; Use the EventKey function within this handler to determine which key caused the event
MajorKeyReleased	Runs when any of the five preceding major keys is released; Use the EventKey function within this handler to determine which key caused the event
MenuKeyPressed	Runs when MENU key is pressed; Use the EventKey function within this handler to determine which key caused the event (880 and 882D only)
MenuKeyreleased	Runs when MENU key is released; Use the EventKey function within this handler to determine which key caused the event (880 and 882D only)
ModeKeyPressed	Runs when the MODE key is pressed (882D only)
ModeKeyReleased	Runs when the MODE key is released (882D only)

Table 6-1. Event Handlers

Handler	Description
NavDownKeyPressed	Runs when the DOWN navigation key is pressed
NavDownKeyReleased	Runs when the DOWN navigation key is released
NavKeyPressed	Runs when any of the navigation cluster keys (including ENTER) is pressed; Use the EventKey function within this handler to determine which key caused the event
NavKeyReleased	Runs when any of the navigation cluster keys (including ENTER) is released; Use the EventKey function within this handler to determine which key caused the event
NavLeftKeyPressed	Runs when the LEFT navigation key is pressed
NavLeftKeyReleased	Runs when the LEFT navigation key is released
NavRightKeyPressed	Runs when the RIGHT navigation key is pressed
NavRightKeyReleased	Runs when the RIGHT navigation key is released
NavUpKeyPressed	Runs when the UP navigation key is pressed
NavUpKeyReleased	Runs when the UP navigation key is released
NumericKeyPressed	Runs when any key on the numeric keypad (including CLR or decimal point) is pressed; Use the EventKey function within this handler to determine which key caused the event
NumericKeyReleased	Runs when any key on the numeric keypad (including CLR or decimal point) is released; Use the EventKey function within this handler to determine which key caused the event (Not supported in the 880 or 920i)
NxKeyPressed	Runs when a numeric key is pressed, where x=the key number 0–9
NxKeyReleased	Runs when a numeric key is released, where x=the key number 0–9
PortxCharReceived	Runs when a character is received on port x, where x is the port number, 1–32; Use the EventChar function within these handlers to return a one-character string representing the character that caused the event. This handler will only fire if the associated communications port is set to Programmability.
PrintFmtx	Runs when a print format x (1–10) that includes the event raised (<EV>) token is printed
PrintKeyPressed	Runs when the PRINT key is pressed
PrintKeyReleased	Runs when the PRINT key is released
ProgramStartup	Runs when the indicator is powered-up or when exiting setup mode
SetpointKeyPressed	Runs when the SETPOINT key is pressed (882D only)
SetpointKeyReleased	Runs when the SETPOINT key is released (882D only)
SoftKeyPressed	Runs when any softkey is pressed; Use the EventKey function within this handler to determine which key caused the event
SoftKeyReleased	Runs when any softkey is released; Use the EventKey function within this handler to determine which key caused the event
SoftxKeyPressed	Runs when softkey x is pressed, where x=the softkey number, 1–5, left to right
SoftxKeyReleased	Runs when softkey x is released, where x=the softkey number, 1–5, left to right
SPxTrip	Runs when setpoint x is tripped, where x is the setpoint number, 1–maximum number of supported setpoints
SPxReset	Reset trips when it achieves it setpoints and then drops below setpoint
TareKeyPressed	Runs when the TARE key is pressed (Not available in the 882D)
TareKeyReleased	Runs when the TARE key is released (Not available in the 882D)
TimerxTrip	Runs when timer x is tripped, where x is the timer number, 1–32
UIReset	Runs when a new browser connects or refreshes the screen; Use global variables to track prompt text, mode, and a flag to know if a prompt is open then re-prompt if desired
UnitsKeyPressed	Runs when the UNITS key is pressed (Not available in the 882D)
UnitsKeyReleased	Runs when the UNITS key is released (Not available in the 882D)
UserxKeyPressed	Runs when a user-defined softkey is pressed, where x is the user-defined key number, 1–10
UserxKeyReleased	Runs when a user-defined softkey is released, where x is the user-defined key number, 1–10
UserEntry	Runs when the ENTER key or Cancel softkey is pressed in response to a user prompt
WidgetClicked	Handler activated when any of the widgets are touched; Works with EventWidget API which returns the number of the widget that was clicked (1280 only)
xKeyReleased	This class of event handlers is activated when a key is released; The x is replaced with the name of the key; Key names are the same as for the xKeyPressed handlers NOTE: The xKeyReleased handlers are subject to the same timing considerations as all other user handlers. The events are queued in the order they are detected. Any handler that involves lengthy operations may delay the start of other handlers.
ZeroKeyPressed	Runs when the ZERO key is pressed
ZeroKeyReleased	Runs when the ZERO key is released

Table 6-1. Event Handlers (Continued)

6.2 Compiler Error Messages

For even handler details, see the following information:

Error Messages	Cause (Statement Type)
Argument is not a handler name	Enable/disable handler
Arguments must have intrinsic type	Write/Writeln
Array bound must be greater than zero	Type declaration
Array bound must be integer constant	Type declaration
Array is too large	Type declaration
Conditional expression must evaluate to a discrete data type	If/while statement
Constant object cannot be stored	Object declaration
Constant object must have initializer	Object declaration
Exit outside all loops	Exit statement
Expected array reference	Subscript reference
Expected object or function reference	Qualifying expression
Expression must be numeric	For statement
Expression type does not match declaration	Initializer
Function name overloads handler name	Function declaration uses name reserved for handler
Handlers may not be called	Procedure/function call
Identifier already declared in this scope	All declarations
Illegal comparison	Boolean expression
Index must be numeric	Subscript reference
Invalid qualifier	Qualifying expression
Loop index must be integer type	For statement
Name is not a subprogram	Procedure/function call
Name is not a valid handler name	Handler declaration
Not a member of qualified type	Qualifying expression
Only a function can return a value	Procedure/handler declaration
Operand must be integer or enumeration type	Function or procedure call
Operand must be integer type	Logical expression
Operand type mismatch	Expression
Parameter is not a valid l-value	Procedure/function call
Parameter type mismatch	Procedure/function call
Parameters cannot be declared constant	Subprogram declaration
Port parameter must be integer type	Write/Writeln
Procedure name overloads handler name	Procedure declaration uses name reserved for handler
Procedure reference expected	Subprogram invocation
Record fields cannot be declared constant	Type declaration
Record fields cannot be declared stored	Type declaration
Reference is not a valid assignment target	Assignment statement
Return is only allowed in a subprogram	Startup body
Return type mismatch	Return statement
Step value must be constant	For statement
Subprogram invocation is missing parameters	Procedure/function call
Syntax error	Any statement
Cannot find system files	Internal error
Compiler error — Context stack error	Internal error
Too many names declared in this context	Any declaration
Operand must be numeric	Numeric operators
Subprogram reference expected	Procedure/function call
Type mismatch in assignment	Assignment statement
Type reference expected	User-defined type name
Undefined identifier	Identifier not declared
VAR parameter type must match exactly	Procedure/function call
Wrong number of array subscripts	Subscript reference
Wrong number of parameters	Procedure/function call

Table 6-2. iRite Compiler Error Messages

6.3 Database Operations

The 1280, 820i, 880 and 882D use Revolution and the 920i uses iRev to edit, save, and restore databases. This section describes procedures for maintaining databases.

6.3.1 Uploading

To upload a database from the indicator (for viewing, editing, or backup), do the following:

1. Make a serial connection between the PC and the indicator.
2. Start Revolution/iRev.
3. Connect to the indicator by clicking on the **Connect** button on the right side of the top toolbar.
4. Click the **Database** bar on the left side of the Revolution/iRev window.
5. Click the **Data Editor** icon.
6. Select the database to upload, then click the **Upload** button on top right of the toolbar.
7. A status message box will confirm that Revolution/iRev is **Uploading Data**. When complete, the message will change to **Upload Complete. Please export your data to a delimited file for backup**. Press **OK**.

The contents of the indicator database can now be viewed, edited, or exported.



NOTE: Changing the database in Revolution/iRev does not change the database stored in the indicator; the existing indicator database must be cleared and replace it by downloading the edited database (Section 6.3.5 on page 117).

6.3.2 Exporting

For display, printing, or backup, save a database opened in Revolution/iRev to a text file by using the **Export** function.

1. With an open database uploaded to or created in Revolution/iRev, click **Export** on the top toolbar.
2. A dialog box is shown to select the separator (delimiter) to be used to separate the database fields.

Examples:

Tab-delimiting – *Elliot Robert 1234 555-8686*

Semi-colon delimiting – *Elliot;Robert;1234;555-8686*

3. Once delimiter is selected, press **Begin**. A prompt appears to choose where to store the text file, save it in the same folder as other program files.

When complete, a message box confirms **Export Successful**. The exported file can be used for viewing or printing the database, or for later import to Revolution for download to the indicator.

6.3.3 Importing

Import brings a previously exported text file into Revolution/iRev. The imported database can be downloaded to the indicator.

1. Start the Revolution/iRev Data Editor and select the table you into which you want to import data.
2. Press **Import** on the top toolbar.
3. A dialog box appears to select the file to import. Double click on the file to import.
4. The **Data Import Wizard** box appears that displays the first couple of rows of data in your file. **Notice that the field names are shown as the first row.** They should not be imported into the database since the field names are not part of the data. Click the up arrow next to **Start import at row:** prompt to start at row 2 (the actual data).
5. Press **Next** and select the separator (delimiter) character used when the file is exported (the default is tab-delimited).
6. Press **Next** again, then Press **Finish** to import the file. All of the data should now be displayed in Revolution/iRev. To download the imported database to the indicator, follow the procedure described in [Section 6.3.5](#).

6.3.4 Clearing

The **Clear All** button on the top of the toolbar in the Revolution/iRev Data Editor clears both the Revolution/iRev screen and the entire indicator database. The existing indicator database must be cleared before downloading edited data, but this function must be used with care to avoid losing data.

To clear a database:

1. Upload the database from the indicator ([Section 6.3.1 on page 116](#)).
2. Edit the database and fields, if necessary.
3. Use the **Export** function described in [Section 6.3.2 on page 116](#) to save a copy of the database.
4. Highlight all of the fields at once and copy them using either Ctrl-C or by choosing **Edit-Copy** from the toolbar.
5. Press the **Clear All** button to clear both the indicator database and the Revolution/iRev fields.
6. Upload the blank database from the indicator to ensure data integrity. The lock symbol on the Revolution/iRev screen will open, allowing a new database to be downloaded.
7. To replace the cleared database with edited data, move the cursor to the upper left-hand box and paste the copied data into the Revolution/iRev database. (Press Ctrl-V or choose **Edit-Paste** from the toolbar.)
8. Press the **Download** button to send fresh, edited data back down to the indicator ([Section 6.3.5](#)).

6.3.5 Downloading



NOTES: When downloading data to the indicator, it does not overwrite data that is there. Downloaded data is added to the database regardless of whether it is the same data. If uploaded data is edited in Revolution/iRev and is to be used to replace the indicator database, a **Clear All** must be done first, upload the cleared (blank) database, and then download the edited data ([Section 6.3.4](#))

1. Create or edit the data in the rows and columns to be entered in the database.
2. With the indicator connected, press the **Download** button at the top on the toolbar.
3. A status box shows the download progress (**Downloading Row [number] of [total rows]**). When complete, a **Download completed successfully** message is shown. The database is now stored in the indicator.

6.4 Fieldbus User Program Interface

(Not used with the 880 and 882D)

The fieldbus data APIs ([Section 5.7 on page 78](#)), two type definitions (BusImage, BusImageReal), and the EventPort function are used to manage fieldbus data.

The function of BusCommandHandler is similar to other user-written event handlers. When present and enabled with the EnableHandler(BusCommandHandler) call, the BusCommandHandler is activated every time a message is received on a fieldbus. Keeping the BusCommandHandler execution short is important in order to not miss data transfers on the fieldbus.

The normal operation of BusCommandHandler is expected to include the following system calls in the following order:

- EventPort
- GetImage, or GetImageReal
- SetImage, or SetImageReal

With intervening code to perform the required user functions. The SetImage or SetImageReal call should be as close to the end of the BusCommandHandler as possible.

The BusImage type is the data type passed in GetImage and SetImage (or, for real data, GetImageReal and SetImageReal).

GetImage(fieldbus_no : integer; var data : BusImage) : SysCode

This call returns an array of data as received from the fieldbus. As only the data elements received on the fieldbus are changed in a GetImage call, the array should be initialized prior to the GetImage call. The **fieldbus_no** is the number returned by an EventPort call from within the BusCommandHandler.

SetImage(fieldbus_no : integer; var data : BusImage) : SysCode

This call writes data to the fieldbus chip for access on the next cycle of the PLC. All data elements of the data array should be properly set before calling SetImage. The **fieldbus_no** is the number returned by an EventPort call from within the BusCommandHandler.

Example BusCommandHandler Code

```

-----
-- Handler Name : BusCommandHandler
-- Created By : Rice Lake Weighing Systems
-- Last Modified on : 1/16/2003
--
-- Purpose : Example handler skeleton.
--
-- Side Effects :
-----
handler BusCommandHandler;
--Declaration Section
busPort : integer;
data : BusImage;
i : integer;
result : SysCode;
begin
  -- Clear out the data array.
  for i := 1 to 32 loop
    data[i] := 0;
  end loop;

  -- Find out which port (which bus card) started this event.
  busPort := EventPort;

  -- Then read the received data.
  result := GetImage(busPort, data);

-- Test result as desired

-- Data interpretation and manipulation goes here.

  -- Finally, put the changed data back.
  result := SetImage(busPort, data);

-- Test result as desired

end;
```

6.5 Program to Retrieve Hardware Configuration

The HARDWARE serial command (see the indicator installation manual) returns a list of coded identifiers to describe which option cards are installed in a system. The following program provides a similar function by deciphering the coded values returned by the HARDWARE command and printing a list of installed option cards.



NOTE: This example is for a 920i. To prevent an Array Bounds error, the size of the array cannot exceed the number of available slots for the indicator type (920i = 14, 820i and 882D = 2, 880 = 1, and 1280 = 6). In addition, supported HW_array_type types vary depending on indicator type ([Section 4.0 on page 35](#)).

program Hardware;

```
my_array : HW_array_type;
```

```
handler User1KeyPressed;
```

```
i : integer;
begin
  Hardware(my_array);
  for i := 1 to 14
  loop
    if my_array[i] = NoCard then
      WriteLn(2,"Slot ",i," No Card");
    elsif my_array[i] = DualAtoD then
      WriteLn(2,"Slot ",i," DualAtoD");
    elsif my_array[i] = SingleAtoD then
      WriteLn(2,"Slot ",i," SingleAtoD");
    elsif my_array[i] = DualSerial then
      WriteLn(2,"Slot ",i," DualSerial");
    elsif my_array[i] = AnalogOut then
      WriteLn(2,"Slot ",i," AnalogOut");
    elsif my_array[i] = DigitalIO then
      WriteLn(2,"Slot ",i," DigitalIO");
    elsif my_array[i] = Pulse then
      WriteLn(2,"Slot ",i," Pulse");
    elsif my_array[i] = Memory then
      WriteLn(2,"Slot ",i," Memory");
    elsif my_array[i] = DeviceNet then
      WriteLn(2,"Slot ",i," DeviceNet");
    elsif my_array[i] = Profibus then
      WriteLn(2,"Slot ",i," Profibus");
    elsif my_array[i] = Ethernet then
      WriteLn(2,"Slot ",i," Ethernet");
    elsif my_array[i] = ABRIO then
      WriteLn(2,"Slot ",i," ABRIO");
    elsif my_array[i] = BCD then
      WriteLn(2,"Slot ",i," BCD");
    elsif my_array[i] = DSP2000 then
      WriteLn(2,"Slot ",i," DSP2000");
    elsif my_array[i] = AnalogInput then
      WriteLn(2,"Slot ",i," AnalogInput");
    elsif my_array[i] = ControlNet then
      WriteLn(2,"Slot ",i," ControlNet");
    elsif my_array[i] = DualAnalogOut then
      WriteLn(2,"Slot ",i," DualAnalogOut");
    end if;
  end loop;
  WriteLn(2,"");
end;
end Hardware;
```

6.6 920i User Graphics

iRite user programs can be used to display graphics. The entire 920i display is writable; graphics can be of any size, up to the full size of the 920i display, and up to 100 graphic images can be displayed. The actual number of graphics that can be loaded depends on the size of the graphics and of the user program, both of which reside in the user program space.

Graphics used in iRite programs can be from any source but must be saved as monochrome bitmap (.bmp) files with write access (file cannot be read-only). To enable the file for use in an iRite program, it is converted to a user program #include (.iri) file using the bmp2iri.exe program (Figure 6-1).




Figure 6-1. Example of Converting Bitmapped Graphic (prompt.bmp) to an .iri File

Figure 6-1 shows the conversion process for a graphic file, `prompt.bmp`, to a user program #include, `bitmap.iri`. The conversion is done by running the `bmp2iri.exe` program in a DOS command window: note that the `bmp2iri` program assumes the `.bmp` extension for the input graphic file (`prompt.bmp`). If additional files are converted using `bmp2iri.exe`, the output of the program is appended to the `bitmap.iri` file.

To display the graphic, the `bitmap.iri` file must be incorporated into the user program by doing the following

- In the iRite source (.src) file, immediately following the program declaration, add: **#include bitmap.iri**
- In the startup handler, call the array initialization routine for each graphic
- To display or erase a graphic, or to clear all graphics, call the DrawGraphic API with the appropriate parameters (Table 5-20 on page 81)



© Rice Lake Weighing Systems Content subject to change without notice.

230 W. Coleman St. • Rice Lake, WI 54868 • USA USA: 800-472-6703 • International: +1-715-234-9171